

EDWARDS UNDERGROUND
WATER DISTRICT

Report 93-01

**LEAK DETECTION SURVEY REPORT
FOR
THE BEXAR METROPOLITAN WATER DISTRICT**

February 10, 1992 - January 8, 1993



EDWARDS UNDERGROUND
WATER DISTRICT

5.4-5

April 30, 1993

Mr. Thomas C. Moreno
General Manager
Bexar Metropolitan Water District
2706 W. Southcross
San Antonio, Texas 78211-0577

Dear Mr. Moreno:

We are pleased to submit this final report of the leak detection survey performed on the Bexar Metropolitan Water District water system. A summary of findings is reported in separate categories for your convenience.

The Edwards Underground Water District (District) appreciates the cooperation and assistance you have provided during the leak detection survey. Special thanks to Jimmy DeLoach and his staff for their attention and patience during the survey. The District hopes that the information provided herein will be beneficial to the Bexar Metropolitan Water District in identifying and targeting areas of actual and potential water loss.

The District would appreciate the opportunity to recheck the remaining 41 leak sites after repairs are completed.

This survey has demonstrated the water saving potential of the Leak Detection Program. Maintaining the best possible program is vital in order to continue the successes that have been realized. For this reason, the District is soliciting your comments, both positive and negative, and any suggestions you may have on how to improve our program.

Please respond to this request candidly, as the District cannot improve on deficiencies or support positive measures without the knowledge of such conditions.

Enclosed is a water audit form. The District requests that this form be completed and returned to the District within sixty days after all detected leaks have been repaired. This information will assist the District in our continued assessment of the Leak Detection Program.

1615 N. ST. MARYS - P.O. BOX 15830
SAN ANTONIO TEXAS 78212-9030
210-222-2204
FAX 222-9869

Mr. Thomas C. Moreno
April 30, 1993 - Page 2

The Edwards Underground Water District commends the Bexar Metropolitan Water District for the implementation of an in-house leak detection/location program. The District stands ready to provide assistance and support, if needed by your staff in this worthy endeavor.

As always, it was a pleasure to work with you and your staff. Should you require leak detection assistance, additional information regarding this report, or have any water related questions, please do not hesitate to call.

Sincerely,



Charles E. Ahrens
Water Resources Planner III




James R. Shipley
Leak Detection Technician II

CEA:JRS/bmc
Enclosures

cc: Mr. Jimmy DeLoach, Field Maintenance Manager

050jrs



EDWARDS UNDERGROUND
WATER DISTRICT

LEAK DETECTION SURVEY REPORT
FOR
BEXAR METROPOLITAN WATER DISTRICT
SAN ANTONIO, TEXAS

FEBRUARY 10, 1992 - JANUARY 8, 1993

PREPARED BY:

The Edwards Underground Water District
Division of Planning & Environmental Management
Leak Detection Program

April, 1993

TABLE OF CONTENTS

	<u>PAGE</u>
SUMMARY.....	1
DISCUSSION.....	2
RECOMMENDATION.....	7
COMMENTS.....	8

APPENDICES

- A. Service Line Leaks
- B. Main Line Leaks
- C. Fire Hydrant Leaks
- D. Valve Leaks
- E. Meter Box Leaks
- F. Customer Side Leaks
- G. Services Added to Plats
- H. Fire Hydrants and Valves Added to Plats
- I. Unable to Survey/Valves
- J. Unable to Survey/Services
- K. Repairs Needed/Valve Stacks
- L. Repairs Needed/Meter Boxes
- M. Repairs Needed/General
- N. Curb Stop Not Holding
- O. Curb Stops Partly Open
- P. Cleaning Needed/Valve Stacks
- Q. Cleaning Needed/Meter Boxes
- R. Replacement Needed/Lids

ENCLOSURES TO REPORT

- A. Revised Master Water System Distribution Plat
- B. Blank Follow-up Water Audit Forms

SUMMARY

On September 3, 1991, the Edwards Underground Water District (EUWD) received a completed application form from the Bexar Metropolitan Water District (BMWD) requesting a leak detection/location survey on its water distribution system. A pre-survey conference was held January 9, 1991 at the BMWD main office to discuss the work to be performed. It was agreed that EUWD would perform sonic leak detection on all available access points, computerized leak location as needed, record any unusual system conditions found, and submit to the utility an updated master water plat with the final report.

Mark L. McGinnis and John E. Gapinski of EUWD began the survey on February 10, 1992, and the survey was concluded on January 8, 1993. Over the course of the survey, EUWD surveyed a total of 37,716 access points including 30,270 customer service connections, 2,066 fire hydrants, 5,257 valves, and 123 other access points covering 421.37 miles of distribution mains. Computer leak sound correlation was performed on 17 locations by EUWD and numerous other locations by BMWD personnel.

EUWD technicians detected a total of 1,907 leaks. This total included 354 meter box leaks, 143 fire hydrant leaks, 44 service leaks, 21 main line leaks, 19 main valve leaks, and 1,326 customer side leaks. EUWD estimates 547,596 gallons of water per day has been saved by the repair of 375 detected leaks as of January 8, 1993. Additionally, 165 leaks were repaired without leakage estimates. The leaks discovered during the survey range from 129,600 gallons per day to numerous small meter box leaks.

As part of the survey, EUWD located 417 service connections, 60 service valves, 19 main valves, 17 fire hydrants, and 5 blow offs with valves not shown on the master water plats. EUWD staff were unable to locate 1,251 service connections and 799 valves shown on the master water plats. An additional 1,404 valve stacks need cleaning and/or repair and 90 valve and meter box lids were discovered missing.

JRS/bmc
001jrs

DISCUSSION

- A. Total Access Points Surveyed.....37,716

The following number of access points were used during the survey:

- | | |
|----------------------------------|--------|
| 1. Customer service connections: | 30,270 |
| 2. Main Valves: | 5,257 |
| 3. Fire Hydrants: | 2,066 |
| 4. Others: | 123 |

- B. Total Miles of Distribution Main Surveyed.....421.37

- C. Total Number of Suspected Leak Sounds Rechecked.....3,555

- D. Total Leaks Detected.....1,907

Main line, service line, fire hydrant, and valve leaks were located by computer correlation of leak sounds or by visual inspection. Meter box leaks and customer side leaks were located through house to house surveying.

- E. Total Estimated Water Saved by Repair of Detected Leaks In Gallons Per Day as of January 7, 1993.....547,596 GPD

Leakage estimates for main line, service line, fire hydrants, and valve leaks are based on hole size and system pressure in P.S.I.. This information was furnished by B.M.W.D. personnel when EUWD was not on site at the time of repair. Totals are only recorded for leaks repaired as of January 7, 1993 with leakage estimates.

EUWD would appreciate a list of leakage estimates for all detected leaks required after January 7, 1993 for our records.

1. Meter Box Leaks.....354

Leakage estimates of repaired leaks.....	5,208.5 GPD
Leaks repaired with leakage estimates.....	179
Leaks repaired without leakage estimates.....	160
Leaks to be repaired.....	15

A list of these leaks is included in Appendix E.

2. Fire Hydrant Leaks.....143

Some fire hydrants may be reseated by flushing, others will need repair or replacement.

Leakage estimate of repaired hydrants.....	53,387 GPD
Leaks repaired with leakage estimates.....	125
Leaks repaired without leakage estimates.....	4
Leaks to be repaired.....	14

A list of these fire hydrants is included in Appendix C.

3. Service Line Leaks.....	44
Leakage estimates of repaired leaks.....	35,446 GPD
Leaks repaired with leakage estimates.....	41
Leaks repaired without leakage estimates.....	0
Leaks to be repaired.....	3
A list of service line leaks is included in Appendix A.	
4. Main Line Leaks.....	21
Leakage estimates of repaired leaks.....	451,644 GPD
Leaks repaired with leakage estimates.....	19
Leaks repaired without leakage estimates.....	0
Leaks to be repaired.....	2
A list of main line leaks is included in Appendix B.	
5. Main Valve Leaks.....	19
Leakage estimates of repaired leaks.....	1,910 GPD
Leaks repaired with leakage estimates.....	11
Leaks repaired without leakage estimates.....	1
Leaks to be repaired.....	7
A list of these leaks is included in Appendix D.	
6. Customer Side Leaks.....	1,326
Customer side leaks were generally small. No attempt was made to estimate this leakage. Customers were notified in person, when possible or will be notified by B.M.W.D. personnel.	
A list of these leaks is included in Appendix F.	
F. Locations To Recheck after Leak Repairs:.....	7
1. 301 Caladium	
2. 100 block of Persimmon	
3. Military @ West Ave.	
4. Loop 410 @ Biltmore	
5. 10614-15 Benchmark	
6. Loop 410 South of Honeysuckle	
7. 300 block of Monfort	
G. Survey Findings Vs. Master Water Plats	
1. Valves shown on plat that could not be located.....	799
Suspected locations were surveyed by EUWD with a ferromagnetic detector to locate buried main line valves. When successful, these locations were marked. It is conceivable that additional valves remain unlocated within the system. All valve box lids located were painted blue.	
A list of these valves is included in Appendix I.	

2. Services shown on the plat that could not be surveyed....1,251

Various reasons prevented the surveying of these services:
locked gates, dogs, under piles of trash or brush, under
parked vehicles, or unable to locate, etc.

A list of these services is included in Appendix J.

3. Services located, but not shown on plats.....417

A list of these services is included in Appendix G.

4. Fire hydrants or valves located, but not shown on plats....101

1. Fire hydrants.....17
2. Main Valves.....19
3. Service Valves.....60
4. Blow off Valves.....5

A list of these valves and hydrants is included in Appendix H.

Valves, fire hydrants, and services located were hand drawn
on the updated master water plats included with this report.

H. Miscellaneous Maintenance Needed

1. Valve stacks needing cleaning.....660

The condition of these valve stacks make them unusable at
this time.

A list of these valves is included in Appendix P.

2. Valve stacks needing repair.....744

The majority of these valve stacks need to be raised to grade.

A list of these valves is included in Appendix K.

3. Meter boxes needing cleaning.....19

The conditions of the boxes is such that meter reading is
difficult and the curb stops are inaccessible.

A list of these meter boxes is included in Appendix Q.

4. Meter Boxes Needing Repair.....109

The majority of these meter boxes or services need to be
raised to grade.

A list of these meter boxes is included in Appendix L.

5. Curb Stops not Holding.....48

The curb stops are passing water in the closed position, but
not leaking.

A list of these curb stops is included in Appendix N.

6. Curb Stops Partly Open.....112
 EUWD recommends that these stops be checked to determine if they will hold in the closed position.
 A list of these curb stops is included in Appendix O.
7. General Repairs Needed.....75
 The majority of this list is non-leaking curb stops with broken operating nuts.
 A list of these curb stops is included in Appendix M.
8. Missing Valve Box or Meter Box Lids.....90
 Valve Box Lids.....39
 Meter Box Lids.....51
 A list of these lids is included in Appendix R.
 The EUWD technicians consider the conditions recorded in the discussion sections G and H of this report to be normal system wear and tear. Most of these conditions are beyond the control of the utility. Street resurfacing, adjustment of street or rights of way grades, heavy rains, customers and plumbers removing meter boxes and operating of curb stops, etc. The consensus of the EUWD technicians is the overall operation and maintenance of the B.M.W.D. systems is excellent.
9. Revised Master Water Plats included with this report.
 1. The 456 pages of B.M.W.D. water system distribution plats used in this survey has been grouped into eight sections. Six sections for south San Antonio and one each for the cities of Castle Hills and Somerset.
 2. Codes
 Yellow indicates mains and services were surveyed from access points.
 Green indicates mains were surveyed with a ground microphone.*
 Blue indicates unable to survey.
 3. Abbreviations Used on Revised Master Plats:
 UTL - Unable to Locate
 UTS - Unable to Survey
 NC - Needs Cleaning
 RTG - Raise to Grade
 LG - Locked Gate
 CCNH - Curb Cock not Holding
 FHWV - Fire Hydrant with Valve
 FH - Fire Hydrant Without Valve
 ARV - Air Relief Valve
 Partly Open - Curb cock is not completely open.

- *4. All mains were surveyed from all available access points. The spacing between access points on these mains is too great to survey properly.
5. All valves located were surveyed. When direct contact could not be made on a valve, a probe rod was used.
6. Fire hydrants labeled on the plat as fire hydrants without lead valves are hydrants where the lead valve could not be located or does not exist.
7. Any item circled on the plat was added, could not be located, or needs repair.
8. All water mains, fire hydrants, water services, blow-offs, and main valves hand drawn on the plats, are for access point accounting. The location and placement of these items on the plat is intended to indicate what was actually found in the field survey. Placement of hand drawn main valves on the plat is the technicians best guess of what they control.
9. All addresses recorded on the appendices were taken from the B.M.W.D. water distribution system plats. When possible, addresses on these plats were changed to reflect actual addresses found in the field. In some instances actual addresses may be different that listed on plats.
10. Every effort was made to ensure the accuracy of these plats, but EUWD does not guarantee their accuracy.

JRS/bmc
002jrs

RECOMMENDATIONS

- I. Revise existing master water distribution plats. Add all mains, fire hydrants, blow offs, valves, and services located in the EUWD survey to the master water plats. Revised plats should be made available to the field supervisor and foremen for their use in the operation and maintenance of the water distribution system.
- II. Utilizing the revised master distribution plats, all distribution system main line valves should be located, adjusted, marked, cleaned, tested, and repaired or replaced as needed. The use of valve marked posts are recommended on main line valves subject to being lost or buried. Time spent searching for lost or buried main valves and flushing fire hydrants to reduce pressure and volume for leak repair is a major source of water loss.
- III. Implement an in-house main line valve preventive maintenance program for inspection and operation of all valves on a routine basis.
- IV. Implement a fire hydrant preventive maintenance program in-house or in conjunction with local fire department. All hydrants should be inspected, flushed, lubricated, and painted on a routine basis.
- V. Install lead valves as part of the installation on all new or replacement fire hydrants.

JRS/bmc
003jrs

COMMENTS

We wish to express our personal appreciation for the assistance and cooperation we received from the management and staff of the Bexar Metropolitan Water District. We applaud your interest in water conservation and the District's Leak Detection Program. We were grateful for the opportunity to survey your water system. Management's professional and progressive approach to serving the needs of their customers while helping to conserve a valued resource is commendable. All personnel we worked with were highly trained, meticulous in the performance of their duties, and had a very positive attitude about their jobs and the customers they serve.


The active participation of Joe Castillo, Ike Martinez, and the other Bexar Metropolitan Water District staff members that assisted in this survey is greatly appreciated. Their knowledge, experience, enthusiasm, and professional work habits contributed to its success.

Your efforts and timely repair of the leaks discovered in this survey have saved a significant amount of precious water. Our thanks to all the staff for your efforts in helping conserve the Edwards Aquifer.


Sincerely,



James R. Shipley
Leak Detection Technician II



Mark. L. McGinnis
Leak Detection Technician I



John E. Gapinski
Leak Detection Technician I

JRS:MLM:JEG/bmc

004jrs

APPENDIX A
Edwards Underground Water District
Service Leak List
1992

System: Bexar Metropolitan Water District

Page 1 of 3

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
1	2/12	H-7.1	850 Division	120	2/13/92	Short Service	7/20
2	2/21	K-4.2	122 Sioux	19,992	2/21/92	Corp. Leak	7/20
3	2/24	N-4.4	3111 Aragon	10,512	3/30/92	Corp. Leak	7/20
4	4/1	N-4.2	143 Ike	1440	4/4/92	Corp. Leak	7/20
5	4/1	N-4.4	3110 Aragon	7920	4/1/92	Long Service	7/20
6	4/1	O-5.4	12251 Applewhite	360	4/2/92	Pinhole	4/2
7	4/7	M-5.2	9211 Lytle	500	8/13/92		9/22
8	4/28	K-7.3	2822 Commercial	N/A	Unknown	Short Service	9/22
9	4/30	J-7.4	1018 Grosvenor	8.64	8/19/92	Short Service	9/22
10	5/5	L-6.1	1530 Parnell	259	5/11/92	Corp. Leak	12/1
11	5/5	N-8.1	307 W. Mally	1	7/17/92		7/20
12	5/7	K-5.4	1503 W. Vestal	1440	5/7/92	Flare Leak	7/17
13	5/11	L-7.4	1430 Escalon	1800	5/13/92	Corp. Leak	5/27
14	5/15	K-8.3	119 Drury	N/A	7/17/92		7/17
15	6/8	K-9.3	551 Ware	N/A	Unknown	Long Service	12/1
16	6/11	K-9.1	3602 Hwy 281	20	6/12/92	Corp. Flare Leak	6/12
17	6/15	J-8.4	1012 S.W. Military	N/A	6/18/92		7/22
18	6/15	J-8.3	600 S.W. Military	N/A	Unknown	Service 28329	12/1
19	7/1	J-8.4	430 Grosvenor	1	7/1/92	Short Service	7/1
20	7/10	K-7.2	614 Sunglo	120	8/13/92	Short Service	8/13
21	7/10	N-5.2	1913 Olimito	18	8/19/92	Corp. Leak	9/22

APPENDIX A

Edwards Underground Water District Service Leak List 1992

System: Bexar Metropolitan Water District

Page 2

3

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
22	7/15	J-9.2	117 W. Dickson	10	7/24/92	Flare Leak	7/24
23	7/18	J-7.3	318 Burton	3	8/13/92	Corp. Leak	9/22
24	7/24	L-4.2	2970 Owasso	9	8/13/92		9/22
25	8/5	I-7.4	1211 Gerald	16	9/15/92	Pinhole in Copper	9/22
26	9/18	F-4.3	2852 Pletzt	16	9/15/92		
27	8/7	I-7.1	IH35 at Fitch	693	11/10/92	Pinhole in Service	11/1
28	10/6	P-5.1	1351 Merida	120	11/16/92	Pinhole in Corp.	
29	8/25	H-6.1	3850 Nogalitos	144	10/13/92		11/1
30	10/27	CF-3	6601 Blanco	3000	12/16/92		12/1
31	10/27	CF-3	304 Lochaven	360	11/9/92	Pinhole in Copper	11/1
32	10/27	CF-3	307 Lochaven	360	11/10/92		11/1
33	11/2	CG-2	111 Parade	12,960	11/12/92		11/1
34	11/8	CD-2	10114 Iron Oak	6640	11/25/92	Corp. Leak	11/2
35	10/26	CF-3	118 Thames			Not Repaired 1/8	
36	10/27	CF-3	105 Chattington			Not Repaired 1/8	
37	10/28	CF-2	101 Twinleaf	2880	11/25/92		12/1
38	11/2	CG-2	353 Towne Vue	1440	12/7/92		12/1
39	11/2	CG-2	106 Cornwall	1760	12/9/92		12/1

APPENDIX A

Edwards Underground Water District Service Leak List 1992

System: Bexar Metropolitan Water District

Page 3 of 3

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
40	11/2	CG-2	128 Lou Jon Circle	720	12/4/92	Corp. Leak	12/1
41	11/13	CG-3	104 Herweck	173	12/29	Flare Leak	1/8
42	11/16	CE-2	200 Tamworth	1440	12/11/92	Corp. Leak	12/1
43	11/23	CF-3	1103 Mt. Eden	2880	11/30	Hole in Corp.	12/1
44	11/30	CD-2	10602 Benchmark			Not Repaired	1/8

APPENDIX B
Edwards Underground Water District
Main Leak List
1992

System: Bexar Metropolitan Water District

Page 1 2

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
1	3/31	K-6.2	IH 35 @ South Park Mall	66,240	4/5/92	1/2" diameter hole	12/1
2	4/1	Q-5.4	Zarzamora @ Applewhite	31,680	4/2/92	Flange Leak	7/20
3	4/10	Q-5.2	2114 Loop 410	31,824	7/17/92	At Corp. Stop	7/20
4	5/11	L-6.1	1615 Parnell	95,040	5/13/92	4" Split	5/13
5	5/27	L-6.1	Clinton @ Southcross	23,760	5/27/92		5/27
6	6/17	J-4.4	S.W. Military @ Laredo Hwy.	129,600	6/25/92	Lead joint	6/25
7	7/31	J-8.2	318 W. Dickson	19,008	8/18/92	1-1/2" crack	8/28
8	8/14	J-6.1	1114 Kyle	15840	8/31/92	2" crack	8/31
9	9/2	J-3.2	Holder @ Price	1000	9/18/92	Joint leak in alley	9/18
10	9/9	I-4.4	219 Bynum	1000	9/24/92	In alley	9/24
11	8/19	CFS	Warwick	3600	9/21/92	Joint leak	11/4
12		SI-21.1	Johnson @ Mitchell	360	10/14/92	Fire hydrant Tee	10/1
13	9/16	E-4.1	1600 Gen. McMullen	7920	10/8/92	Joint Leak	10/1
14	10/6	D-4.1	Chipinque @ Gen. McMullen	1440	11/5/92	Elbow before valve	12/1
15	7/17	I-8.4	Tobar @ Gerald	120	11/10/92	Corp. Leak	11/1
16	7/30	J-7.1	838 McCauley	21,600	11/10/92	Circle Break	11/1
17	9/10	I-4.3	3003 W. Gerald	163	9/10/92		11/1
18	11/12	F-5.3	2108 Jupiter	864	Unknown	Coupling	12/1

APPENDIX B

Edwards Underground Water District Main Leak List 1992

System: Bexar Metropolitan Water District

Page 2 of 2

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
19	9/28	F-5.3	Saturn @ Jupiter	1440	Unknown	Joint leak	12/1
20	11/16	CE.3	217 Briarcliff			Not Repaired	11/8
21	12/9	CP.2	N.W. Military @ West Ave.			"	

APPENDIX C

Edwards Underground Water District Fire Hydrants Leak List 1992

System: Bexar Metropolitan Water District

Page 1 of 8

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
1	2/10	L-2.4	#C Plumnear @ Quintana	360	2/14/92	Reseated	7/20
2	2/21	K-4.3	#E Palo Alto @ Navajo	420	2/21/92	Reseated	7/20
3	2/21	K-3.2	#E La Violetta @ Baecke	720	4/23/92	Repaired	7/20
4	2/21	K-4.4	#H Yuma @ Somerset	420	2/21/92	Reseated	7/20
5	2/21	K-4.2	#E La Rosa @ Somerset 11	420	2/21/92	Reseated	7/20
6	2/21	L-4.2	#B Palo Alto @ Owasso	720	2/21/92	Reseated	7/20
7	2/28	K-4.3	#G Palo Alto @ Pima	360	2/13/92	Repaired	7/20
8	2/28	L-9.3	#D 702 Dodic	100	9/14/92	Reseated	9/22
9	3/9	W-4.2	#A Bradley @ Palo Alto	360	3/9/92	Reseated	7/20
10	3/16	M-3.2	I35 North of Palm Beach	720	3/23/92	Reseated	7/20
11	3/16	L-4.4	#E IH35 Across from Clovis St.	360	3/23/92	Reseated	7/20
12	3/18	M-3.3	#A 3740 Remigio	1440	4/10/92	Repaired	7/20
13	3/20	M-4.1	#C 3230 Anna Rose	360	3/23/92	Reseated	7/20
14	3/20	M-4.2	#D Anna Rose @ Prairie Hill	360	3/23/92	Reseated	7/20
15	3/23	M-3.2	#D 8903 Palm Crest	360	3/23/92	Reseated	7/20
16	3/23	M-3.2	#A 8803 Oletha	360	3/23/92	Reseated	7/20
17	3/13	M-4.2	#B Fair Meadows @ Palo Alto	360	3/23/92	Reseated	7/20

APPENDIX C

Edwards Underground Water District Fire Hydrants Leak List 1992

System: Bexar Metropolitan Water District

Page 2 of 8

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
18	3/13	M-4.1	#B 3110 Fort Parker	360	3/23/92	Reseated	7/20
19	3/31	K-5.3	IH35 Plat K-53	1440	4/28/92	Repaired	7/20
20	4/15	K-4.3	#D Navajo @ Glengarden	180	10/21/92	Repaired	12/11
21	3/18	M-3.2	#G Fair Meadows @ Somerset	180	7/2/92	Repaired	7/17
22	3/20	N-5.1	#D 1471 W. Villaret	360	4/14/92	Reseated	7/17
23	4/3	M-4.3	Hwy 16 South of Gillette	8306	7/7/92	Repaired	7/17
24	4/6	M-5.4	#D Ozalid @ Hunter	360	4/7/92	Reseated	7/17
25	4/7	M-5.3	#D Lytle @ Calais	720	4/17/92	Reseated	7/17
26	4/7	M-5.3	#F Lytle @ Edenvale	360	4/17/92	Reseated	7/17
27	4/9	L-5.2	#E Marek @ Peterson	180	Unknown		7/22
28	4/9	L-5.2	#B Marek @ Parnell	360	4/15/92	Reseated	7/17
29	4/9	L-6.1	#B Crenshaw @ Peterson	360	4/15/92	Reseated	7/17
30	4/17	M-6.4	#A Hunter @ Zarzamora	100	4/17/92	Reseated	7/17
31	4/14	N-6.2	#G 1426 W. Mally	360	9/14/92		9/22
32	4/7	M-5.4	#C 2138 Bane Blvd.	180	4/17/92		9/22
33	4/14	M-6.3	#H 915 Gillette	720	8/10/92	Repaired	9/22
34	4/20	M-6.1	#D 1534 Beverly Ann	720	8/10/92	Repaired	9/22
35	4/28	K-7.4	#F 834 Cantrell	360	5/6/92		7/20
36	4/29	K-6.2	#A 1334 Clovis	180	5/5/92		7/17

APPENDIX C

Edwards Underground Water District Fire Hydrants Leak List 1992

System: Bexar Metropolitan Water District

Page 3 of 8

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
37	4/30	K-7.1	#F 902 Sunglo	180	5/5/92		7/10
38	4/30	K-7.1	#C 1102 Sharmain	360	Unknown		9/22
39	4/30	K-5.4	#B IH35 @ Mango	100	Unknown		9/22
40	5/11	N-8.4	#D 207 Chavaneaux	180	5/15/92	Reseated	7/10
41	5/11	N-7.3	#A 4401 Commercial	720	5/15/92	Reseated	7/10
42	5/11	N-7.3	#B S. 410 @ Commercial	100	7/22/92	Reseated	7/22
43	5/11	J-8.4	#F 138 Grosvenor	360	9/14/92		9/22
44	5/12	L-8.1	#H Formosa @ Malcolm	100	5/20/92	Reseated	7/20
45	5/12	L-8.4	#B Garnett @ Petaluma	180	5/19/92	Reseated	7/20
46	5/15	K-8.1	#S 302 Sunglo	360	9/14/92		9/22
47	5/27	N-8.2	#D 202 Yukon	100	7/22/92	Reseated	7/22
48	5/27	N-9.1	#D 446 Pinehurst	100	7/22/92	Reseated	7/22
49	5/27	J-8.4	#N 405 Verne	360	6/8/92	Reseated	7/22
50	5/27	N-9.2	#B Yukon @ Yett	720	6/19/92	Reseated	7/22
51	5/28	M-9.4	#A Walhalla @ Lanier	180	6/22/92	Reseated	7/22
52	6/2	L-9.4	#F 358 E. Petaluma	2880	6/4/92	Repaired	7/22
53	6/2	M-8.2	#E 8807 Braburn	100	6/22/92	Reseated	7/22
54	6/2	L-9.3	#B 642 Saipan	1584	7/22/92	Repaired	7/22
55	6/3	L-8.3	#D 176 E. Petaluma	100	6/22/92	Reseated	7/22
56	6/3	L-8.2	#D 134 Creath	720	6/24/92	Reseated	7/22

APPENDIX C

Edwards Underground Water District Fire Hydrants Leak List 1992

System: Bexar Metropolitan Water District

Page 4 of 8

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
57	6/3	L-9.2	#G Fournier @ Creath	720	6/3/92	Reseated	7/20
58	6/5	O-10.2	#B Estancia @ US281	360	6/15/92	Reseated	7/20
59	6/5	O-10.3	#A 10102 US 281 @ Socorro	360	7/1/92	Reseated	7/1
60	6/8	K-9.3	#J 7931 S. Flores	180	6/8/92	Reseated	7/22
61	6/10	K-9.2	#D Sussex @ S. Flores	360	6/25/92	Reseated	6/25
62	6/10	K-9.2	#B 459 Shrine	720	6/24/92	Reseated	6/24
63	6/15	J-8.4	#G Mango @ S.W. Military	180	6/19/92	Reseated	6/19
64	6/15	J-8.3	#B Pleasanton @ S. W. Military	180	7/22/92	Reseated	7/22
65	6/16	J-6.3	#B 2310 SW Military	100	6/19/92	Reseated	6/19
66	6/19	J-8.2	#A Pleasanton @ McCauley	360	6/17/92	Reseated	7/22
67	6/19	J-9.1	#G Wiggins @ S. Flores	180	7/22/92	Reseated	7/22
68	7/6	J-9.4	#C Behind 152 W. Dickson	100	7/6/92	Reseated	7/6
69	7/16	J-8.1	#B 238 McCauley	180	7/23/92	Reseated	8/13
70	7/16	J-8.1	#H 146 W. Mayfield	360	7/23/92	Reseated	7/23
71	7/16	J-8.1	#G 680 W. Pyron	360	10/21/92		12/11
72	7/17	I-8.3	#B 139 E. Gerald	180	7/23/92		9/22
73	7/20	I-7.2	#B 702 Brunswick	180	7/24/92	Reseated	7/24
74	7/20	H-8.4	#D 443 Stonewall	100	7/24/92	Reseated	7/24

APPENDIX C
Edwards Underground Water District
Fire Hydrants Leak List
1992

System: Bexar Metropolitan Water District

Page 5 of 8

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
75	7/27	J-7.3	#I 634 Rayburn	720	7/24/92	Repaired	9/22
76	7/28	I-7.3	#D 494 Burchan	360	7/28/92	Reseated	7/28
77	7/30	J-6.3	#O 1128 Rayburn	180	10/21/92	Repaired	12/11
78	7/30	J-7.1	#G 1002 McCauley	100	8/5/92	Reseated	8/5
79	7/30	J-6.3	#C Rayburn @ IH35	360	8/4/92	Reseated	8/4
80	8/5	J-6.4	#M 6202 Zarzamora @ Vickers	360	8/20/92	Reseated	8/20
81	8/6	I-7.1	#A 726 W. Southcross	180	10/21/92	Repaired	10/21
82	8/12	I-6.1	#R 1352 Harlan	360	8/13/92	Reseated	8/13
83	8/12	H-7.3	#A 803 Stonewall	360	8/14/92	Reseated	8/14
84	8/12	H-6.2	#L 1402 Stonewall	1440	8/20/92	Reseated	8/20
85	8/12	H-6.4	#H 5330 Zarzamora	360	8/20/92	Reseated	8/20
86	8/12	H-6.3	#N 400 Humboldt	180	8/20/92	Reseated	8/20
87	8/17	H-6.2	#C 1303 Keats	180	8/21/92	Reseated	8/21
88	8/18	H-6.2	#F 1400 Crystal	180	8/21/92	Reseated	8/21
89	8/18	H-6.2	#D 1303 Chalmers	360	8/20/92	Repaired	8/20
90	8/18	H-6.2	#K 1302 Vermont	360	8/20/92	Reseated	8/20
91	8/18	H-7.2	#D 834 Vermont	360	8/20/92	Reseated	8/20
92	8/14	H-7.1	#C 1000 Crystal	360	8/21/92	Reseated	8/21
93	8/18	H-6.4	#D 116 Somerset	180	8/28/92	Reseated	8/28
94	8/31	J-5.2	#H 1900 W. Pyron	180	9/2/92	Reseated	9/14
95	9/1	J-5.3	#A 1826 Rayburn	180	10/21/92	Repaired	12/11

APPENDIX C

Edwards Underground Water District
Fire Hydrants Leak List
1992

System: Bexar Metropolitan Water DistrictPage 6 of 8

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
96	9/1	I-5.1	#E 314 Fay	360	9/1/92	Reseated	9/10
97	9/3	J-5.4	#C 1661 Somerset				
98	9/4	I-5.4	#A 183 King	100	9/14/92	Reseated	9/14
99	9/8	I-4.3	#L 332 King	180	Unknown		1/8
100	9/9	I-4.4	#B 129 Bynum				
101	9/9	I-4.3	#G Peabody @ Oregon	N/A	Unknown		
102	9/9	I-4.3	#A 3220 W. Gerald				
103	9/10	I-4.2	#A 2502 Southcross	N/A	Unknown		12/11
104	9/10	I-4.1	#I N. Southcross @	100	9/22/92	Reseated	9/22
105	9/11	H-4.2	#B 1129 Quintana				
106	9/11	G-4.3	#B Quintana under bridge	360	9/22/92	Reseated	9/22
107	9/14	F-4.1	#C 138 Bayville	360	Unknown		1/8
108	9/14	F-3.2	#B 178 Chesley	720	Unknown		1/8
109	9/15	F-4.2	#C Thompson @ 28th St.				
110	9/15	E-3.4	#A 3862 Bay	360	Unknown		1/8
111	9/15	F-4.4	#C 126 Nightingale	360	9/22/92	Reseated	9/22
112	9/17	F-4.2	#G 538 Academy	180	9/18/92	Reseated	9/18
113	9/17	E-5.4	#G Menefee @ Barclay	100	9/25/92	Reseated	9/25
114	10/1	D-4.3	1542 Ceralvo B	180	1/4/93	Repaired	1/8
115	10/1	D-4.4	203 Arteago K	720	10/8/92	Reseated	10/8

APPENDIX C

Edwards Underground Water District
Fire Hydrants Leak List
1992

System: Bexar Metropolitan Water DistrictPage 7 of 8

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
116	10/2	D-3.3	1202 Patton C	N/A	Unknown	Repaired	12/11
117	10/6	D-5.4	1334 Merida C	360	12/17/92	Repaired	12/17
118	10/7	D-4.2	231 Queretaro B	180	10/7/92	Reseated	10/8
119	10/16	SH-21.4	3rd St. @ Dixon B	360	Unknown	Repaired	12/8
120	9/9	I-4.3	2614 Gerald B	360	10/23		10/23
121	9/28	F-5.3	2103 Jupiter D	180	11/12/92		12/11
122	10/21	Q-0.4	Fisher Rd. D	180	11/19/92		
123	11/2	CG-2	102 Rivera				
124	11/13	CG-3	109 Lou-Jon Circle				
125	11/13	CG-3	118 Herwick				
126	11/13	CG-3	213 Atwater				
127	11/17	CE-2	119 Dogwood				
128	11/17	CE-2	100 Tamworth	360	11/19/92	Reseated	11/19
129	11/18	CD-2	Lockhill Selma @ Manton	17	1/8/93	Reseated	1/8/93
130	11/18	CF-3	Lockhill Selma @ Northcrest	180	12/2/92	Reseated	12/9
131	11/23	CE-3	Carolwood @ Mt. Eden	180	12/17/92	Reseated	12/17
132	11/23	CF-3	1118 Mt. Rainer			Not Repaired 1/8	
133	11/23	CD-3	1010 Grey Oak	180	12/17/92	Reseated	12/17
134	11/24	CD-3	10107 Carolwood	100	12/9/92	Reseated	12/9

APPENDIX C

Edwards Underground Water District
Fire Hydrants Leak List
1992System: Bexar Metropolitan Water DistrictPage 8 of 8

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
135	11/24	CD-3	1106 Spentwood	180	12/9/92	Reseated	12/9
136	11/30	CD-3	102 Spanish Oak	180	12/9/92	Reseated	12/9
137	11/30	CD-3	10603 Benchmark	360	12/9/92	Reseated	12/9
138	12/4	CE-2	111 Lemonwood	180	12/9/92	Reseated	12/9
139	12/4	CE-2	210 Zornia				
140	12/4	CE-2	Military @ Manton				
141	12/7	CE-1	Hibiscus @ West Ave. 100		12/9/92	Reseated	12/9
142	12/7	CD-1	109 West Castle				
143	12/9	CE-2	211 Caladium				

APPENDIX D

Edwards Underground Water District
Valve Leak List
1992

System: Bexar Metropolitan Water DistrictPage 1 of 2

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
1	3/17	M-3.2	Somerset @ IH35	1	7/17/92	Operated Valve	7/20
2	4/10	L-6.1	W. Hutchins @ Zarmamora			Valve #34	
3	6/10	K-9.4	302 E. Vestal	360	6/25/96	Valve #3	7/3
4	6/7	J-3.3	S.W. Military @ Bynum	1440	6/24/92	Repaired	7/3
5	7/29	J-7.2	Brunswick @ Bruhn	2	11/9/92	Operated Valve	11/9
6	8/18	H-6.2	1202 Crystal	1	9/22/92	"	9/22
7	8/18	H-7.1	1102 Crystal	1	9/22/92	"	7/22
8	8/26	J-6.1	W. Pyron @ Zarzamora	1	9/24/92	Valve #9	
9	9/1	I-5.2	1900 W. Pyron	1	9/24/92	Valve #13	
10	10/9	SI22.2	6965 FM 1604	2	10/14/92	Blow Off	10/1
11	9/18	F-4.3	258 W. Gramercy	1	9/18/92	Operated Valve	9/18
12	11/17	C-F.3	217 Briarcliff		1/8-Not Repaired	Service Valve	
13	11/23	CE-3	902 Mt. Krusco		1/8-Not Repaired		
14	12/9	CE-2	Pump Station #2		1/8-Not Repaired	Valve 25, 81	
15	12/4	CE-2	2002 N.W. Military		1/8-Not Repaired		
16	12/9	CE-3	Biltmore		1/8-Not Repaired	Blow Off Leak	
17	11/3	CG-3	116 Cas-Hills	100	12/10/92	Repaired	12/1
18	11/18	CD-2	10134 Jandre	N/A	1/8/92	Blow Off	

APPENDIX D
Edwards Underground Water District
Valve Leak List
1992

System: Bexar Metropolitan Water District

Page 2 of 2

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
19	12/9	CF-3	1007 410 Loop		Not Repaired	Service #29432 Valve @ Meatballs	

APPENDIX E
Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water District

Page 1 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
1	2/11	J-4.3	356 Kelsey	N/A	4/23/92	Inlet Washer	
2	2/11	J-4.4	246 Briggs	N/A	4/23/92		
3	2/11	J-4.4	253 Briggs	N/A	4/23/92		
4	2/11	J-3.3	7230 Hwy 81	N/A	4/23/92		
5	2/11	J-3.3	7326 Hwy 81	1	7/24/92	Inlet Washer	
6	2/11	J-3.3	529 Briggs	8.6	4/23/92	Outlet Washer	
7	2/11	J-3.3	417 Briggs	.5	Unknown	Curb Stop	7/20
8	2/11	J-3.3	3934 SW Military	.5	4/23/92	Curb Stop	7/20
9	2/12	K-4.2	200 Block of McArthur	.5	4/23/92	Service #19292	7/20
10	2/12	K-4.1	3138 La Violetta	10	4/23/92		
11	2/12	K-4.1	3111 La Violetta	N/A	7/24/92		
12	2/12	K-4.1	3139 La Violetta	50	4/23/92	Outlet Washer	
13	2/12	K-4.1	3314 La Violetta	8.6	4/24/92	Inlet Washer	
14	2/13	K-4.4	3110 Golden	.5	7/24/92	Inlet Washer	
15	2/13	M-3.2	8843 IH 35	N/A	7/24/92	Inlet Washer	
16	2/13	K-3.2	3410 Golden		7/24/92	Inlet Washer	
17	2/13	K-4.1	3223 La Rosa	9.9	7/23/92		
18	2/13		7310 Somerset Rd.	N/A	Unknown	Service @ Palo Alto - Outlet Washer	
19	2/14	J-3.3	546 Briggs	N/A	4/24/92	Outlet Washer	
20	2/14	J-3.3	509 Briggs	N/A	7/24/92	Inlet Washer	
21	2/17	L-4.2	2970 Owasso	N/A	7/24/92	Washers	

APPENDIX E

Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water DistrictPage 2 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
22	2/17	L-4.2	134 Iroquois	.5	7/24/92		
23	2/17	L-4.3	3130 Owasso	43	5/5/92	Outlet Washer	
24	2/17	L-4.1	3046 Kiowa	N/A	Unkown	Washers	9/24
25	2/18	K-4.3	119 Yuma	1	7/24/92		
26	2/18	K-4.3	2810 Fern Circle	682	2/18/92	Curb Stop	
27	2/18	K-4.2	135 Cree	N/A	Unknown		
28	2/18	K-5.4	2603 Misty Hollow	N/A	7/23/92		
29	2/18	K-4.4	211 Pima	N/A	7/23/92		
30	2/21		158 Navajo	N/A	7/23/92		
31	2/21	K-3.2	3266 Pitluk	N/A	3/12/92	Inlet Washer	
32	2/21	L-4.2	166 Mohawk	N/A	7/24/92	Inlet Washer	
33	2/21	K-4.4	242 Yuma	1	7/23/92	Outlet Washer	
34	2/21	K-4.3	119 Pima	N/A	7/23/92		
35	2/21	K-4.2	138 Cree	N/A	7/24/92		
36	2/21	K-4.2	118 Sioux	N/A	7/24/92		
37	2/25	P-4.1	10818 Gaylord	N/A	7/24/92	Inlet Washer	
38	2/27	N-4.1	3322 Coconino	N/A	7/24/92	Inlet Washer	
39	2/28	N-4.4	3107 Chamita	N/A	7/24/92	Inlet Washer	
40	2/28	N-4.4	3135 Chamita	N/A	7/24/92	Inlet Washer	
41	2/28	N-4.4	3242 Twining	.5	7/24/92	Outlet Washer	
42	2/28	N-4.4	3258 Twining	2	7/24/92	Outlet Washer	
43	3/2	K-4.3	2802 Fern Circle	1	7/24/92	Outlet Washer	

APPENDIX E

Edwards Underground Water District Meter Box Leak List 1992

System: Bexar Metropolitan Water District

Page 3 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
44	3/2	P-4.1	10900 Bending	1	3/2/92	Meter Nipple	7/20
45	3/4	N-4.1	318 Tedder	N/A	7/24/92	Meter Nipple	
46	3/4	N-3.2	475 Tedder	N/A	7/24/92	Meter Nipple	
47	3/9	N-4.1	150 Ike	1	3/9/92	Curb Stop	7/20
48	3/10	M-4.3	219 Spaatz	N/A	Unknown	Inlet Washer	9/24
49	3/10	M-4.3	119 Wainright	720	Unknown	Curb Stop	7/20
50	3/10	M-4.1	3111 Goose Creek	3	4/6/92	Curb Stop	7/20
51	3/10	M-4.4	242 Spaatz	N/A	7/24/92	Inlet Washer	
52	3/13	M-4.1	8723 Hunter Creek	.5	7/24/92	Outlet Washer	
53	3/13	M-4.2	2935 Fair Meadows	1	3/9/92	Washers	7/20
54	3/13	M-4.2	3226 Fort Parker	.5	Unknown	Inlet Washer	7/20
55	3/13	M-4.2	3214 Fort Parker	.5	7/17/92	Inlet Washer	
56	3/20	M-4.2	3023 Anna Rosa	1	7/24/92	Washers	
57	3/26	M-4.4	263 Wainwright	.5	7/24/92	Inlet Washer	
58	3/27	O-5.1	2338 SW Loop 410	1	7/24/92	Curb Stop	
59	3/27	O-5.1	2114 SW Loop 410	N/A	7/10/92	Meter Leak + Customer Side	
60	4/2	N-5.3	1923 Jennifer	N/A	7/24/92	Inlet Washer	
61	4/3	N-6.1	9442 Zarzamora	1	5/24/92	Inlet Washer	
62	4/6	M-5.1	2227 Abacus	1	5/24/92	Washers	
63	4/6	M-5.1	2311 Abacus	N/A			9/24
64	4/6	M-5.3	2107 Henrietta	N/A	7/24/92	Inlet Washer	

APPENDIX E

Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water DistrictPage 4 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
65	4/6	M-5.4	9219 Reagan	N/A	7/24/92	Outlet Washer	
66	4/7	M-5.3	1245 Gillette	N/A	7/24/92	Outlet Washer	
67	4/7	M-5.3	1911 Duluth	N/A	7/24/92	Outlet Washer	
68	4/7	M-5.3	1923 Duluth	N/A	7/24/92	Outlet Washer	
69	4/7	M-5.3	1926 Hunter	N/A	7/24/92	Outlet Washer	
70	4/7	M-5.2	2038 Ann Arbor	N/A	5/19/92	Outlet Washer	
71	4/7	M-5.2	9051 Lytle	N/A	5/19/92	Outlet Washer	
72	4/8	M-6.4	1742 Points West	N/A	5/20/92	Outlet Washer	
73	4/8	M-6.4	1735 Point West	N/A	5/20/92		
74	4/8	M-6.1	1706 Ann Arbor	N/A	5/19/92		7/24
75	4/8	M-6.4	9230 Silver Arrow	N/A	Unknown	Inlet Washer	
76	4/9	L-5.2	1938 W. Hutchins	N/A	5/19/92	Outlet Washer	7/24
77	4/9	L-6.1	1635 Peterson	N/A	5/19/92	Outlet Washer	7/24
78	4/13	N-7.1	748 W. Villaret	N/A	5/19/92	Outlet Washer	7/23
79	4/13	N-7.1	802 W. Villaret	N/A	5/19/92	Outlet Washer	7/24
80	4/13	N-6.2	903 W. Villaret	N/A	5/19/92	Outlet Washer	7/23
81	4/13	N-6.2	1243 W. Mally	N/A	5/19/92	Outlet Washer	7/24
82	4/13	M-6.3	1223 Edris	N/A	5/19/92	Outlet Washer	7/23
83	4/13	M-6.3	1227 Edris	N/A	5/19/92	Outlet Washer	7/23
84	4/14	N-6.2	1447 Caballero	N/A	5/20/92	Outlet Washer	7/23
85	4/14	M-7.4	703 Gillette	N/A	5/19/92	Outlet Washer	7/23

APPENDIX E
Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water District

Page 5 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
86	4/14	M-7.4	731 Gillette	N/A	6/2/92 5/22/92	Outlet Washer	7/23
87	4/15	N-6.1	1522 Edris	N/A	5/19/92		
88	4/15	M-6.3	935 Gillette	N/A	5/19/92		
89	4/16	M-6.1	1523 Beverly Ann	N/A	5/20/92		
90	4/16	M-6.1	1534 Beverly Ann	N/A	5/15/92	Outlet Washer	5/15
91	4/16	M-6.1	9026 Geraldine	N/A	5/15/92	Outlet Washer	5/15
92	4/18	M-6.4	9102 Silver Arrow	N/A	Unknown		9/24
93	4/20	L-6.2	8206 Forsen	1	Unknown		
94	4/21	M-7.2	416 W. Ansley	.5	8/4/92	Inlet Washer	
95	4/21	M-9.1	411 W. Ansley	N/A	Unknown		9/24
96	4/21	L-7.3	467 W. Petaluma	N/A	Unknown		9/24
97	4/27	K-6.3	1227 W. Vestal	N/A	Unknown	Outlet Washer	9/24
98	4/27	K-7.4	903 Drury	N/A	Unknown		9/24
99	4/28	L-7.1	911 W. Amber	1	8/4/92	Flare Leak	
100	4/28	K-7.3	2822 Commercial	.5	8/5/92	Inlet Washer	
101	4/30	J-7.4	234 Escalon	8.64	8/5/92	Inlet Washer	
102	4/30	K-8.2	1007 Clovis	N/A	5/19/92	Inlet Washer	
103	4/30	K-7.1	1430 W. Harding	N/A	5/19/92	Outlet Washer	
104	4/30	J-7.4	1018 Grosvenor	N/A	5/19/92	Outlet Washer	
105	4/30	K-7.1	1111 Sunglo	8	5/6/92	Outlet Washer	7/20
106	5/11	M-8.4	9011 Garnett	5	5/15/92	Outlet Washer	7/20

APPENDIX E

Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water DistrictPage 6 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
107	5/11	M-8.4	411 Gillette	N/A	5/27/92	Washers	7/20
108	5/11	M-8.4	371 Gillette	1	5/19/92	Curb Stop	7/20
109	5/11	N-8.1	369 W. Villaret	1	8/14/92	Outlet Washer	7/20
110	5/11	N-7.2	441 W. Villaret	N/A	5/13/92	Outlet Washer	7/20
111	5/11	N-8.1	335 W. Villaret	N/A	5/14/92	Inlet Washer	5/14
112	5/12	N-8.2	552 Moursund	120	5/15/92	Curb Stop	7/20
113	5/12	L-8.4	119 Hopkins	.5	8/4/92	Inlet Washer	7/20
114	5/12	M-8.1	154 Ansley	.5	8/4/92	Washer	7/20
115	5/13	L-8.4	142 Petaluma	N/A	Unknown	Inlet Washer	
116	5/14	K-7.3	703 W. Vestal	.5	5/15/92	Washers	7/29
117	5/15	N-8.1	307 W. Mally	N/A	Unknown		9/24
118	5/27	M-9.2	610 Baltzell	1	7/22/92	Washers	7/22
119	5/27	K-7.3	723 Aaron	.5	7/30/92		9/24
120	5/27	N-9.1	318 Pinehurst	N/A	Unknown	Outlet Washer	9/24
121	5/28	M-9.4	419 Lanier	2	Unknown	Inlet Washer	7/22
122	5/28	M-9.4	254 E. Baetz	1	Unknown	Inlet Washer	7/22
123	6/1	M-10.1	830 E. Ashley	2	7/24/92	Meter Change Out	7/24
124	6/1	L-9.3	810 E. Petaluma	1	7/28/92	Inlet Washer	
125	6/1	M-9.2	723 Ansley	1	7/24/92	Inlet Washer	
126	6/2	L-8.3	322 Saipan	1	Unknown	Inlet Washer	7/22
127	6/3	L-9.1	303 Creath	N/A	Unknown	Meter Nipple	9/24

APPENDIX E

Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water DistrictPage 7 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
128	6/3	L-8.2	100 Blk. of Formosa	144	Unknown	Service #17826 Curb Stop	7/22
129	6/3	L-9.1	163 Creath	.5	7/24/92	Inlet Washer	
130	6/3	L-9.2	382 E. Ackard	1	Unknown	Inlet Washer	7/22
131	6/3	L-8.2	210 E. Amber	N/A	Unknown	Outlet Washer	7/24
132	6/4	L-8.2	123 Langford	.5	7/22/92	Meter Replacement	7/24
133	6/4	L-8.2	122 Langford	.5	7/22/92	Inlet Washer	7/24
134	6/4	K-8.3	210 E. Hutchins	1	Unknown	Inlet Washer	7/22
135	6/4	I-9.1	155 Langford	1	Unknown	Inlet Washer	7/22
136	6/5	O-10.2	5510 US 281	N/A	Unknown	Meter Nipple	9/24
137	6/8	K-7.2	415 Burton	.5	8/14/92	Inlet Washer	7/22
138	6/8	J-8.4	507 Verne	.5	8/14/92	Outlet Washer	
139	6/8	K-9.4	419 Ware	1.5	6/24/92	Inlet Washer	7/24
140	6/8	K-9.4	326 Ware	360	6/9/92	Inlet Washer	7/6
141	6/9	K-9.3	706 Ware	N/A	Unknown	Inlet Washer	
142	6/10	K-9.1	407 Sussex	N/A	7/30/92	Washers	7/30
143	6/10	K-9.2	171 W. Harding	1	Unknown	Inlet Washers	7/24
144	6/10	K-9.2	459 Sussex	1	Unknown	Inlet Washers	7/24
145	6/10	K-8.3	151 Ware	1	7/6/92	Washers	7/27
146	6/10	K-10.4	226 Genevieve	.5	7/24/92	Inlet Washers	
147	6/10	K-10.4	247 Genevieve	N/A	7/30/92	Inlet Washers	
148	6/10	K-10.4	251 Genevieve	N/A	7/30/92	Outlet Washer	

APPENDIX E

Edwards Underground Water District Meter Box Leak List 1992

System: Bexar Metropolitan Water District

Page 8 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
149	6/15	H-8.4	327 Aaron	N/A	7/24/92	Outlet Washer	
150	6/15	J-8.3	684 SW Military	N/A	8/5/92		
151	6/15	O-10.2	1323 Sanco	1.5	7/30/92	Inlet Washer	
152	6/15	O-10.3	1427 Socorro	.5	7/24/92	Inlet Washer	
153	6/15	N-11.4	1534 E. Chavaneaux	1	7/29/92	Inlet Washer	7/29
154	6/15	O-11.2	1515 Sanco	N/A	Unknown	Inlet Washer	9/24
155	6/16	N-10.4	915 E. Chavaneaux	1	7/29/92	Inlet Washer	
156	6/16	J-7.4	1813 SW Military	N/A	9/22/92		
157	6/18	J-8.4	1012 SW Military	1	6/18/92	Inlet Washer	7/29
158	7/6	J-9.1	127 Kendalia	8.64	9/3/92	Inlet Washer	
159	7/7	J-9.1	128 Handley	N/A	9/4/92	Curb Stop	
160	7/7	J-8.2	333 W. Dickson	17.3	9/3/92	Inlet Washer	
161	7/7	J-8.2	118 E. Mayfield	N/A	9/3/92	Outlet Washer	
162	7/7	J-8.2	420 W. Pyron	N/A	7/21/92	Inlet Washer	
163	7/8	I-9.4	206 W. Huff	N/A	Unknown	Inlet Washer	
164	7/8	J-9.2	112 E. Pyron	3	7/21/92	Galv. 90	7/24
165	7/8	J-9.2	206 Congress	3	9/4/92	Curb Stop	
166	7/9	I-8.3	408 Cliff	3	9/4/92	Curb Stop	
167	7/9	I-8.3	10007 US 281	1	7/22/92	Outlet Washer	7/24
168	7/10	J-8.4	317 Rayburn	N/A	Unknown	Inlet Washer	7/23
169	7/16	J-8.1	655 W. Pyron	8.64	9/21/92		
170	7/17	J-8.4	211 Gerald	N/A	9/21/92		

APPENDIX E
Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water District

Page 9 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
171	7/17	I-8.1	223 Canavan	N/A	Unknown	Inlet Washer	
172	7/17	I-8.1	400 Canavan	25.92	7/28/92	Curb Stop	
173	7/20	H-8.4	546 Stonewall	N/A	9/3/92	Curb Stop	
174	7/20	H-8.4	562 Harlan	N/A	9/3/92	Curb Stop	
175	7/22	J-9.3	238 Vado	1.2	7/30/92	Inlet Washer	
176	7/27	J-7.2	531 McCauley	N/A	9/3/92	Curb Stop	
177	7/27	J-7.2	851 W. Pyron	N/A	7/29/92	Inlet Washer	
178	7/28	I-7.3	703 Gerald	N/A	9/3/92	Inlet Washer	
179	7/28	I-7.3	602 W. Southcross	N/A	9/3/92	Inlet Washer	
180	7/28	I-7.3	1510 Commercial	N/A	9/3/92		
181	7/29	H-7.3	602 Harlan	N/A	9/3/92		
182	7/29	I-7.2	519 W. Southcross	8.64	8/3/92	Inlet Washer	
183	7/29	I-7.2	431 Canavan	N/A	8/6/92	Inlet Washer	
184	7/29	I-7.2	451 Canavan	N/A	8/6/92	Washer	
185	7/29	I-7.2	502 Canavan	N/A	8/6/92	Washer	
186	7/29	I-7.2	509 Canavan	8.64	8/6/92	Washer	
187	7/29	I-7.2	512 Canavan	N/A	8/6/92	Washer	
188	7/29	I-7.2	767 Fitch	N/A	8/6/92	Outlet Washer	
189	7/29	I-7.2	727 Fitch	8.6	8/6/92	Curb Stop	
190	7/29	I-7.2	711 Fitch	N/A	8/6/92	Curb Stop	
191	7/29	I-7.2	906 McCauley	N/A	9/21/92	Curb Stop	
192	7/31	J-7.1	341 W. Mayfield	N/A	Unknown	Curb Stop	

APPENDIX E

Edwards Underground Water District Meter Box Leak List 1992

System: Bexar Metropolitan Water District

Page 10 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
193	7/31	J-7.1	346 W. Mayfield	25.9	9/3/92	Curb Stop	
194	8/3	J-6.1	1215 Kyle	1	8/10/92	Washer	8/10
195	8/3	J-6.3	1214 McCauley	N/A	Unknown		
196	8/3	J-6.3	1417 McCauley	8.64	8/6/92	Inlet Washer	
197	8/4	J-6.3	1228 W. Pyron	N/A	9/21/92	Outlet Washer	
198	8/4	J-6.3	1525 W. Pyron	N/A	9/21/92	Inlet Washer	
199	8/4	J-6.3	411 Whitman	N/A	9/21/92	Inlet Washer	
200	8/4	I-6.4	806 Whitman	N/A	9/21/92	Inlet Washer	
201	8/5	I-6.3	608 Vickers	25.92	9/23/92	Inlet Washer	
202	8/5	H-6.3	328 Elks			Inlet Washer	
203	8/5	I-6.4	814 Wagner	25.92	9/21/92		9/21
204	8/5	I-6.3	503 Wagner	N/A	9/21/92		
205	8/5	I-6.3	219 Wagner	N/A	Unknown	Inlet Washer	9/24
206	8/6	I-6.1	1210 W. Southcross	N/A	9/22/92	Outlet Washer	
207	8/6	I-6.1	916 W. Southcross	N/A	9/22/92	Inlet Washer	
208	8/6	I-7.1	5707 Macdona	N/A	9/22/92	Outlet Washer	
209	8/6	I-7.1	210 Adolph	8.64	9/22/92	Inlet Washer	
210	8/7	I-6.1	723 Berlin	N/A	9/22/92	Inlet Washer	
211	8/7	I-7.1	935 Fitch	43.2	8/24/92	Inlet Washer	
212	8/10	J-6.1	1336 Harlan			Curb Stop	
213	8/12	H-7.4	923 Stonewall	N/A	8/12/92		8/14
214	8/12	H-6.4	1427 Stonewall	8.64	9/22/92	Inlet Washer	9/22

APPENDIX E
Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water District

Page 11 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
215	8/12	H-6.3	311 Humboldt	8.64	9/14/92	Inlet Washer	
216	8/12	H-7.4	122 Humboldt	8.64	9/14/92	Inlet Washer	9/14
217	8/14	H-7.3	858 Flanders	N/A	10/1/92	Outlet Washer	
218	8/14	H-6.3	1403 Flanders	8.64	9/22/92	Outlet Washer	9/22
219	8/14	H-6.4	627 Elks	8.6	10/1/92	Inlet Washer	
220	8/14	H-6.3	348 Elks	N/A	10/1/92	Inlet Washer	
221	8/17	H-6.4	1533 Brighton	N/A	10/1/92	Curb Stop	
222	8/17	H-7.4	1151 Brighton	N/A	10/1/92	Curb Stop	
223	8/17	H-7.4	1029 Brighton	8.6	10/1/92	Curb Stop	
224	8/17	H-7.4	970 Brighton	N/A	10/1/92	Curb Stop	
225	8/17	H-6.2	1218 Keats	8.6	10/1/92	Inlet Washer	
226	8/17	H-7.1	947 Keats	40.3	10/14/92	Inlet Washer	
227	8/17	H-7.2	910 Keats	17.2	9/14/92	Curb Stop	
228	8/17	H-7.2	823 Keats	N/A	10/19/92	Curb Stop	
229	8/18	H-7.2	818 Keats	25.9	10/14/92	Inlet Washer	
230	8/18	H-7.1	1140 Chalmers	N/A	10/14/92	Curb Stop	
231	8/18	H-7.1	1142 Chalmers	17.2	10/14/92	Inlet Washers	
232	8/18	H-6.2	1208 Chalmers	17.2	10/14/92	Inlet Washers	
233	8/18	H-7.1	1118 Vermont	25.9	10/14/92	Outlet Washer	
234	8/18	H-7.1	944 Vermont	8.6	10/14/92	Inlet Washer	
235	8/18	H-7.2	815 Vermont	17.2	10/26/92	Inlet Washer	

APPENDIX E

Edwards Underground Water District Meter Box Leak List 1992

System: Bexar Metropolitan Water District

Page 12 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
236	8/18	H-7.1	870 Division	N/A	10/26/92	Curb Stop	
237	8/18	H-7.1	918 Division	25.9	10/26/92	Curb Stop	
238	8/18	H-7.1	938 Chalmers	8.6	10/26/92	Inlet Washer	
239	8/19	G-7.3	726 Carisle	25.9	10/26/92	Inlet Washer	
240	8/25	H-6.4	5419 Zarzamora	N/A	9/17/92	Outlet Washer	
241	8/26	I-6.1	1607 Southcross	25.8	10/26/92	Inlet Washer	
242	8/26	I-6.4	1709 Gerald	25.9	10/6/92	Inlet Washer	
243	8/26	I-5.3	1809 Gerald	8.6	10/26/92	Inlet Washer	
244	8/31	I-5.3	1414 Wagner	8.6	10/26/92	Inlet Washer	
245	8/31	I-5.3	2035 W. Pyron	8.6	10/26/92	Inlet Washer	
246	8/31	J-5.1	861 W. Mayfield	N/A	9/24/92	Flare @ Curb Stop	
247	9/1	J-5.4	1935 Rayburn	25.9	10/14/92	Inlet Washer	
248	9/1	J-5.3	1826 Rayburn	17.2	10/13/92	Curb Stop	
249	9/2	J-3.2	806 Price	43.2	9/15/92	Meter Leaking	
250	9/2	J-4.2	634 Fleming	N/A	10/27/92	Meter Leaking	
251	9/3	J-4.2	1661 Somerset	43.2	10/28/92	Inlet Washer	
252	9/3	J-3.2	610 McLaughlin	N/A	10/28/92	Inlet Washer	
253	9/3	J-3.2	687 McLaughlin	N/A	9/15/92	Curb Stop	
254	9/4	J-4.2	1033 W. Mayfield	43.2	9/15/92	Inlet Washer	
255	9/8	I-4.3	408 King	25.9	10/30/92	Inlet Washer Alley	
256	9/8	I-3.3	1018 King	N/A	10/30/92	Inlet Washer	

APPENDIX E

Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water DistrictPage 13 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
257	9/9	I-3.3	3220 Quintana	N/A	10/30/92		
258	9/10	I-4.2	303 #1 Wilcox	8.6	9/29/92	Inlet Washer	
259	9/10	I-4.2	2532 Southcross	N/A	10/30/92	Flare on Curb Stop	
260	9/11	H-4.3	226 Dacus	8.6	11/2/92		
261	9/11	H-4.3	201 Dacus	43.2	10/6/92	Inlet Washer	
262	9/11	H-4.3	231 Dacus	N/A	10/6/92	Flare @ Curb Stop	
263	9/11	H-4.3	1511 Quintana	N/A	11/2/92	"	
264	9/15	F-4.4	139 Ballard	N/A	10/6/92	Outlet Washer	
265	9/14	F-4.4	158 Felton	25.9	11/4/92	Inlet Washer	
266	9/14	F-3.3	118 Gorham	25.9	11/4/92	Inlet Washer	
267	9/16	F-4.4	102 Marlowe	N/A	11/10/92	Outlet Washer	
268	9/17	F-4.3	3131 Jane Ellen	17.2	11/4/92	Inlet Washer	
269	9/17	F-4.2	436 Academy	N/A	11/2/92	Outlet Washer	
270	9/17	F-4.2	436 Pletz	N/A	11/2/92		
271	9/18	F-4.3	238 Jewel	N/A	11/2/92		
272	9/18	F-4.3	223 Greenway	8.6	11/4/92		
273	9/18	F-4.3	242 Pletz	N/A	11/2/92	Outlet Washer	
274	9/23	F-5.1	330 W. Bedford	43.2	11/2/92	Inlet Washer	
275	9/23	H-6.1	3854 Nogalitos	8.6	11/10/92	Inlet Washer	
276	9/25	E-5.4	1202 W. Kirk	N/A	11/10/92	Outlet Washer	
277	9/25	E-5.4	2826 Depla	8.6	11/4/92	Inlet Washer	

APPENDIX E

Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water DistrictPage 14 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
278	9/28	E-5.4	900 W. Thompson	N/A	11/3/92	Outlet Washer	
279	9/28	E-5.4	3119 Mars	8.6	11/3/92	Inlet Washer	
280	9/29	F-5.2	853 W. Thompson	25.9	11/3/92	Inlet Washer	
281	9/29	F-5.2	849 W. Thompson	25.9	11/4/92	Inlet Washer	
282	9/29	F-5.2	842 W. Thompson	N/A	11/4/92	Inlet Washer	
283	9/29	F-5.2	819 Barrett	N/A	Unknown	Outlet Washer	
284	9/29	F-5.2	827 Barrett	17.2	10/1/92		
285	9/29	F-5.2	731 W. Kirk	25.9	10/2/92	Inlet Washer	
286	9/29	F-5.2	859 W. Kirk	8.6	11/4/92	Inlet Washer	
287	9/29	F-5.3	838 W. Harriman	N/A	12/23/92	Inlet Washer	
288	9/30	D-5.4	339 Patton	N/A	Unknown	Outlet Washer	
289	10/1	D-4.3	1725 Ceralvo	N/A	Unknown	Inlet Washer	11/10
290	10/1	D-4.3	1738 Ceralvo	N/A	Unknown	Inlet Washer	11/4
291	10/1	D-4.3	1919 Delfino	25.9	11/9/92	Inlet Washer	11/4
292	10/1	D-4.4	1923 Amerada	N/A	11/25/92	Inlet Washer	
293	10/1	D-4.4	432 Guanajuato	8.6	11/18/92	Inlet Washer	
294	10/1	D-3.3	426 Arteago			Not Repaired 1/8/92	
295	10/1	D-3.3	228 Amaya	8.6	11/18/92		
296	10/2	D-3.3	322 Amaya	8.6	11/18/92		
297	10/2	D-3.3	443 Amaya	8.6	11/18/92		
298	10/2	D-3.3	427 Aldama	8.6	11/18/92		

APPENDIX E

Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water DistrictPage 15 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
299	10/2	D-3.2	1723 Allende	8.6	11/25/92		
300	10/2	D-3.2	321 Sylvia	N/A	11/25/92		
301	10/6	D-3.2	103 Rocco			Needs Repair 1/8/93 Curb Stop	
302	10/6	D-5.1	211 Queretaro	8.6	10/8/92	Inlet Washer	
303	10/6	D-4.1	519 Chipinque			Needs Repair 1/8 Curb Stop	
304	10/6	D-4.1	518 Chipinque			"	
305	10/6	D-4.1	134 Escuela			Inlet Washer	
306	10/13	SI-21.1	19921 Somerset	360	10/19/92		
307	10/13	SI-21.1	20215 Somerset	720	10/10/92	Outlet Complex	10/16
308	10/15	SF-21.1	19770 Somerset	3	10/16/92	Bath Washer	10/16
309	10/16	SI-21.1	7871 Sixth St.			Not repaired 1/8	
310	8/25	H-6.1	211 Ames			Not Repaired 1/8 Inlet Washer	
311	9/11	G-4.2	South of 1990 Cupples Rd.	N/A	11/24		
312	10/26	CF-3	414 Thames			Not Repaired 1/8	
313	10/26	CF-3	126 Thames	3 GPD	Unknown	Outlet Washer	12/17
314	10/26	CF-3	626 Oban	3 GPD	Unknown	Inlet Washer	12/17
315	10/26	CF-3	734 Oban	8.6	1/4	1" Angle Stop	1/8
316	10/26	CF-3	622 Barchester	8.6	1/4	Angle Stop	1/8

APPENDIX E
Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water District

Page 16 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
317	10/26	CF-3	217 Atwater	25.9	10/26/92	Inlet Washer	1/8
318	10/27	CF-3	207 Sir Arthur	1	12/22	Inlet Washer	12/16
319	10/27	CF-2	368 Towne Vue	8.6	12/22	Inlet Washer	1/8
320	10/27	CF-2	132 Twinleaf	N/A	12/22	Outlet Washer	1/8
321	10/28	CF-2	109 Traventine			Inlet Washer	1/8
322	10/28	CF-2	112 Traventine			Inlet Washer	1/8
323	10/28	CF-2	605 Squires			Hole in Meter	
324	10/28	CF-2	124 Trillium	25.9	12/22		12/16
325	11/2	CG-2	102 Parade			Inlet Washer	
326	11/2	CG-2	108 Rivera	N/A	12/30	Outlet Washer	12/16
327	11/13	CG-3	201 Herwick	8.6	12/30	Inlet Washer	1/8
328	11/13	CG-3	100 Gardenview	8.6	12/28	Valve in Box Leak	12/17
329	11/18	CE-2	12571 Somerset Rd.	3 GPD	11/20	Curb Stop Leak (Flare)	11/20
330	11/18	CF-3	104 Briarcliff	1 GPD	12/28	Inlet Washer	12/16
331	11/18	CF-3	101 Northcrest	1 GPD	12/28	Outlet Washer	12/17
332	11/18	CF-3	10118 N. Manton Ln.	17.3	1/4	Curb Stop	12/17
333	11/23	CF-3	1006 Tamworth	8.6	12/2	Inlet Washer	12/17
334	11/23	CF-3	819 Tamworth	1 GPD	12/2		12/17
335	11/23	CF-3	803 Tamworth	17.3	12/2	Curb Stop Leaking	1/8
336	11/23	CF-3	1006 Mt. Rainer	3 GPD	12/28	Inlet Washer	1/8

APPENDIX E
Edwards Underground Water District
Meter Box Leak List
1992

System: Bexar Metropolitan Water District

Page 17 of 17

Line #	Date #	Plat	Address	Loss G.P.D.	Date Repaired	Comments	R/C Date
337	11/23	CF-3	1107 Mt. Rainer	8.6	12/28	Inlet Washer	12/17
338	11/24	CD-3	1019 Grey Oak	N/A	12/28	Outlet Washer	1/8
339	11/24	CD-3	1126 Hilton	8.6	12/28	Inlet Washer	1/8
340	11/24	CD-3	1110 Hilton	8.6	12/28	Inlet Washer	1/8
341	11/24	CD-3	1015 Spentwing	17.3	12/28	Inlet Washer	1/8
342	11/24	CD-3	1211 Mt. Riga	17.3	12/29	Curb Stop Leaking	1/8
343	11/24	CD-3	217 Glentower	25.9	12/15	Straight Curb Stop	1/8
344	12/3	CF-2	110 Krameria	8.6	12/30	Curb Stop Flare Leak	1/8
345	12/4	CE-2	210 Zornia	8.6	12/29	Curb Stop Leak	1/8
346	12/7	CD-1	110 West Castle	N/A	12/30	Outlet Washer	1/8
347	12/7	CF-2	114 Garden View	N/A	12/29	Outlet Washer	1/8
348	12/7	CF-2	109 Garden View	34.6	1/4/93	Curb Stop Leak	1/8
349	11/2	CG-2	219 Herwick	3 GPD	12/4	Curb Stop Leak	12/16
350	11/13	CG-3	112 Atwater	17.3	12/29		1/8
351	10/21	QE-1.4	11419 Somerset	10	11/20/92	Curb Stop Flare	12/20
352	11/18	CD-2	104 Martin	1 GPD	11/18	Brushing Repair	12/2
353	11/13	CG-3	607 Antler			Curb Stop	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 1 of 66

Line #	Date #	Address	Comments
1	2/11	346 Briggs	
2	2/12	3242 Pitluk	
3	2/13	3515 La Rosa	
4	2/14	3002 Pitluk	
5	2/14	3031 Pitluk	
6	2/14	2919 Pitluk	
7	2/14	2934 Pitluk	
8	2/17	219 Caddo	
9	2/17	130 Caddo	
10	2/17	8006 Somerset	
11	2/17	320 Iroquois	
12	2/17	201 Caddo	Packing Leak
13	2/17	251 Iroquois	Packing Leak
14	2/17	3115 Kiowa	Packing Leak
15	2/17	331 Iroquois	
16	2/18	115 Yuma A-B	
17	2/18	8014 Glengarden	
18	2/18	2947 Navajo	
19	2/18	2611 Misty Hollow	
20	2/18	231 Pima	
21	2/18	218 Pima	
22	2/18	2707 Coldstream	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 2 of 66

Line #	Date #	Address	Comments
23	2/18	2622 Sleepy Glade	
24	2/18	641 Briggs	
25	2/21	129 Briggs	
26	2/21	139 Briggs	
27	2/21	225 Briggs	
28	2/21	3507 Gracie	
29	2/21	7326 US 281	
30	2/21	737 Somerset	
31	2/21	2919 McArthur	
32	2/21	8851 IH 35	
33	2/21	3130 Golden	Front Faucet
34	2/21	3207 Golden	
35	2/21	3314 Golden	
36	2/21	3138 Pitluk	
37	2/21	109 Yvonne	
38	2/21	2927 Owasso	
39	2/21	2955 Owasso	
40	2/21	159 Caddo	
41	2/21	118 Palo Alto	
42	2/21	162 Mohawk	
43	2/21	225 Caddo	
44	2/21	307 Iroquois	Front Faucet

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 3 of 66

Line #	Date #	Address	Comments
45	2/21	3131 Kiowa	
46	2/21	201 Palo Alto	
47	2/21	____ Palo Alto	Service #16557
48	2/21	2830 Longmeadow	Front Faucet
49	2/21	2822 Longmeadow	
50	2/21	2818 Longmeadow	
51	2/21	2826 Moss Circle	
52	2/21	171 Pima	
53	2/21	142 Pima	
54	2/21	130 Yuma	
55	2/21	315 Palo Alto	
56	2/21	303 Palo Alto	
57	2/21	151 Cree	
58	2/21	2810 Moss Circle	
59	2/21	128 Briggs	
60	2/25	10809 Claymore	
61	2/25	3135 Durette	
62	2/25	3106 Bay Hurst	
63	2/25	3034 Bay Hurst	
64	2/25	3011 Wood Sage	
65	2/25	9615 Marie Isabell	
66	2/25	3101 Dana Circle	Front Faucet

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 4 of 66

Line #	Date #	Address	Comments
67	2/27	3322 Aragon	
68	2/27	3034 Coconino	
69	2/27	3215 Algo Dulce	
70	3/2	3022 Coconino	Customer Contacted
71	3/2	10819 Claymore	"
72	3/2	3058 Moss Springs	"
73	3/2	3035 Moss Springs	"
74	3/2	3027 Wood Sage	"
75	3/4	427 Tedder	"
76	3/4	10851 Hwy. 16	"
77	3/4	3027 Durette	
78	3/4	446 Tedder	
79	3/4	156 Vincent	
80	3/4	311 Vincent	
81	3/4	359 Tedder	
82	3/5	250 Ike	
83	3/5	2323 Palo Alto	
84	3/5	170 Ike	
85	3/6	114 McNarney	
86	3/6	243 Bradley	
87	3/9	303 Ike	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 7 of 66

Line #	Date #	Address	Comments
130	4/3	9311 Oden	
131	4/3	1115 W. Villaret	
132	4/3	1110 W. Villaret	
133	4/3	234 Cayo	
134	4/6	9023 Niner	
135	4/6	9039 Niner	
136	4/6	2103 Abacus	
137	4/7	9119 Lytle	Customer Contacted
138	4/7	9214 Rhonda	
139	4/7	9103 Hunter	Customer Contacted
140	4/7	1923 Ann Arbor	"
141	4/7	9138 Lytle	
142	4/7	1915 Calais	
143	4/7	9015 Buda	
144	4/8	2515 Patron	Front Faucet
145	4/8	2619 Patron	
146	4/8	1810 Ann Arbor	Front Faucet
147	4/9	1811 Parnell	"
148	4/9	1934 W. Hutchins	
149	4/9	1918 W. Hutchins	
150	4/10	8030 Zarzamora	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 8 of 68

Line #	Date #	Address	Comments
151	4/13	1069 W. Villaret	Customer Contacted
152	4/13	1051 W. Villaret	"
153	4/13	859 Rockwell	"
154	4/13	910 W. Villaret	
155	4/13	1230 W. Mally	Customer Contacted
156	4/13	4235 Commercial	Front Faucet
157	4/14	1515 Edris	Customer Contacted
158	4/14	1402 Edris	"
159	4/14	1518 Edris	Front Faucet
160	4/14	1442 Edris	Customer Contacted
161	4/14	842 Gillette	
162	4/14	1522 Caballero	Customer Contacted
163	4/15	1030 Baetz	"
164	4/15	831 Baetz	"
165	4/15	1527 Hunter	
166	4/15	1531 Beverly Ann	
167	4/16	9223 Ozalid	
168	4/16	1526 Betty	
169	4/16	4154 Commercial	
170	4/16	1530 Betty	
171	4/16	1506 Betty	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 9 of 66

Line #	Date #	Address	Comments
172	4/18	1403 Parnell	
173	4/20	1507 W. Vestal	
174	4/20	8023 Cuff	Customer Contacted
175	4/20	1522 Peterson	
176	4/20	1419 Ackard	Customer Contacted
177	4/20	8311 Kingley	
178	4/21	3703 Commercial	
179	4/22	1419 Escalon	
180	4/22	1503 Escalon	Customer Contacted
181	4/22	602 Petaluma	
182	4/22	3553 Commercial	
183	4/22	3552 Commercial	
184	4/22	1306 Cullin	
185	4/22	1219 Cullin	
186	4/22	1235 W. Amber	Customer Contacted
187	4/22	1338 W. Amber	"
188	4/27	1130 W. Vestal	"
189	4/27	1134 W. Vestal	"
190	4/27	1018 W. Vestal	
191	4/27	1227 W. Vestal	Customer Contacted
192	4/27	1223 W. Vestal	"

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 10 of 66

Line #	Date #	Address	Comments
193	4/27	923 Drury	
194	4/27	939 Drury	
195	4/27	939 Cantrell	
196	4/27	1011 Cantrell	
197	4/27	1127 Cantrell	Customer Contacted
198	4/27	1123 Hilton	
199	4/27	1035 W. Hutchins	
200	4/28	1239 Cantrell	
201	4/28	911 Aaron	
202	4/28	915 Aaron	
203	4/28	1327 W. Hutchins	Customer Contacted
204	4/28	1026 W. Amber	
205	4/28	1023 W. Amber	Customer Contacted
206	4/28	935 W. Amber	
207	4/28	926 W. Amber	
208	4/28	3418 Commercial	Customer Contacted
209	4/28	2909 Commercial	
210	4/28	2911 Commercial	Customer Contacted
211	4/29	9319 W. Vestal	"
212	4/29	1226 Drury	"
213	4/29	1335 Drury	

APPENDIX F
Edwards Underground Water District
Customer Side Leak List
1992

System: Bexar Metropolitan Water District

Page 11 of 66

Line #	Date #	Address	Comments
214	4/29	1419 Cantrell	
215	4/29	1438 Cantrell	
216	4/29	1223 Aaron	Customer Contacted
217	4/29	1319 Aaron	"
218	4/29	1338 Aaron	
219	4/29	602 Logwood	Customer Contacted
220	4/30	224 Escalon	
221	4/30	236 Escalon	
222	4/30	243 Nock	
223	4/30	1035 Grosvenor	
224	4/30	906 Clovis	
225	4/30	939 Clovis	Customer Contacted
226	4/30	1118 Grosvenor	"
227	4/30	1302 W. Harding	"
228	4/30	1314 W. Harding	
229	4/30	1319 W. Harding	Customer Contacted
230	4/30	1338 W. Harding	
231	4/30	1427 W. Harding	
232	4/30	1506 W. Harding	Customer Contacted
233	4/30	938 Sunglo	
234	4/30	1018 Sunglo	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 12 of 66

Line #	Date #	Address	Comments
235	4/30	1118 Sunglo	Customer Contacted
236	5/11	338 W. Mally	"
237	5/11	135 W. Mally	"
238	5/11	638 W. Mally	"
239	5/11	639 W. Mally	"
240	5/11	376 W. Villaret	"
241	5/11	9310 Garnett	
242	5/11	9306 Garnett	
243	5/11	9007 Garnett	
244	5/11	9022 Garnett	Customer Contacted
245	5/11	9102 Garnett	"
246	5/11	472 Gillette	"
247	5/11	449 W. Villaret	"
248	5/11	732 Buchanan	"
249	5/12	8618 Garnett	"
250	5/12	507 Over Ridge	"
251	5/12	178 Dorsey	"
252	5/12	171 Dorsey	
253	5/12	850 Honora	
254	5/12	8711 Ludtke	
255	5/12	8705 Ludtke	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 13 of 66

Line #	Date #	Address	Comments
256	5/12	8614 Ludtke	Customer Contacted
257	5/12	8514 Ludtke	"
258	5/12	614 Pike Ridge	"
259	5/12	4145 Pleasanton	
260	5/12	326 Moursund	
261	5/12	9208 Clamp	
262	5/12	9115 Clamp	
263	5/12	234 W. Baetz	
264	5/12	310 W. Baetz	
265	5/13	423 W. Formosa	
266	5/13	410 W. Formosa	
267	5/13	406 W. Formosa	
268	5/13	311 W. Formosa	Customer Contacted
269	5/13	219 W. Formosa	
270	5/13	202 W. Formosa	
271	5/13	8123 Hilton	
272	5/13	8110 Clamp	
273	5/13	311 Leff	Customer Contacted
274	5/13	347 Leff	"
275	5/13	278 W. Petaluma	
276	5/13	166 W. Petaluma	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 14 of 66

Line #	Date #	Address	Comments
277	5/13	1862 Clamp	
278	5/13	1846 Clamp	
279	5/13	327 W. Petaluma	Customer Contacted
280	5/13	429 W. Petaluma	"
281	5/13	155 Moursund	"
282	5/13	141 Ansley	
283	5/13	434 W. Vestal	Customer Contacted
284	5/14	502 W. Vestal	Customer Contacted
285	5/14	326 W. Vestal	"
286	5/15	8227 Oppenheimer	
287	5/15	8215 Oppenheimer	
288	5/18	201 Sunglo	Customer Contacted
289	5/18	227 Sunglo	"
290	5/18	410 Sunglo	"
291	5/18	214 Clovis	"
292	5/18	926 W. Harding	
293	5/18	1114 W. Harding	Customer Contacted
294	5/18	526 Sunglo	"
295	5/18	503 Sunglo	"
296	5/18	523 Sunglo	"
297	5/18	610 Sunglo	"

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 15 of 66

Line #	Date #	Address	Comments
298	5/18	730 Sunglo	
299	5/18	119 Cantrell	
300	5/18	138 Cantrell	
301	5/18	723 Cantrell	
302	5/18	303 Aaron	
303	5/18	322 Drury	
304	5/26	426 Aaron	
305	5/27	539 Tidewind	
306	5/28	9206 Agan Ln.	
307	5/28	303 Yukon	Customer Contacted
308	5/28	302 E. Mally	"
309	5/28	402 E. Mally	Customer Contacted
310	5/28	418 E. Mally	
311	5/28	423 E. Mally	
312	5/28	447 E. Mally	
313	5/28	455 Wimberly	Customer Contacted
314	5/28	511 Wimberly	"
315	5/28	9326 Yett	"
316	5/28	543 Wimberly	"
317	5/28	539 Ashley	Front Faucet
318	5/28	551 Ashley	Stop & Waste

APPENDIX F

Edwards Underground Water District Customer Side Leak List 1992

System: Bexar Metropolitan Water District

Page 16 of 66

Line #	Date #	Address	Comments
319	5/28	318 Myrick	Customer Contacted
320	5/28	338 Myrick	"
321	5/28	226 Myrick	
322	5/28	306 Myrick	
323	6/1	723 Deely	
324	6/1	455 Kopplow	Customer Contacted / Front Faucet
325	6/1	946 E. Petaluma	
326	6/1	847 E. Petaluma	
327	6/1	722 Bernard	
328	6/1	819 Bernard	
329	6/1	1008 Sams	
330	6/1	1018 Sams	Customer Contacted
331	6/1	1038 Sams	"
332	6/1	906 Sams	Small Leak
333	6/1	826 Dodic	Front Faucet
334	6/1	602 Baltzell	
335	6/2	538 Ansley	Customer Contacted
336	6/2	311 Ansley	Front Faucet
337	6/2	8938 Oakbrook	Customer Contacted
338	6/2	8914 Oakbrook	"

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 17 of 66

Line #	Date #	Address	Comments
339	6/2	8910 Braburn	
340	6/2	655 Kopplow	Customer Contacted
341	6/2	718 Kopplow	"
342	6/2	730 Kopplow	"
343	6/2	738 Saipan	Stop & Waste
344	6/2	739 Saipan	Customer Contacted
345	6/3	603 E. Formosa	
346	6/3	130 E. Formosa	Customer Contacted
347	6/3	138 E. Formosa	"
348	6/3	273 E. Petaluma	"
349	6/3	126 E. Ackard	Front Faucet
350	6/3	214 E. Amber	
351	6/3	211 E. Amber	Customer Contacted
352	6/3	231 E. Amber	
353	6/3	235 E. Amber	
354	6/3	307 E. Amber	Customer Contacted
355	6/3	431 E. Amber	Stop & Waste
356	6/3	142 E. Ackard	Front Faucet
357	6/3	218 E. Ackard	
358	6/3	239 E. Ackard	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 18 of 66

Line #	Date #	Address	Comments
359	6/3	323 E. Ackard	Stop & Waste
360	6/3	239 E. Formosa	
361	6/3	315 E. Formosa	
362	6/3	331 E. Formosa	Front Faucet
363	6/3	406 E. Formosa	Front Faucet
364	6/3	342 E. Ackard	"
365	6/3	410 E. Ackard	
366	6/3	514 Creath	Stop & Waste
367	6/3	511 Creath	Front Faucet
368	6/4	214 E. Hutchins	
369	6/4	215 E. Hutchins	
370	6/5	10102 U.S. 281	Customer Contacted
371	6/5	9822 U.S. 281	Meter Nipple
372	6/5	1382 Moursund	Customer Contacted
373	6/5	12060 Pleasanton	"
374	6/8	230 E. Vestal	
375	6/8	331 E. Vestal	Front Faucet
376	6/8	203 Verne	
377	6/8	522 Verne	Customer Contacted
378	6/8	625 Verne	"
379	6/8	306 Burton	"

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 19 of 66

Line #	Date #	Address	Comments
380	6/8	407 Sharmain	
381	6/8	435 E. Formosa	
382	6/8	317 Aaron	
383	6/8	427 Sharmain	Customer Contacted
384	6/8	607 Sharmain	"
385	6/8	614 Grosvenor	"
386	6/8	615 Ware	
387	6/8	443 Ware	Customer Contacted
388	6/8	410 E. Vestal	Front Faucet
389	6/8	415 E. Vestal	Stop & Waste
390	6/8	3200 Pleasanton	
391	6/8	2914 Pleasanton	
392	6/10	310 Sussex	
393	6/10	250 Shire	
394	6/10	306 Shasta	
395	6/10	111 Shasta	
396	6/10	126 Shasta	
397	6/10	150 Shasta	
398	6/10	267 Harding	
399	6/10	327 Sussex	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 20 of 66

Line #	Date #	Address	Comments
400	6/10	310 Sussex	
401	6/10	6804 S. Flores	
402	6/10	431 Sussex	
403	6/10	446 Sussex	Front Faucet
404	6/10	306 Sussex	Front Faucet / Customer Contacted
405	6/10	335 Sussex	"
406	6/10	246 Shire	"
407	6/10	255 Shire	
408	6/10	311 Shire	
409	6/10	402 Shire	Front Faucet / Customer Contacted
410	6/10	126 W. Harding	
411	6/10	118 E. Harding	Customer Contacted
412	6/11	227 E. Harding	"
413	6/11	267 E. Harding	"
414	6/11	141 Lorita	"
415	6/11	226 Vado	
416	6/12	1626 Chavaneaux	
417	6/15	1722 Sanco	
418	6/15	1134 Sanez	Customer Contacted
419	6/15	1235 S.W. Military	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 21 of 66

Line #	Date #	Address	Comments
420	6/15	1503 S.W. Military	Stop & Waste
421	6/15	1707 San Rafael	Front Faucet / Customer Contacted
422	6/15	10014 Ruidosa	Customer Contacted
423	6/15	10030 Ruidosa	"
424	6/15	1726 Sanco	"
425	6/16	1534 San Acacia	"
426	6/16	9907 Moursund	"
427	6/16	10305 Moursund	Front Faucet
428	6/16	10415 Moursund	Customer Contacted
429	6/17	3627 S.W. Military	
430	6/17	3506 S.W. Military	
431	6/18	611 Aaron	Customer Contacted
432	6/18	135 Grosvenor	"
433	6/18	219 Grosvenor	"
434	6/18	302 Clovis	
435	6/18	310 Tidewind	Customer Contacted
436	6/18	419 Tidewind	"
437	6/18	211 E. Villaret	
438	6/18	230 E. Villaret	Stop & Waste
439	6/19	527 E. Villaret	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 22 of 66

Line #	Date #	Address	Comments
440	6/19	514 E. Villaret	
441	6/19	315 Pinehurst	Customer Contacted
442	6/19	334 Pinehurst	"
443	6/19	6423 S. Flores	"
444	6/19	555 E. Mayfield	
445	6/27	411 E. Villaret	
446	7/6	136 W. Dickson	Customer Contacted
447	7/6	145 W. Dickson	
448	7/6	202 W. Dickson	Customer Contacted
449	7/6	226 W. Dickson	"
450	7/6	238 W. Dickson	"
451	7/6	119 W. Bonner	"
452	7/6	144 Harald	
453	7/6	115 Kendalia	
454	7/6	116 Kendalia	
455	7/6	231 Kendalia	
456	7/6	131 W. Bonner	Customer Contacted
457	7/7	314 W. Dickson	Front Faucet
458	7/7	306 E. Mayfield	
459	7/7	220 W. Pyron	Customer Contacted
460	7/7	222 W. Pyron	Very Small

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 23 of 66

Line #	Date #	Address	Comments
461	7/7	345 Dickson	Customer Contacted
462	7/7	406 Dickson	"
463	7/7	355 Kendalia	
464	7/7	415 Kendalia	Customer Contacted
465	7/7	242 E. Mayfield	Front Faucet
466	7/7	227 E. Mayfield	
467	7/7	114 E. Mayfield	
468	7/7	412 W. Pyron	Customer Contacted
469	7/7	520 W. Pyron	Stop & Waste
470	7/8	1318 Cullin	
471	7/8	100 W. White	Customer Contacted
472	7/8	103 W. White	
473	7/8	200 W. White	
474	7/8	114 W. Huff	Customer Contacted
475	7/8	205 E. Pyron	
476	7/8	105 Congress	Customer Contacted
477	7/8	204 Congress	"
478	7/8	310 Congress	"
479	7/8	311 Congress	"
480	7/8	108 E. Bonner	Customer Contacted
481	7/8	112 E. Bonner	"

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 24 of 66

Line #	Date #	Address	Comments
482	7/8	113 E. Bonner	
483	7/8	207 E. Bonner	Customer Contacted / Stop & Waste
484	7/8	212 E. Bonner	
485	7/8	217 E. Bonner	Customer Contacted
486	7/9	207 E. Dickson	Stop & Waste
487	7/9	111 Crane	Front Faucet
488	7/9	306 Crane	
489	7/9	500 Cliff	Front Faucet / Customer Contacted
490	7/9	502 Cliff	"
491	7/9	509 Cliff	
492	7/9	315 W. White	
493	7/9	313 W. White	Customer Contacted
494	7/9	115 McCauley	
495	7/16	221 Rayburn	Customer Contacted
496	7/16	418 Rayburn	In front yard
497	7/16	551 Kendalia	
498	7/16	582 Kendalia	
499	7/16	622 Kendalia	
500	7/16	711 W. Pyron	
501	7/16	746 W. Pyron	Stop & Waste

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 25 of 66

Line #	Date #	Address	Comments
502	7/16	230 Rosebud	Customer Contacted
503	7/16	239 Rosebud	"
504	7/17	243 Gerald	"
505	7/17	319 Gerald	Customer Contacted
506	7/17	209 Burcham	"
507	7/17	301 Burcham	"
508	7/17	303 Burcham	"
509	7/17	306 Burcham	Stop & Waste
510	7/17	311 Burcham	"
511	7/17	321 Burcham	Front Faucet / Customer Contacted
512	7/17	325 Burcham	
513	7/17	328 Burcham	Front Faucet / Customer Contacted
514	7/17	201 W. Southcross	
515	7/17	206 W. Southcross	
516	7/17	211 W. Southcross	Stop & Waste / Customer Contacted
517	7/17	225 W. Southcross	Front Faucet / Customer Contacted
518	7/17	316 W. Southcross	Rear Faucet / Customer Contacted
519	7/17	324 W. Southcross	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 26 of 66

Line #	Date #	Address	Comments
520	7/17	119 Canavan	
521	7/17	220 Canavan	Customer Contacted
522	7/17	222 Canavan	
523	7/17	302 Canavan	Front Faucet / Customer Contacted
524	7/17	319 Canavan	"
525	7/20	551 Fitch	Stop & Waste
526	7/20	555 Fitch	Front Faucet
527	7/20	542 Brunswick	Stop & Waste
528	7/20	535 Brunswick	Front Faucet
529	7/20	554 Brunswick	Customer Contacted
530	7/20	563 Brunswick	"
531	7/20	626 Brunswick	"
532	7/20	659 Brunswick	Front Faucet
533	7/20	434 Harlan	Customer Contacted
534	7/20	510 Harlan	Customer Contacted / Stop & Waste
535	7/20	435 Stonewall	Front Faucet
536	7/20	467 Stonewall	
537	7/20	526 Stonewall	Customer Contacted
538	7/20	535 Stonewall	"

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 27 of 66

Line #	Date #	Address	Comments
539	7/20	539 Stonewall	"
540	7/20	540 Stonewall	"
541	7/20	603 Stonewall	Front Faucet
542	7/23	167 W. Mayfield	
543	7/23	188 W. Mayfield	
544	7/23	692 W. Pyron	Customer Contacted
545	7/23	739 W. Pyron	
546	7/23	723 W. Pyron	Customer Contacted / Stop & Waste
547	7/23	526 Kendalia	Customer Contacted
548	7/23	2022 Pleasanton	"
549	7/23	133 Rosebud	Front Faucet
550	7/23	178 Rosebud	Customer Contacted
551	7/23	216 Rosebud	"
552	7/27	511 Rayburn	
553	7/27	510 McCauley	
554	7/27	718 Kendalia	Front Faucet
555	7/27	726 Kendalia	
556	7/27	810 Kendalia	Customer Contacted
557	7/27	854 Kendalia	Front Faucet
558	7/27	234 W. Mayfield	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 28 of 66

Line #	Date #	Address	Comments
559	7/27	815 W. Pyron	
560	7/27	942 W. Pyron	
561	7/27	861 W. Pyron	
562	7/28	302 Rosebud	
563	7/28	315 Rosebud	Stop & Waste
564	7/28	342 Rosebud	
565	7/28	374 Rosebud	
566	7/28	375 Rosebud	Front Faucet
567	7/28	627 Gerald	
568	7/28	639 Gerald	Customer Contacted
569	7/28	735 Gerald	"
570	7/28	1557 Commercial	Front Faucet
571	7/28	1520 Commercial	
572	7/28	541 Burcham	Stop & Waste
573	7/28	471 Burcham	
574	7/28	467 Burcham	
575	7/28	421 Burcham	
576	7/28	409 Burcham	
577	7/29	408 W. Southcross	
578	7/29	416 W. Southcross	
579	7/29	430 W. Southcross	

APPENDIX F

Edwards Underground Water District Customer Side Leak List 1992

System: Bexar Metropolitan Water District

Page 29 of 66

Line #	Date #	Address	Comments
580	7/29	438 W. Southcross	
581	7/29	423 W. Southcross	
582	7/29	427 W. Southcross	
583	7/29	505 W. Southcross	
584	7/29	430 Canavan	
585	7/29	434 Canavan	
586	7/29	482 Canavan	
587	7/29	858 Fitch	
588	7/29	811 Fitch	
589	7/29	807 Fitch	
590	7/29	754 Brunswick	
591	7/29	741 Brunswick	
592	7/29	733 Brunswick	
593	7/29	630 Harlan	
594	7/29	720 Harlan	
595	7/29	611 Stonewall	
596	7/29	651 Stonewall	
597	7/30	926 McCauley	Customer Contacted
598	7/30	915 Rayburn	"
599	7/30	919 Rayburn	"
600	7/30	918 Rayburn	"

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 30 of 66

Line #	Date #	Address	Comments
601	7/30	926 Rayburn	
602	7/30	1022 Rayburn	Customer Contacted
603	7/30	1030 Rayburn	"
604	7/30	1062 Rayburn	"
605	7/30	1108 Rayburn	"
606	7/31	983 Kendalia	
607	7/31	925 Kendalia	Stop & Waste
608	7/31	921 Kendalia	
609	7/31	323 W. Mayfield	
610	7/31	363 W. Mayfield	
611	7/31	1102 W. Pyron	
612	7/31	1092 W. Pyron	
613	7/31	6207 Macdona	Customer Contacted
614	7/31	6206 Macdona	"
615	7/31	6203 Macdona	"
616	7/31	6202 Macdona	"
617	8/3	1331 Rayburn	"
618	8/3	1139 McCauley	
619	8/3	1201 McCauley	Front Faucet
620	8/3	1206 McCauley	"
621	8/3	1226 McCauley	"

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 31 of 66

Line #	Date #	Address	Comments
622	8/3	1322 McCauley	Front Faucet
623	8/3	1406 McCauley	"
624	8/3	1421 McCauley	"
625	8/3	1422 McCauley	Customer Contacted
626	8/3	1509 McCauley	"
627	8/3	1525 McCauley	"
628	8/3	1421 Kendalia	"
629	8/3	1417 Kendalia	Front Faucet
630	8/3	1333 Kendalia	Customer Contacted
631	8/3	1179 Kendalia	Front Faucet
632	8/4	557 W. Mayfield	
633	8/4	515 W. Mayfield	Front Faucet / Customer Contacted
634	8/4	446 W. Mayfield	
635	8/4	437 W. Mayfield	Customer Contacted
636	8/4	420 W. Mayfield	Customer Contacted / Stop & Waste
637	8/4	1214 W. Pyron	Customer Contacted
638	8/4	1423 W. Pyron	"
639	8/4	1435 W. Pyron	"
640	8/4	1208 W. Pyron	Stop & Waste
641	8/4	81 Whitman	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 32 of 66

Line #	Date #	Address	Comments
642	8/4	314 Whitman	
643	8/4	417 Whitman	Stop & Waste
644	8/4	507 Whitman	
645	8/4	311 Ocone	Customer Contacted
646	8/4	703 Whitman	
647	8/4	723 Whitman	Customer Contacted
648	8/4	718 Whitman	
649	8/5	110 Wagner	
650	8/5	215 Ocone	
651	8/5	303 Ocone	
652	8/5	86 Wagner	
653	8/5	1226 Gerald	
654	8/5	722 Vickers	
655	8/5	511 Vickers	Customer Contacted
656	8/5	415 Vickers	"
657	8/5	318 Vickers	
658	8/5	302 Vickers	
659	8/5	107 Ocone	Customer Contacted
660	8/5	54 Vickers	
661	8/5	322 Adolph	
662	8/6	303 Linden	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 33 of 66

Line #	Date #	Address	Comments
663	8/6	110 Linden	
664	8/6	108 Linden	
665	8/6	53 Linden	
666	8/6	1405 W. Southcross	Front Faucet / Customer Contacted
667	8/6	1307 W. Southcross	
668	8/6	1223 W. Southcross	Front Faucet / Customer Contacted
669	8/6	1112 W. Southcross	"
670	8/6	918 W. Southcross	"
671	8/6	919 W. Southcross	"
672	8/6	758 W. Southcross	
673	8/6	750 W. Southcross	Customer Contacted
674	8/6	5807 Macdona	
675	8/7	710 Berlin	
676	8/7	508 Berlin	Customer Contacted / Stop & Waste
677	8/7	307 Berlin	Customer Contacted
678	8/7	110 Berlin	"
679	8/7	812 Milvid	"
680	8/7	1719 Fitch	" Front Faucet
681	8/7	1703 Fitch	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 34 of 66

Line #	Date #	Address	Comments
682	8/7	1607 Fitch	
683	8/7	1215 Fitch	Customer Contacted
684	8/7	1193 Fitch	"
685	8/7	1157 Fitch	
686	8/7	1106 Fitch	
687	8/7	1102 Fitch	Customer Contacted
688	8/7	1074 Fitch	
689	8/7	1010 Fitch	Front Faucet / Customer Contacted
690	8/7	951 Fitch	
691	8/10	1622 Brunswick	Customer Contacted Stop & Waste
692	8/10	1414 Brunswick	Front Faucet
693	8/10	1314 Brunswick	Customer Contacted
694	8/10	1222 Brunswick	Front Faucet
695	8/10	951 Brunswick	Customer Contacted
696	8/10	918 Brunswick	Front Faucet
697	8/10	1461 Harlan	Front Faucet
698	8/10	1449 Harlan	Customer Contacted
699	8/10	1453 Harlan	Front Faucet
700	8/10	1415 Harlan	Customer Contacted
701	8/10	1352 Harlan	Customer Contacted / Stop & Waste

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 35 of 66

Line #	Date #	Address	Comments
702	8/10	1311-2 Harlan	Customer Contacted
703	8/10	1234 Harlan	Front Faucet
704	8/10	1023 Harlan	Customer Contacted
705	8/10	934 Harlan	Front Faucet
706	8/10	923 Harlan	Front Faucet / Customer Contacted
707	8/10	1107 Commercial	Rear Faucet / Customer Contacted
708	8/12	718 Stonewall	Front Faucet
709	8/12	1018 Commercial	Customer Contacted
710	8/12	807 Stonewall	"
711	8/12	926 Stonewall	Customer Contacted
712	8/12	940 Stonewall	"
713	8/12	1008 Stonewall	
714	8/12	1031 Stonewall	Customer Contacted
715	8/12	1105 Stonewall	"
716	8/12	1043 Stonewall	
717	8/12	1108 Stonewall	Customer Contacted
718	8/12	1119 Stonewall	"
719	8/12	1143 Stonewall	"
720	8/12	1148 Stonewall	"
721	8/12	1162 Stonewall	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 36 of 66

Line #	Date #	Address	Comments
722	8/12	1201 Stonewall	"
723	8/12	1304 Stonewall	Faucet
724	8/12	667 Humboldt	Customer Contacted
725	8/12	662 Humboldt	"
726	8/12	628 Humboldt	Customer Contacted / Stop & Waste
727	8/12	535 Humboldt	Customer Contacted / Front Faucet
728	8/12	522 Humboldt	
729	8/12	357 Humboldt	Customer Contacted
730	8/12	334 Humboldt	Customer Contacted / Stop & Waste
731	8/12	227 Humboldt	Customer Contacted Galv. Service
732	8/12	213 Humboldt	Customer Contacted Front Faucet
733	8/12	111 Humboldt	Customer Contacted Stop & Waste
734	8/14	819 Flanders	Customer Contacted
735	8/14	838 Flanders	
736	8/14	1122 Flanders	Front Faucet / Customer Contacted
737	8/14	1345 Flanders	
738	8/14	1417 Flanders	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 37 of 66

Line #	Date #	Address	Comments
739	8/14	648 Elks	"
740	8/14	622 Elks	Front Faucet / Customer Contacted
741	8/14	614 Elks	"
742	8/14	556 Elks	"
743	8/14	446 Elks	"
744	8/14	410 Elks	Front Faucet Customer Contacted
745	8/14	1224 Flanders	Customer Contacted Stop & Waste
746	8/14	114 Elks	
747	8/17	1346 Brighton	Customer Contacted
748	8/17	1541 Brighton	Customer Contacted
749	8/17	1502 Brighton	"
750	8/17	1302 Brighton	Front Faucet
751	8/17	1439 Brighton	Customer Contacted
752	8/17	1405 Brighton	" Front Faucet
753	8/17	1311 Brighton	"
754	8/17	1241 Brighton	
755	8/17	1227 Brighton	Customer Contacted
756	8/17	1221 Brighton	
757	8/17	1135 Brighton	Customer Contacted / Front Faucet

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 38 of 66

Line #	Date #	Address	Comments
758	8/17	1130 Brighton	Customer Contacted
759	8/17	1110 Brighton	
760	8/17	938 Brighton	Stop & Waste
761	8/17	922 Brighton	
762	8/17	1329 Keats	Stop & Waste / Customer Contacted
763	8/17	1311 Keats	"
764	8/17	1309 Keats	
765	8/17	1250 Keats	Customer Contacted
766	8/17	1143 Keats	
767	8/17	1142 Keats	Customer Contacted
768	8/17	958 Keats	Customer Contacted / Stop & Waste
769	8/17	959 Keats	
770	8/17	946 Keats	
771	8/17	863 Keats	Customer Contacted
772	8/17	834 Keats	
773	8/17	855 Keats	Customer Contacted / Front Faucet
774	8/17	815 Keats	"
775	8/18	1424 Crystal	
776	8/18	1143 Crystal	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 39 of 66

Line #	Date #	Address	Comments
777	8/18	1115 Crystal	Customer Contacted
778	8/18	911 Crystal	
779	8/18	847 Crystal	Customer Contacted
780	8/18	811 Crystal	
781	8/18	722 Chalmers	
782	8/18	730 Chalmers	Front Faucet / Customer Contacted
783	8/18	731 Chalmers	"
784	8/18	803 Chalmers	
785	8/18	1302 Chalmers	
786	8/18	1341 Vermont	
787	8/18	1323 Vermont	
788	8/18	411 Huron	Front Faucet
789	8/18	1250 Vermont	
790	8/18	1011 Vermont	Customer Contacted
791	8/18	803 Vermont	
792	8/19	810 Division	
793	8/19	822 Division	Stop & Water / Customer Contacted
794	8/19	834 Division	
795	8/19	926 Division	
796	8/19	927 Division	In Alley

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 41 of 66

Line #	Date #	Address	Comments
817	8/25	117 Somerset	Customer Contacted
818	8/25	207 Somerset	
819	8/26	5537 Zarzamora	Customer Contacted
820	8/26	2001 Fitch	"
821	8/26	921 Milvid	Customer Contacted Front Faucet
822	8/26	1002 Milvid	Customer Contacted Stop & Waste
823	8/26	1110 Berlin	
824	8/26	1116 Linden	Water Cooler
825	8/26	1731 W. Pyron	Customer Contacted
826	8/26	1707 W. Pyron	Customer Contacted / Stop & Waste
827	8/26	6606 Zarzamora	
828	8/26	1014 Whitman	
829	8/26	1015 Wagner	
830	8/26	1611 Gerald	Customer Contacted
831	8/26	1107 Wagner	Customer Contacted Front Faucet
832	8/26	1816 Gerald	"
833	8/31	1910 W. Pyron	Stop & Waste
834	8/31	1911 W. Pyron	Customer Contacted
835	8/31	1315 Linden	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 42 of 66

Line #	Date #	Address	Comments
836	8/31	1402 Linden	Stop & Waste
837	8/31	314 Mallard	
838	8/31	1508 Wagner	Customer Contacted Front Faucet
839	8/31	2043 W. Pyron	" / Toilet
840	9/1	1815 Kendalia	Front Faucet
841	9/1	1823 Kendalia	Customer Contacted / Front Faucet
842	9/1	1835 Kendalia	Customer Contacted / Stop & Waste
843	9/1	1947 McCauley	Customer Contacted
844	9/1	1915 McCauley	
845	9/1	1723 McCauley	Customer Contacted
846	9/1	1726 McCauley	Front Faucet
H47	9/1	1918 Rayburn	Customer Contacted / Stop & Waste
848	9/1	1910 Rayburn	"
849	9/1	1822 Rayburn	"
850	9/1	1810 Rayburn	Customer Contacted / Front Faucet
851	9/1	1807 Rayburn	Door Tag / Stop & Waste
852	9/1	115 Applebee	Customer Contacted / Front Faucet
853	9/1	106 Applebee	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 43 of 66

Line #	Date #	Address	Comments
854	9/2	122 Fernleaf	Front Faucet
855	9/2	107 Fernleaf	Customer Contacted
856	9/2	111 Parmly	"
857	9/2	126 Parmly	
858	9/2	138 Parmly	Customer Contacted / Stop and Waste
859	9/2	143 Parmly	Front Faucet
860	9/2	150 Parmly	Customer Contacted / Front Faucet
861	9/2	722 Price	Customer Contacted / Front Faucet
862	9/2	630 #2 Price	
863	9/2	623 Price	
864	9/2	244 Price	
865	9/2	642 Fleming	
866	9/2	621 Fleming	
867	9/2	619 Fleming	
868	9/2	161 Price	
869	9/2	151 Price	
870	9/2	124 Price	Customer Contacted / Toilet
871	9/3	1351 Fenfield	Stop & Waste
872	9/3	1251 Fenfield	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 44 of 66

Line #	Date #	Address	Comments
873	9/3	925 Fenfield	Customer Contacted / Stop & Waste
874	9/3	311 Fenfield	
874	9/3	308 Fenfield	
876	9/3	702 Lindeman	Customer Contacted
877	9/3	403 McLaughlin	Front Faucet
878	9/3	406 McLaughlin	Customer Contacted / Front Faucet
879	9/3	411 McLaughlin	Customer Contacted / Front Faucet
880	9/3	508 McLaughlin	Customer Contacted / Kitchen Sink
881	9/3	521 McLaughlin	Customer Contacted
882	9/3	539 McLaughlin	Customer Contacted / Front Faucet
883	9/3	639 McLaughlin	
884	9/4	243 Kelsey	
885	9/4	172 King	
886	9/4	127 King	Customer Contacted / Toilet
887	9/8	215 Prospect	Customer Contacted
888	9/8	219 King	Door Tag / Stop & Waste
889	9/8	1214 Somerset	Customer Contacted / Sink
890	9/8	248 King	
891	9/8	428 King	Empty House / T-off Water

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 45 of 66

Line #	Date #	Address	Comments
892	9/8	508 King	Customer Contacted / Front Faucet
893	9/8	1316 Creighton	
894	9/8	910 King	Customer Contacted / Front Faucet
895	9/8	1122 King	Bad Bathtub
896	9/8	1823 W. Mayfield	Front Faucet
897	9/8	1818 W. Mayfield	
898	9/8	2539 Quintana	
899	9/8	2535 Quintana	Stop & Waste
900	9/8	2419 Quintana	
901	9/9	930 Peabody	Customer Contacted / Notified
902	9/9	929 Peabody	Customer Contacted
903	9/9	826 Peabody	
904	9/9	811 Peabody	
905	9/9	706 Peabody	
906	9/9	702 Peabody	
907	9/9	222 Peabody	
908	9/9	207 Peabody	
909	9/9	171 Peabody	Customer Contacted / Stop & Waste
910	9/9	216 Lovett	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 46 of 66

Line #	Date #	Address	Comments
911	9/9	514 Lovett	Stop & Waste
912	9/9	714 Lovett	
913	9/9	722 Lovett	
914	9/9	806 Lovett	Small
915	9/9	922 Lovett	Small
916	9/9	923 Lovett	
917	9/9	1011 Lovett	
918	9/9	1024 Lovett	
919	9/9	3204 W. Gerald	
920	9/9	3106 W. Gerald	
921	9/9	2806 W. Gerald	
922	9/10	2927 W. Gerald	
923	9/10	511 Lovett	
924	9/10	130 Wilcox	
925	9/10	2408 Southcross	
926	9/10	2415 Southcross	
927	9/10	2427 Southcross	
928	9/10	2422 Southcross	
929	9/10	2522 Southcross	
930	9/10	303 #2 Wilcox	
931	9/10	2606 W. Southcross	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 47 of 66

Line #	Date #	Address	Comments
932	9/10	315 Hollenbeck	
933	9/10	702 Fay	
934	9/10	102 Tampa	
935	9/10	118 Tampa	
936	9/10	122 Tampa	
937	9/11	202 Tampa	
938	9/11	215 Tampa	
939	9/11	316 Creighton	
940	9/11	109 Dacus	
941	9/11	119 Dacus	
942	9/11	127 Dacus	
943	9/11	219 Dacus	
944	9/11	210 Palestine	
945	9/11	218 Palestine	
946	9/11	238 Palestine	
947	9/11	239 Palestine	
948	9/11	138 Griffin	
949	9/11	118 Griffin	
950	9/11	114 Griffin	
951	9/11	110 Querida	
952	9/11	127 Querida	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 48 of 66

Line #	Date #	Address	Comments
953	9/11	151 Querida	
954	9/14	151 Bayville	
955	9/14	106 Querida	
956	9/14	123 Querida	
957	9/14	158 Chesley	
958	9/14	135 Dexter	Customer Contacted / Front Faucet / 1 More
959	9/14	154 Dexter	Customer Contacted / Front Faucet
960	9/14	114 Elkins	Customer Contacted / Bathroom
961	9/14	107 Felton	Customer Contacted / Toilet
962	9/14	114 Felton	
963	9/14	119 Felton	Customer Contacted
964	9/14	135 Felton	
965	9/15	142 Nightingale	
966	9/15	110 Nightingale	
967	9/15	106 Nightingale	Customer Contacted / Kitchen
968	9/15	135 Ballard	" / Sink
969	9/15	143 Ballard	Front Faucet
970	9/15	1603 Thompson	Customer Contacted
971	9/15	1438 Thompson	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 49 of 66

Line #	Date #	Address	Comments
972	9/15	3830 Carnation	Customer Contacted / Toilet
973	9/15	3826 Carnation	
974	9/15	2619 Wescott	Customer Contacted / Toilet and Kitchen
975	9/16	3139 Weir	
976	9/16	3439 Weir	Customer Contacted
977	9/16	2419 Aiken	Backyard
978	9/16	2406 Aiken	Door Tag / Front Faucet
979	9/16	2339 Yantis	
980	9/16	2343 Yantis	Customer Contacted / Toilet
981	9/16	2347 Yantis	" / Kitchen
982	9/16	2346 Yantis	
983	9/17	3123 Jane Ellen	Customer Contacted / Front Faucet
984	9/17	3114 Jane Ellen	
985	9/17	3034 Jane Ellen	Customer Contacted
986	9/17	3002 Jane Ellen	Customer Contacted / Stop & Waste
987	9/17	2923 Hatton	Customer Contacted / Kitchen
988	9/17	3018 Hatton	
989	9/17	3118 Hatton	Customer Contacted / Stop and Waste
990	9/17	3135 Hatton	" / Notified

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 50 of 66

Line #	Date #	Address	Comments
991	9/17	3126 Darby	Front Faucet / More
992	9/17	3122 W. Kirk	
993	9/17	2615 Aiken	Customer Contacted
994	9/17	538 Academy	"
995	9/17	518 Academy	
996	9/17	501 Pletz	
997	9/17	440 Pletz	
998	9/18	2823 Roselawn	Customer Contacted
999	9/18	242 W. Jewel	" / Stop & Waste
1000	9/18	354 Pletz	
1001	9/18	218 W. Jewel	
1002	9/18	210 W. Jewel	Customer Contacted
1003	9/18	211 W. Jewel	" / Back Faucet
1004	9/18	154 W. Emerson	
1005	9/18	123 W. Emerson	
1006	9/18	103 W. Emerson	
1007	9/18	302 Pletz	Customer Contacted
1008	9/18	226 Pletz	Stop & Waste
1009	9/18	111 W. Pletz	Customer Contacted / Stop & Waste
1010	9/18	210 W. Academy	
1011	9/18	250 W. Academy	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List

1992

System: Bexar Metropolitan Water DistrictPage 51 of 66

Line #	Date #	Address	Comments
1012	9/22	351 W. Academy	Door Tag
1013	9/22	1250 W. Thompson	Customer Contacted / Stop & Waste
1014	9/22	1202 W. Thompson	
1015	9/22	119 W. Academy	Customer Contacted
1016	9/22	1102 W. Thompson	Customer Contacted
1017	9/22	1123 W. Thompson	" / Front Faucet
1018	9/22	1211 W. Thompson	" "
1019	9/22	1315 W. Thompson	Customer Contacted
1020	9/25	2527 SW 21st	"
1021	9/25	2523 SW 21st	"
1022	9/25	2511 SW 21st	
1023	9/25	1106 W. Kirk	Front Faucet
1024	9/25	1227 W. Kirk	Customer Contacted
1025	9/25	922 Darby	Stop & Waste
1026	9/25	919 Darby	
1027	9/25	902 Darby	
1028	9/25	847 Darby	Customer Contacted
1029	9/25	2818 Depla	"
1030	9/25	519 Menefee	
1031	9/25	2918 Venus	Front Faucet
1032	9/25	3119 Venus	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 52 of 66

Line #	Date #	Address	Comments
1033	9/28	3122 Venus	
1034	9/28	3207 Neptune	Customer Contacted
1035	9/28	3102 Neptune	"
1036	9/28	3003 Neptune	
1037	9/28	3067 Mars	
1038	9/29	823 W. Thompson	
1039	9/29	826 Taft	
1040	9/29	842 Taft	
1041	9/29	851 Barrett	
1042	9/29	819 Taft	
1043	9/29	711 W. Kirk	Customer Contacted
1044	9/29	751 W. Kirk	" / Stop & Waste
1045	9/29	766 W. Kirk	
1046	9/29	831 W. Kirk	Stop & Waste Repaired 10/7
1047	9/29	839 W. Kirk	Front Faucet
1048	9/29	854 W. Kirk	
1049	9/29	858 W. Kirk	
1050	9/29	910 W. Harriman	
1051	9/29	906 W. Harriman	
1052	9/29	851 W. Harriman	
1053	9/29	847 W. Harriman	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 53 of 66

Line #	Date #	Address	Comments
1054	9/29	830 W. Harriman	Stop & Waste
1055	9/29	811 W. Harriman	
1056	9/29	760 W. Harriman	
1057	9/30	745 W. Harriman	
1058	9/30	734 W. Harriman	
1059	9/30	727 W. Harriman	
1060	9/30	410 Patton	Front Faucet
1061	9/30	1339 Barclay	Customer Contacted
1062	9/30	1343 Barclay	Front Faucet
1063	9/30	1127 Brady Blvd.	
1064	9/30	1355 Brady Blvd.	
1065	9/30	722 Patton	
1066	9/30	634 Patton	Customer Contacted
1067	9/30	611 Patton	"
1068	9/30	547 Patton	"
1069	9/30	2015 Paso Doble	
1070	9/30	2901 Cumbre	Customer Contacted
1071	10/1	1307 Ceralvo	
1072	10/1	646 Cupples	
1073	10/1	1538 Ceralvo	
1074	10/1	1614 Ceralvo	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 54 of 66

Line #	Date #	Address	Comments
1075	10/1	1901 Ceralvo	
1076	10/1	2002 Amerada	
1077	10/1	425 Balboa	Front Faucet
1078	10/1	1834 Madrid	
1079	10/1	1837 Madrid	
1080	10/1	1829 Allende	
1081	10/1	1927 Wescott	
1082	10/1	450 Guanajuato	
1083	10/1	442 Guanajuato	
1084	10/1	346 Guanajuato	
1085	10/1	342 Guanajuato	
1086	10/1	335 Guanajuato	
1087	10/1	238 Arteago	
1088	10/1	323 Arteago	
1089	10/1	419 Arteago	
1090	10/1	432 Arteago	
1091	10/1	306 Guanajuato	Stop & Waste
1092	10/2	1232 Patton	
1093	10/2	1226 Patton	
1094	10/2	1134 Patton	
1095	10/2	1126 Patton	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 55 of 66

Line #	Date #	Address	Comments
1096	10/2	310 Amaya	
1097	10/2	336 Amaya	
1098	10/2	402 Amaya	
1099	10/2	424 Amaya	Customer Contacted
1100	10/2	303 Aldama	
1101	10/2	1616 Romero	
1102	10/2	1726 Allende	
1103	10/2	1736 Allende	
1104	10/2	1822 Allende	
1105	10/5	322 Southlawn	Customer Contacted
1106	10/5	306 Southlawn	Front Faucet
1107	10/5	222 Southlawn	
1108	10/5	232 Coronado	Customer Contacted / Stop and Waste
1109	10/5	339 Coronado	
1110	10/5	414 Coranado	
1111	10/5	406 Balboa	
1112	10/5	326 Balboa	
1113	10/5	318 Balboa	Customer Contacted
1114	10/5	202 Balboa	
1115	10/5	115 Balboa	
1116	10/5	322 Sylvia	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 56 of 66

Line #	Date #	Address	Comments
1117	10/5	315 Sylvia	
1118	10/5	310 Remolino	
1119	10/5	314 Remolino	
1120	10/5	331 Remolino	
1121	10/5	341 Remolino	
1122	10/6	247 Cupples	Stop and Waste
1123	10/6	252 Cupples	Customer Contacted
1124	10/6	146 Cheyenne	"
1125	10/6	103 Piegan	Front Faucet
1126	10/6	1027 Barclay	
1127	10/6	1018 Barclay	
1128	10/6	1050 Barclay	
1129	10/6	1402 Merida	
1130	10/6	118 Mazzurana	Stop and Waste
1131	10/6	111 Mazzurana	
1132	10/6	111 Rocco	
1133	10/6	622 Morelia	
1134	10/6	111 Queretaro	Rear Faucet
1135	10/6	108 Querataro	Customer Contacted
1136	10/6	131 Querataro	"
1137	10/6	215 Querataro	"

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 57 of 66

Line #	Date #	Address	Comments
1138	10/6	331 Querataro	
1139	10/6	402 Queretaro	Customer Contacted
1140	10/6	506 Queretaro	
1141	10/6	1118 Gen McMullen	Stop and Waste
1142	10/6	1140 Gen McMullen	"
1143	10/6	522 Chipingue	
1144	10/6	206 Chipingue	Front Faucet
1145	10/6	138 Escuela	Customer Contacted
1146	10/6	7725 W. Dixon	
1147	10/6	19944 Barron	
1148	10/14	20265 Howard Payne	
1149	10/14	20571 Somerset	
1150	10/14	20425 Somerset	
1151	10/14	20295 Somerset	
1152	10/14	8070 W. Dixon	
1153	10/16	8021 Ninth St.	
1154	10/16	8030 Eighth St.	
1155	10/16	7980 Ninth St.	
1156	10/16	19815 King	
1157	10/16	19880 Seventh St.	
1158	10/16	7890 Sixth St.	

APPENDIX F

Edwards Underground Water District Customer Side Leak List 1992

System: Bexar Metropolitan Water District

Page 58 of 66

Line #	Date #	Address	Comments
1159	10/16	8095 2nd St.	
1160	10/16	8155 2nd St.	
1161	10/16	7767 3rd St.	
1162	10/16	8025 3rd St.	
1163	10/16	8005 3rd St.	Customer Contacted
1164	10/9	7155 FM 2790 (1604)	
1165	10/9	17690 FM 2790	
1166	10/9	19875 Casis	
1167	10/9	19906 Casis	
1168	10/9	8560 FM 2790	
1169	10/9	8520 FM 2790	
1170	10/9	8640 FM 2790	
1171	9/16	739 Menefee	
1172	10/26	203 Bamburg	
1173	10/26	114 Warwick	
1174	10/26	235 Southbridge	Stop and Waste
1175	10/26	231 Southbridge	Customer Contacted
1176	10/26	211 Southbridge	Stop and Waste
1177	10/26	246 Montfort	Very Small
1178	10/26	735 Barchester	Stop and Waste
1179	10/27	220 Lindblade	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 59 of 66

Line #	Date #	Address	Comments
1180	10/27	200 Lindblade	Door Tagged / Stop & Waste
1181	10/27	101 Sir Arthur Ct.	Customer Contacted
1182	10/27	100 Sir Arthur Ct.	Front Faucet
1183	10/27	213 Sir Arthur Ct.	
1184	10/27	307 Lochaven	Customer Contacted
1185	10/27	104 Cobblestone	"
1186	10/27	401 Squires	
1187	10/27	505 Squires	Customer Contacted
1188	10/27	115 Honeysuckle	"
1189	10/27	206 Honeysuckle	" / Stop & Waste
1190	10/27	213 Honeysuckle	
1191	10/27	317 Towne Vue	Customer Contacted
1192	10/27	353 Towne Vue	
1193	10/27	357 Towne Vue	Customer Contacted
1194	10/27	164 Twinleaf	"
1195	10/27	160 Twinleaf	Front Faucet
1196	10/28	121 Trillium	
1197	10/28	136 Trillium	
1198	10/28	101 Squires	
1199	10/28	308 Traventine	Sprinkler
1200	10/28	107 Amerson	Sprinkler

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 60 of 66

Line #	Date #	Address	Comments
1201	10/28	107 Shalimar	Stop & Waste
1202	10/28	208 Shalimar	
1203	10/28	407 Antler	
1204	10/28	230 Herwick	
1205	11/2	141 Danube	Very Small
1206	11/2	141 Danube	"
1207	11/2	134 Danube	Stop and Waste
1208	11/2	116 Riviera	Valve / Sprinkler
1209	11/2	104 Lou Jon Circle	Customer Contacted / Stop and Waste
1210	11/13	106 Herwick	Stop and Waste / Door Tag
1211	11/13	103 Herwick	"
1212	11/13	609 Antler	
1213	11/13	512 Antler	Front Faucet
1214	11/13	510 Antler	"
1215	11/13	508 Antler	Front Faucet / Customer Contacted
1216	11/13	507 Antler	
1217	11/13	503 Antler	
1218	11/13	136 Cas-Hills	
1219	11/13	128 Cas-Hills	Very Small
1220	11/13	117 Cas-Hills	Stop & Waste

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 62 of 66

Line #	Date #	Address	Comments
1221	11/13	101 Villa Ann	Stop & Waste / Customer Contacted
1222	11/13	104 Lou Jon Circle	
1223	11/13	108 Lou Jon Circle	Stop & Waste / Customer Contacted
1224	11/13	212 Northcrest	Customer Contacted
1225	10/26	106 Cornwall	Front Faucet / Customer Contacted
1226	8/18	1340 Vermont	
1227	9/2	626 Fleming	
1228	9/9	407 Peabody	
1229	9/9	2303 Quintana	
1230	11/24	102B Peg Sue	Customer Contacted
1231	11/24	814 #1 Lockhill Selma	" / Toilet
1232	11/24	814 #2 Lockhill Selma	Customer Contacted
1233	11/24	214 Northcrest	
1234	11/24	204 Northcrest	
1235	11/24	216 Halbart	Customer Contacted / Stop and Waste
1236	11/24	206 Briarcliff	
1237	11/27	206 Glen Tower	
1238	11/27	204 Glen Tower	Customer Contacted / Stop and Waste
1239	11/27	205 Glen Tower	Stop and Waste

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 62 of 66

Line #	Date #	Address	Comments
1240	11/27	208 Gardenview	Very Small / Sprinkler
1241	11/27	217 Glen Tower	Customer Contacted
1242	11/27	226 Gardenview	Sprinkler
1243	11/27	227 Glen Tower	Customer Contacted
1244	11/27	222 Carolwood	Stop and Waste
1245	11/27	214 Carolwood	Customer Contacted
1246	11/27	216 Carolwood	" / Sprinkler
1247	11/27	215 Gardenview	Back Faucet
1248	11/27	207 Gardenview	
1249	11/17	102 Prinz	
1250	11/17	217 Carolwood	
1251	11/17	214 Prinz	
1252	11/17	107 Prinz	
1253	11/17	100 Dogwood	
1254	11/17	102 Dogwood	Stop and Waste
1255	11/17	105 Dogwood	
1256	11/17	117 Dogwood	
1257	11/17	119 Dogwood	
1258	11/17	118 Dogwood	Front Faucet
1259	11/17	123 Dogwood	Stop and Waste
1260	11/17	1303 Lockhill Selma	Customer Contacted

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 63 of 66

Line #	Date #	Address	Comments
1261	11/17	118 Moss Drive	"
1262	11/17	111 Moss Drive	
1263	11/17	107 Moss Drive	Customer Contacted / Front Faucet
1264	11/17	106 Sunflower	
1265	11/17	10106 N. Manton Lane	Stop and Waste / Door Tag
1266	11/17	10123 N. Manton Lane	Customer Contacted
1267	11/17	208 La Rue Ann	"
1268	11/17	919 Northcrest	
1269	11/17	1010 Mt. Kisco	Front Faucet
1270	11/17	1119 Mt. Eden	"
1271	11/17	1102 Mt. Eden	" / Customer Contacted
1272	11/17	1103 Mt. Eden	" / "
1273	11/17	1022 Mt. Eden	
1274	11/23	1106 Mt. Rainer	
1275	11/23	1123 Mt. Rainer	Customer Contacted / Stop and Waste
1276	11/23	1003 Melissa	
1277	11/23	1114 Haltown	Stop and Waste
1278	11/24	1002 Haltown	
1279	11/24	1111 Spentwing	
1280	11/24	104 Manton	Front Faucet

APPENDIX F

Edwards Underground Water District Customer Side Leak List 1992

System: Bexar Metropolitan Water District

Page 64 of 66

Line #	Date #	Address	Comments
1281	11/30	10606 Sunflower	
1282	11/30	10507 Mt. Marcy	
1283	11/30	10401 Mt. Marcy	Front Faucet
1284	11/30	1414 Mt. Vieja	
1285	11/30	1332 Spanish Oak	Customer Contacted
1286	11/30	1333 Grey Oak	"
1287	11/30	1338 Grey Oak	" / Kitchen
1288	11/30	1419 Grey Oak	Yard Leak
1289	11/30	1438 Grey Oak	
1290	12/3	112 Ranchland	Stop and Waste
1291	12/3	308 Caladium	Door Tag
1292	12/4	101 Lemonwood	
1293	12/4	109 Roletto	
1294	12/4	300 Zornia	
1295	12/4	211 Zornia	
1296	12/4	209 Zornia	
1297	12/4	203 Zornia	Customer Contacted
1298	12/4	2000 N.W. Military	
1299	12/4	2002 N.W. Military	
1300	12/4	2106 (?) N.W. Military	
1301	12/4	2106 (?) N.W. Military	

APPENDIX F

Edwards Underground Water District
Customer Side Leak List
1992System: Bexar Metropolitan Water DistrictPage 65 of 66

Line #	Date #	Address	Comments
1302	12/4	2106 (?) N.W. Military	
1303	12/4	111 East Castle	Front Faucet / 1 More
1304	12/4	116 East Castle	
1305	12/7	101 Fox Hall Lane	Customer Contacted
1306	12/7	120 Fox Hall Cove	
1307	12/7	126 Fox Hall Lane	
1308	12/7	119 Fox Hall Lane	
1309	12/7	231 Fox Hall Lane	Customer Contacted
1310	12/7	230 Fox Hall Lane	Front Faucet
1311	12/7	240 Fox Hall Lane	" / Toilet
1312	12/7	214 Hibiscus	
1313	12/7	315 Fox Hall Lane	
1314	12/7	120 Winston	
1315	12/7	307 Caladium	Customer Contacted / Stop and Waste
1316	12/7	210 Persimmons	Customer Contacted
1317	12/7	104 Ivy Wood	"
1318	12/7	105 Ivy Wood	"
1319	12/7	100 Lemonwood	"
1320	12/7	100 Gardenview	" / Stop & Waste
1321	12/9	103 Persimmons	Customer Contacted
1322	12/9	104 Persimmons	"

APPENDIX F

Edwards Underground Water District Customer Side Leak List 1992

System: Bexar Metropolitan Water District

Page 66 of 66

Line #	Date #	Address	Comments
1323	12/9	102 Gardenview	Customer Contacted
1324	10/27	203 Honeysuckle	
1325	11/30	10511 Sunflower	

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 1 of 20

Line #	Plat	Address
1	T-9.2	14655 Pleasanton Rd.
2	S-9.3	Pleasanton Rd. Tract C
3	S-9.3	Pleasanton Rd. Tract B
4	O-10.2	9923 Hwy 281
5	O-10.2	1410 San Rafael
6	N-9.3	2 services, last two lots on Tidewind at Yett
7	N-8.2	434 Moursund
8	N-8.1	2 services, Garnett southeast of Villaret
9	N-7.2	1 service west of 706 W. Mally
10	N-6.3	1 service between 226 and 252 Strech St.
11	N-6.2	1438 Mally
12	N-4.1	262 Tedder St.
13	N-4.1	306 Vincent
14	M-10.4	1 service beside 4729 U.S. Hwy 281
15	M-7.2	1 service across from 331 Ansley
16	M-5.4	3139 Hunter Blvd.
17	M-5.4	3135 Hunter Blvd.
18	M-5.4	3131 Hunter Blvd.
19	M-5.4	3127 Hunter Blvd.
20	M-5.4	3123 Hunter Blvd.
21	M-5.4	3119 Hunter Blvd.
22	M-5.4	3115 Hunter Blvd.

APPENDIX G
Edwards Underground Water District
Services Added to Plat
1992

System: Bexar Metropolitan Water District

Page 2 of 20

<u>Line #</u>	<u>Plat</u>	<u>Address</u>
23	M-5.4	3111 Hunter Blvd.
24	M-5.4	3107 Hunter Blvd.
25	M-5.4	2130 Bane Blvd.
26	M-5.4	2126 Bane Blvd.
27	M-5.3	1245 Gillette
28	M-5.1	2606 Tortuga
29	M-5.1	2207 Abacus Dr.
30	M-5.1	2203 Abacus Dr.
31	M-5.1	2147 Abacus Dr.
32	M-5.1	2143 Abacus Dr.
33	M-5.1	2139 Abacus Dr.
34	M-5.1	2135 Abacus Dr.
35	M-5.1	2131 Abacus Dr.
36	M-5.1	2127 Abacus Dr.
37	M-5.1	2123 Abacus Dr.
38	M-5.1	2119 Abacus Dr.
39	M-5.1	2115 Abacus Dr.
40	M-5.1	2111 Abacus Dr.
41	M-5.1	2105 Abacus Dr.
42	M-4.4	242 Spaatz
43	M-4.4	366 Doolittle
44	M-4.4	422 Bradley

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 3 of 20

<u>Line #</u>	<u>Plat</u>	<u>Address</u>
45	M-4.3	106 Spaatz
46	M-4.3	110 Doolittle
47	M-4.1	3135 Goose Creek
48	M-4.1	3235 Pine Hollow
49	M-4.1	3127 Annarose
50	M-4.1	3232 Fort Parker
51	L-10.4	946 Dodic
52	L-9.4	502 Saipan
53	L-9.4	506 Saipan
54	L-9.4	300 E. Petaluma
55	L-9.3	822 Deely
56	L-9.2	546 Creath Pl.
57	L-8.4	8610 Garnett
58	L-8.4	8606 Garnett
59	L-8.4	8602 Garnett
60	L-8.4	1854 Clamp
61	L-8.3	1 service next to 171 E. Petaluma
62	L-8.3	202 E. Petaluma
63	L-7.2	3413 Commercial
64	L-7.2	1515 Burton
65	L-6.2	1239 W. Hutchins
66	L-6.2	1223 W. Formosa

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 4 of 20

Line #	Plat	Address
67	L-5.4	2607 Patron Dr.
68	L-5.4	2603 Patron Dr.
69	L-4.2	803 Palo Alto
70	L-4.1	3106 Owasso St.
71	L-4.1	3138 Kiowa
72	K-8.1	139 Clovis Pl.
73	K-7.4	1027 W. Vestal
74	K-7.4	1023 W. Vestal
75	K-7.4	923 Escalon
76	K-7.4	903 Drury
77	K-7.4	939 W. Vestal
78	K-7.3	831 Cantrell
79	K-7.3	1 service on Drury at drainage R.O.W.
80	K-7.3	535 W. Vestal
103	K-7.2	626 Grosvenor
104	K-7.2	501 Burton
105	K-7.1	522 Logwood
106	K-7.1	938 Grosvenor
107	K-6.3	1439 Drury
108	K-6.3	1403 Drury
109	K-6.3	1438 Drury
110	K-6.3	1239 Cantrell

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 6 of 20

Line #	Plat	Address
111	J-5.2	Across from 850 W. Mayfield
112	J-5.1	147 King Ave.
113	J-5.1	1874 Kendalia
114	J-5.1	1975 McCauley in alley
115	J-4.3	Between 3255 and 3251 S.W. Military
116	J-4.3	7155 Somerset Rd.
117	J-4.2	115 Kelsey
118	J-4.2	South San Elementary on Price Ave.
119	J-4.2	1134 W. Mayfield, service on Oregon
120	J-4.2	175 Price Ave.
121	J-4.2	167 Price Ave.
122	J-4.2	161 Price Ave.
123	J-4.3	159 Price Ave.
124	J-3.2	226 Prospect
125	I-8.4	139 Gerald
126	I-8.1	216 Southcross
127	I-7.4	Between 6117 - 6111 Macdona
128	I-7.2	806 Brunswick
129	I-6.3	West of 503 Vickers
130	I-6.1	Between 1415-11 W. Southcross
131	I-5.2	159 Fay
132	I-5.1	Between 450-426 U.S. Hwy 81

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 7 of 20

Line #	Plat	Address
133	I-4.4	426 Wilcox in alley
134	I-4.4	3227 Gerald in alley
135	I-4.4	926 Kings Ave.
136	I-4.3	200 Block Kings Ave.
137	I-4.3	200 Block Kings Ave.
138	I-4.3	Between 500-510 Peabody in alley
139	I-4.1	2706 W. Southcross
140	I-3.3	2602 Quintana
141	I-3.3	2412 Quintana
142	H-7.4	823 Stonewall
143	H-7.3	609 Stonewall
144	H-7.3	687 Stonewall
145	H-7.2	802 Vermont - Service on Bruhn St.
146	H-7.1	Between 937-927 Division in alley
147	H-6.4	1506 Brighton
148	H-6.4	1502 Brighton
149	H-6.4	1447 Flanders
150	H-6.4	1443 Flanders
151	H-6.4	1437 Flanders
152	H-6.4	1440 Flanders
153	H-6.4	602 Elks
154	H-6.3	1245 Brighton

APPENDIX G
Edwards Underground Water District
Services Added to Plat
1992

System: Bexar Metropolitan Water District

Page 8 of 20

Line #	Plat	Address
155	H-6.3	1422 Flanders
156	H-6.3	446 Elks
157	H-6.3	306 Elks
158	H-6.3	304 Humboldt
159	H-6.2	1328 Division
160	H-6.1	Between 3635 and 3615 Nogalitos
161	H-6.1	3615 Nogalitos
162	H-6.1	North of 3607 Nogalitos
163	H-6.1	3836 Nogalitos
164	H-6.1	130 Illg
165	H-6.1	122 Illg
166	H-6.1	114 Illg
167	G-7.4	Two services 503 Carlisle
168	G-7.4	509 Carlisle
169	G-7.4	513 Carlisle
170	F-5.4	110 Emerson
171	F-5.3	2306 Jupiter
172	F-5.1	Next to 1139 W. Thompson Pl.
173	F-5.1	1139 W. Thompson Pl.
174	F-5.1	1203 W. Thompson Pl.
175	F-4.3	327 Emerson
176	F-4.3	247 W. Emerson

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 9 of 20

<u>Line #</u>	<u>Plat</u>	<u>Address</u>
177	F-4.2	502 Bedford
178	F-4.2	522 Pletz
179	F-4.1	Gen. McMullen across from Dexter
180	E-4.4	2519 Aiken
181	E-4.3	942 Cupples
182	E-4.3	N.E. corner of Cupples and Darby
183	E-4.3	Across from 2939 Weir Ave.
184	E-3.4	3826 Bay St.
185	E-4.2	151 Blocker
186	D-5.4	542 Cupples
187	D-5.4	1233 Barclay
188	D-5.4	1239 Barclay
189	D-5.5	1243 Barclay - two services
190	D-4.4	1030 Patton
191	D-4.1	317 Juanita
192	D-5.4	1406 Merida
193	H-7.4	1115 Flanders
194	I-3.3	2602 Quintana
195	I-4.3	3003 Gerald
196	I-6.3	219 Whitman
197	I-8.4	683 W. Pyron
198	J-4.4	271 Briggs

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 10 of 20

Line #	Plat	Address
199	J-9.1	118 Bonner
200	K-3.2	U.S. Hwy 81 @ Pitluk N.W.
201	K-7.1	339 Escalon
202	M-4.3	Between 130-128 Wainwright
203	M-4.3	106 Spaatz
204	M-4.3	Next to 106 Doolittle
205	M-4.3	1414 Beverly Ann
206	M-7.4	Between 922-906 W. Baetz
207	M-8.2	159 Moursund
208	M-4.1	238 Ike
209	N-5.1	1477 Villaret Blvd.
210	N-6.2	1410 Caballero
211	Q-0.1	Fisher Rd. between 12211 and 12225
212	Q-0.1	Fisher Rd. between 12211 and 12225
213	Q-0.1	Fisher Rd. between 12211 and 12225
214	Q-0.1	Fisher Rd. between 12211 and 12225
215	Q-0.1	Fisher Rd. between 12211 and 12225
216	Q-0.1	Fisher Rd. between 12211 and 12225
217	J-8.3	700/600 Block of S.W. Military across from FH H.
218	J-8.3	700/600 Block of S.W. Military across from FH H.
219	J-8.3	700/600 Block of S.W. Military across from FH H.
220	SA-25.4	Somerset Rd.

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 11 of 20

Line #	Plat	Address
221	SB-25.1	13687 Somerset Rd.
222	SB-25.1	13742 Somerset Rd.
223	SB-25.1	13751 Somerset Rd.
224	SB-25.1	13891 Somerset Rd.
225	SB-25.1	13892 Somerset Rd.
226	SB-25.1	13896 Somerset Rd.
227	SB-25.1	13900 Somerset Rd.
228	SB-25.1	Across from 13900 Somerset
229	SB-25.4	13981 Somerset Rd.
230	SB-25.4	Across from 13981 Somerset Rd.
231	SD-23.4	Somerset Rd.
232	SE-22.3	16792 Somerset Rd.
233	SE-23.1	Somerset Rd.
234	SE-23.4	Somerset Rd.
235	SH-21.1	19290 K. Street
236	SH-21.1	19357 Somerset Rd.
237	SH-21.1	19075 #1 Somerset Rd.
238	SH-21.2	19075 #2 Somerset Rd.
239	SH-21.3	7855 Second St.
240	SH-21.4	8155 Second St.
241	SH-21.4	Third St. @ K St.

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 12 of 20

<u>Line #</u>	<u>Plat</u>	<u>Address</u>
242	SH-21.4	Third St. @ N. Dixon St.
243	SI-20.2	8710 James St.
244	SI-20.2	8660 James St.
245	SI-20.2	8650 James St.
246	SI-20.2	8620 James St.
247	SI-20.2	8715 James St.
248	SI-20.2	8655 James St.
249	SI-20.2	B.M.W.D. Clayton St. Pump Station
250	SH-21.3	7990 Casias
251	SI-20.3	8715 S. FM 2790
252	SI-20.3	8685 #1 S. FM 2790
253	SI-20.3	8685 #2 S. FM 2790
254	SI-20.3	8685 #3 S. FM 2790
255	SI-20.3	8685 #4 S. FM 2790
256	SI-20.3	8655 S. FM 2790
257	SI-20.3	8625 S. FM 2790
258	SI-20.3	8611 S. FM 2790
259	SI-20.3	8535 S. FM 2790
260	SI-20.3	8489 #1 S. FM 2790
261	SI-20.3	8489 #2 S. FM 2790
262	SI-20.3	8489 #3 S. FM 2790

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 13 of 20

<u>Line #</u>	<u>Plat</u>	<u>Address</u>
263	SI-20.3	8485 #1 S. FM 2790
264	SI-20.3	8485 #2 S. FM 2790
265	SI-20.3	8455 S. FM 2790
266	SI-20.3	8680 S. FM 2790
267	SI-20.3	8660 S. FM 2790
268	SI-20.3	8640 S. FM 2790
269	SI-20.3	8620 S. FM 2790
270	SI-20.3	8580 S. FM 2790
271	SI-20.3	8560 S. FM 2790
272	SI-20.3	8542 S. FM 2790
273	SI-20.3	8536 S. FM 2790
274	SI-20.3	8534 S. FM 2790
275	SI-20.3	8532 S. FM 2790
276	SI-20.3	8474 S. FM 2790
277	SI-20.3	20014 #1 Mitchell St.
278	SI-20.3	20014 #2 Mitchell St.
279	SI-20.3	19943 Mitchell St.
280	SI-20.3	20031 Mitchell St.
281	SI-20.3	20041 Mitchell St.
282	SI-20.3	8815 Johnson St.
283	SI-20.3	8475 Johnson St.

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 14 of 20

Line #	Plat	Address
284	SI-20.3	8520 Johnson St.
285	SI-20.3	8480 Johnson St.
286	SI-20.3	8470 Johnson St.
287	SI-20.4	--- S. FM 2790
288	SI-21.1	8219 Fourth St.
289	SI-21.1	19670 Kurz
290	SI-21.1	19690 Oil St.
291	SI-21.1	8211 Fifth St.
292	SI-21.1	8212 Fifth St.
293	SI-21.1	19639 N. Dixon St.
294	SI-21.1	19665 Oil St.
295	SI-21.1	19695 Oil St.
296	SI-21.1	19705 Oil St.
297	SI-21.1	Next to 19727 Oil St.
298	SI-21.1	19809 Oil St.
299	SI-21.1	Oil St. @ James St.
300	SI-21.1	8360 James St.
301	SI-21.1	8310 James St.
302	SI-21.1	8260 James St.
303	SI-21.2	19607 Somerset St.
304	SI-21.2	Between 7891-7970 Sixth St.

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 15 of 20

Line #	Plat	Address
305	SI-21.2	Across from 7998 Sixth St.
306	SI-21.2	Between 7730-7708 Sixth St.
307	SI-21.2	19936 Casias Lane
308	SI-21.2	Next to 7871 Sixth St.
309	SI-21.2	7980 Sixth St.
310	SI-21.2	7970 Sixth St.
311	SI-21.2	7989 Seventh St.
312	SI-21.2	East end of Seventh St.
313	SI-21.2	19880 Touchstone St.
314	SI-21.3	7755 #3 Barron St.
315	SI-21.3	7755 #5 Barron St.
316	SI-21.3	7755 #6 Barron St.
317	SI-21.3	7755 #7 Barron St.
318	SI-21.3	7755 #8 Barron St.
319	SI-21.3	7755 #9 Barron St.
320	SI-21.3	7755 #10 Barron St.
321	SI-21.3	7755 #11 Barron St.
322	SI-21.3	7755 #12 Barron St.
323	SI-21.3	7755 #13 Barron St.
324	SI-21.3	Across from 7755 #6 Barron St.
325	SI-21.3	Across from 7755 #11 Barron St.

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 16 of 20

<u>Line #</u>	<u>Plat</u>	<u>Address</u>
326	SI-21.3	7795 W. Dixon
327	SI-21.3	7785 W. Dixon
328	SI-21.3	8815 #1 Eighth St.
329	SI-21.3	8815 #2 Eighth St.
330	SI-21.3	8012 Eighth St.
331	SI-21.4	8435 W. Dixon
332	SI-21.4	8415 W. Dixon
333	SI-21.4	8375 W. Dixon
334	SI-21.4	8345 W. Dixon
335	SI-21.4	8251 W. Dixon
336	SI-21.4	8175 W. Dixon
337	SI-21.4	8101 W. Dixon
338	SI-21.4	8420 W. Dixon
339	SI-21.4	8330 W. Dixon
340	SI-21.4	8283 W. Dixon
341	SI-21.4	8279 W. Dixon
342	SI-21.4	19898 Caruthers - service is on Eighth St.
343	SI-21.4	8151 Eighth St.
344	SI-21.4	8147 Eighth St.
345	SI-21.4	8029 Eighth St.
346	SI-21.4	Next to 8220 Eighth St.

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 17 of 20

<u>Line #</u>	<u>Plat</u>	<u>Address</u>
347	SI-21.4	19914 #1 Somerset St.
348	SI-21.4	8160 Ninth St.
349	SI-21.4	8070 Ninth St.
350	SI-21.4	Next to 8070 Ninth St.
351	SI-21.4	20215 Somerset St.
352	SI-21.4	20118 Somerset St.
353	SI-21.4	20110 Somerset St.
354	SI-21.4	Next to 20168 Somerset St.
355	SI-22.1	19635 Quail Run
356	SI-22.1	19611 Dove Hill
357	SI-22.1	Next to 19611 Dove Hill
358	SI-22.1	Sixth St. @ Dove Hill
359	SI-22.2	19780 Frank Hoffman Rd.
360	SI-22.2	7245 FM 2790 W.
361	SI-22.2	7155 FM 2790 W.
362	SI-22.2	-- FM 2790 W.
363	SI-22.4	20265 Howard Payne Rd.
364	SI-22.4	7475 S. Dixon
365	SI-22.4	7435 #1 S. Dixon
366	SI-22.4	7435 #2 S. Dixon
367	SI-22.4	7405 S. Dixon

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 18 of 20

<u>Line #</u>	<u>Plat</u>	<u>Address</u>
368	SI-22.4	7335 S. Dixon
369	SI-22.4	7325 S. Dixon
370	SI-22.4	7534 S. Dixon
371	SI-22.4	20163 Frank Hoffman
372	SJ-20.3	20696 Somerset Rd.
373	SJ-21.1	Across from 20317-20295 Somerset Rd.
374	SJ-21.1	Across from 20317-20295 Somerset Rd.
375	SJ-21.1	Across from 20317-20295 Somerset Rd.
376	SJ-21.1	Across from 20317-20295 Somerset Rd.
377	SJ-21.1	Between 20490 and 20498 Somerset Rd.
378	SJ-21.1	Between 20490 and 20498 Somerset Rd.
379	SJ-21.1	Across from 20515 Somerset Rd.
380	SJ-21.1	20515 Somerset Rd.
381	CD-1	2301 Military
382	CD-2	Winston @ Lockhill Selma
383	CD-2	2259 Military
384	CD-2	Woodyew @ Slimp #1
385	CD-2	Woodyew @ Slimp #2
386	CD-2	2116 Military
387	CD-2	108 La Rue Ann
388	CD-2	124 Elizabeth Ann

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 19 of 20

<u>Line #</u>	<u>Plat</u>	<u>Address</u>
389	CD-2	Between 115-119 Manton Ln.
390	CD-2	1034 Jandre Lane
391	CD-2	10401 Mt. Marcy Dr.
392	CD-2	10414 Monte Sereno
393	CD-3	1014 Mt. Riga
394	CD-3	1301 Spanish Oak
395	CD-3	1106 Grey Oak
396	CE-1	Service 2897 Hibiscus
397	CE-1	86 Roundup Dr.
398	CE-2	207 East Castle
399	CE-2	206 Gardenvue
400	CF-1	Next to 101 Castleoaks
401	CF-2	Next to 112 Roundup Dr.
402	CF-2	Next to 203 Lemonwood
403	CF-2	Next to 100 Honeysuckle
404	CF-2	112 Gardenvue
405	CF-2	110 Gardenvue
406	CF-2	345 Towne Vue
407	CF-2	101 Sheffield
408	CF-2	104 Wickford
409	CF-3	102 Briarcliff

APPENDIX G

Edwards Underground Water District Services Added to Plat 1992

System: Bexar Metropolitan Water District

Page 20 of 20

<u>Line #</u>	<u>Plat</u>	<u>Address</u>
410	CF-3	206 Lochaven Ln.
411	CF-3	6601 Blanco Rd.
412	CF-3	204 Sir Arthur
413	CG-2	Between 112-120 Traventine
414	CG-2	Across from 101 Squire Row
415	CG-3	602 Antler
416	CG-3	107 Riviera
417	CG-3	Next to 130 Danube

APPENDIX H

Edwards Underground Water District Fire Hydrants or Valves Added to Plat 1992

System: Bexar Metropolitan Water District

Page 1 of 5

Line #	Plat #	Address	Type	Number Added
1	N-4.2	Bradley @ Lawley	Valve	2
2	N-4.2	Bradley @ Lawley	Fire Hydrant	1
3	N-4.2	Ike @ Lawley	Fire Hydrant	1
4	N-4.2	Tedder @ Lawley	Fire Hydrant	1
5	N-4.2	138 Tedder	Fire Hydrant	1
6	N-4.1	228 Ike	Fire Hydrant	1
7	N-4.1	230 Tedder	Fire Hydrant	1
8	L-4.1	8327 Kiowa	Valve	1
9	J-72	Kendalia west of Commercial	Fire Hydrant	1
10	J-71	1042 Kendalia	Fire Hydrant	1
11	J-71	1083 Kendalia	Fire Hydrant	1
12	J-71	982 Kendalia	Fire Hydrant	1
13	J-71	954 Kendalia	Fire Hydrant	1
14	J-4.3	3255 S.W. Military	Fire Hydrant	1
15	J-4.3	3251 S.W. Military	Fire Hydrant	1
16	I-4.1	2706 W. Southcross	Service Valve	1
17	H-7.2	814-815 Crystal	Main Line Valve	1
18	H-6.4	Harlan @ Zarmamora	"	3
19	F-4.4	3322 Roselawn	Service Valve	1
20	F-4.1	Hallett for 1919 Gen McMullen	Service Valve	3
21	D-4.3	1507 Patton	Service Valve	1

APPENDIX H

Edwards Underground Water District Fire Hydrants or Valves Added to Plat 1992

System: Bexar Metropolitan Water District

Page 2 of 5

Line #	Plat #	Address	Type	Number Added
22	K-8.2	Shrine @ Loleta	Main Line Valve	1
23	K-9.1	Shrine @ Norma	"	1
24	K-9.1	Shannon @ Shue	Service Valve	1
25	L-9.3	E. Petaluma @ Bascum	Main Valve	1
26	M-4.3	Wainwright @ Lawley	Main Valve	1
27	M-4.1	228 Ike	Fire Hydrant	1
28	Q-0.1	Fisher Rd. between 12211 and 12225	Service Valves	3
29	Q-0.4	12515 Fisher Rd.	Service Valve	1
30	SC-24.2	Somerset Rd.	Blow Off with Valve	1
31	SH-21.1	Somerset Rd. Pump Station	Main Valve	2
32	SI-21.1	8212 Fifth St.	Blow Off with Valve	1
33	SI-21.1	K. Street	Fire Hydrant	1
34	SI-21.1	K. Street	Main Valve	1
35	SI-21.2	Sixth Street	Fire Hydrant E	1
36	SI-21.2	Barrum Street	Blow Off with Valve	1
37	SI-21.3	Eighth @ Touchstone S.	Blow Off with Valve	1
38	SI-21.4	8474 W. Dixon	Fire Hydrant	1
39	CD-1	W. Dixon @ N. Dixon	Main Valve	1
40	CD-1	400 Foxhall Ln.	Service Valve	1
41	CD-1	Winston @ Military	Main Valve	1
42	CD-1	2300 Military	Blow Off with Valve	1

APPENDIX H

Edwards Underground Water District Fire Hydrants or Valves Added to Plat 1992

System: Bexar Metropolitan Water District

Page 3 of 5

Line #	Plat #	Address	Type	Number Added
43	CD-2	2259 Military	Service Valve	1
44	CD-2	1351 Lockhill Selma	Service Valve	1
45	CD-2	1639 Lockhill Selma	Service Valve	1
46	CD-2	1653 Lockhill Selma	Service Valve	1
47	CD-2	1637 West Ave	Service Valve	1
48	CE-1	214 Hibiscus	Main Valve	1
49	CE-2	102 Zornia Dr.	Service Valve	1
50	CE-2	200 Caladium	"	1
51	CE-2	103 Roieto	"	1
52	CE-2	100 Lemonwood	"	1
53	CE-2	100 Gardenview	"	1
54	CE-2	106 Mars Dr.	"	1
55	CE-2	101 Dogwood	"	1
56	CE-2	103 Dogwood	"	1
57	CE-2	101 Prinz	"	1
58	CE-2	108 Prinz	"	1
59	CE-2	110 Prinz	"	1
60	CE-2	200 Prinz	"	1
61	CE-2	212 Prinz	"	1
62	CE-2	107 Carolwood	"	1
63	CE-2	111 Carolwood	"	1
64	CE-2	205 Carolwood	"	1

APPENDIX H

Edwards Underground Water District Fire Hydrants or Valves Added to Plat 1992

System: Bexar Metropolitan Water District

Page 4 of 5

<u>Line #</u>	<u>Plat #</u>	<u>Address</u>	<u>Type</u>	<u>Number Added</u>
65	CE-2	211 Carolwood	Service Valve	1
66	CE-2	202 Gardenview	"	1
67	CE-2	211 Gardenview	"	1
68	CE-2	205 Glentower	"	1
69	CE-2	211 Glentower	"	1
70	CE-2	201 Tamsworth	"	1
71	CE-2	Military @ Carolwood	Fire Hydrant	1
72	CE-3	226 Carolwood	Valve	1
73	CE-3	216 Halbart	Service Valve	1
74	CF-2	Across from 100 Honeysuckle	"	1
75	CF-2	Across from 118 Gardenview on Roletto	"	1
76	CF-2	101 Chattington	"	1
77	CF-2	103 Chattington	"	1
78	CF-2	202 Sheffield	"	1
79	CF-2	104 Ivy Wood	"	1
80	CF-3	104 Briarcliff	"	1
81	CF-3	101 Northcrest	"	1
82	CF-3	Service 29063 Blanco Rd.	"	1
83	CF-3	100 Irongate	"	1
84	CF-3	108 Irongate	"	1
85	CF-3	110 Irongate	"	1

APPENDIX H

Edwards Underground Water District Fire Hydrants or Valves Added to Plat 1992

System: Bexar Metropolitan Water District

Page 5 of 5

Line #	Plat #	Address	Type	Number Added
86	CG-3	149 Lou Jon	Service Valve	1
87	CG-3	133 Lou Jon	"	1
88	GG-3	106 Villa Ann	"	1
89	CG-3	144 Cas-Hills	"	1
90	CG-3	136 Cas-Hills	"	1
91	CG-3	108 Cas-Hills	"	1
92	CG-3	123 Danube	"	1
93	CG-3	102 Herwick	"	1

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 1 of 32

Line #	Plat #	Address	Valve #	Number of Valves
1	S-7.1	Mauermann Rd.	Fire Hydrant A	1
2	R-5.4	Walsh Rd. @ Applewhite	#1	1
3	Q-5.4	Zarzamora Rd.	#9	1
4	Q-5.4	Applewhite Rd.	Fire Hydrant A	1
5	Q-5.4	Applewhite Rd.	#1	1
6	Q-5.1	Applewhite Rd.	#1	1
7	Q-5.1	Applewhite Rd.	Fire Hydrant B	1
8	Q-5.1	Applewhite Rd.	Fire Hydrant C	1
9	P-11.4	U.S. 281	Fire Hydrant A	1
10	P-4.4	Woodsage @ Hillcrest	#12	1
11	P-4.4	Winsome @ Tilson	#13, 15	2
12	P-4.4	Landcrest @ Hillcrest	#10	1
13	P-4.4	Gaylord	#20	1
14	P-4.4	Valley Star @ Gaylord	#8, 7	2
15	P-4.2	State Hwy 16	Fire Hydrant A,D	2
16	P-4.2	State Hwy 16	#3	1
17	P-4.2	Applewhite Rd.	#11	1
18	P-4.1	Kingsride @ Gaylord	Fire Hydrant B	1
19	P-4.1	Durette @ Claymore	#24	1
20	P-4.1	Bayhurst @ Gaylord	#3	1
21	P-4.1	Wink Circle	#22	1
22	P-4.1	Dana Circle	#25	1

APPENDIX I

Edwards Underground Water District
Valves/Unable to Locate
1992

System: Bexar Metropolitan Water DistrictPage 2 of 32

Line #	Plat #	Address	Valve #	Number of Valves
23	P-4.1	Fidelia	#23	1
24	O-10.3	Hwy 281	#12	1
25	O-9.1	Police Training Field	Fire Line #7	1
26	O-8.3	Moursund Rd.	#1, 2	2
27	O-8.2	Moursund Rd.	#6, 5	2
28	O-8.1	S. W. Loop 410	Fire Hydrant B	1
29	O-7.2	S. W. Loop 410	#2, 4, 5	3
30	O-6.4	Zarzamora	#1	1
31	O-6.1	S.W. Loop 410	#5	1
32	O-5.2	S.W. Loop 410	#4	1
33	O-5.1	S.W. Loop 410	#3	1
34	O-4.3	Hwy 16	Fire Hydrant B	1
35	N-10.4	954 Chavaneaux	#2	1
36	N-10.3	281 @ Chavaneaux	#1	1
37	N-10.1	Herbst Rd.	#2	1
38	N-9.3	Chavaneaux	#5	1
39	N-9.2	Villaret @ Yett	#10	1
40	N-9.1	Villaret @ Walhalla	#11	1
41	N-8.4	Buchanan	#5, 6	2
42	N-8.4	Garnett	#8, 10	2
43	N-8.4	Chavaneaux	Fire Hydrant F	2
44	N-8.2	W. Mally	#1, 18	2

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 3 of 32

Line #	Plat #	Address	Valve #	Number of Valves
45	N-8.3	Trustin	#7	1
46	N-8.3	Moursund	#6	1
47	N-8.1	Mally @ Clamp	#9	1
48	N-8.1	Clamp @ W. Villaret	#5, 7	2
49	N-8.1	Garnett Ave.	#12	1
50	N-7.3	Chavaneaux @ Commercial	#10, 12	2
51	N-7.2	Mally @ Commercial	#4	1
52	N-7.2	Commercial @ W. Villaret	Fire Hydrant F	1
53	N-7.1	W. Villaret @ R. R. Tracks	#1	1
54	N-7.1	Grand River	#11	1
55	N-7.1	W. Villaret	Fire Hydrant B	1
56	N-6.4	Jennifer	#9, 10, 11, 12	4
57	N-6.4	Zarzamora @ Chaveneaux	#14	1
58	N-6.2	Mally @ Strech	#14	1
59	N-5.4	Palo Alto College	#3	1
60	N-5.3	Jennifer @ Lourdes	#11	1
61	N-5.3	Palo Alto College	Fire Hydrant D	1
62	N-5.2	Lytle @ W. Villaret	#6, 9, 22, 28, I	5
63	N-5.2	Lytle @ Mally	#23	1
64	N-5.2	Boco Chica	#18	1
65	N-5.2	Olimito	#16	1
66	N-5.2	1439 Villaret	Fire Hydrant H	1

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 4 of 32

Line #	Plat #	Address	Valve #	Number of Valves
67	N-4.4	Chamita @ Manzano	#19	1
68	N-4.4	Celeste	#11	1
69	N-4.4	3310 Twining	#17	1
70	N-4.3	Reforma @ Wikieup	#10, 11	2
71	N-4.2	132 Ike	#9	1
72	N-4.2	Palo Alto @ W. Villaret	#2	1
73	N-4.2	W. Villaret @ Hwy 348	#19, 28	2
74	N-4.2	W. Mally @ Hwy 346	#17, 23	2
75	N-4.1	Coconino	#14	1
76	N-4.1	Vincent @ Lasswell	#17	1
77	N-3.3	Maria Isabel @ Twining	#2, 3	2
78	M-10.4	Sams @ Ely	#4, 5	2
79	M-10.4	Bernard @ Ely	#2	1
80	M-9.4	Baetz @ Walhalla	#9	1
81	M-9.4	Walhalla @ Myrich	Service Valve	1
82	M-9.4	335 Beam	#1	1
83	M-9.3	Sams @ Lucinda	#1, 2	2
84	M-9.2	706 Baltzell	#10	1
85	M-9.1	Topsey	#7	1
86	M-9.1	347 Ansley	#8	1
87	M-9.1	534 Barberry	#13	1
88	M-9.1	503 Emmett	#12	1

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 5 of 32

Line #	Plat #	Address	Valve #	Number of Valves
89	M-9.1	Ashley @ Walhalla	# 1, 9, 10	3
90	M-8.3	112 Gillette	#2	1
91	M-8.3	409 Moursund	#18	1
92	M-8.2	Moursund @ Ansley	#3	1
93	M-8.1	Ansley	#25	1
94	M-7.4	1122 Baetz	#8	1
95	M-7.3	Baetz @ Burcham	#6	1
96	M-7.2	Ansley @ Ludtke	#6, 3	2
97	M-7.1	Shemya @ Escalon	#3	1
98	M-6.4	Gillette @ Zarzamora	#3	1
99	M-6.2	1402 Beverly Ann	#13	1
100	M-6.2	9000 Geraldine	#5	1
101	M-6.2	Janice Gail	#6, 7	2
102	M-6.2	Ilene Lynn	#9	1
103	M-6.1	1400 Betty	#12	1
104	M-6.1	1502 W. Ansley	#15	1
105	M-5.4	9043 Niner Ln.	#15	1
106	M-5.4	2202 Reel Dr.	#6	1
107	M-5.3	1902 Perlita	#32	1
108	M-5.3	Rhonda @ Point West	#22	1
109	M-5.3	Gillette @ Rhonda	#3, 31	2
110	M-.4	Spatz	#15	1

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 6 of 32

Line #	Plat #	Address	Valve #	Number of Valves
111	M-4.4	Bradley @ Lasswell	Fire Hydrant G	1
112	M-4.3	Palo Alto @ Gillette	#12, 30	2
113	M-4.3	1759 Palo Alto	#1	1
114	M-4.2	Hunter @ Hwy 344	Fire Hydrant E	1
115	M-4.2	Fairmeadows @ Palo Alto	Fire Hydrant B	1
116	M-4.2	Service 28494 @ Palo Alto	Service Valve	1
117	M-4.2	Service 291794 @ Palo Alto	Service Valve	1
118	M-4.1	3403 Normangee	#18	1
119	M-4.1	8902 Raywood	#19	1
120	M-4.1	3224 Pine Hollow	#12	1
121	M-3.2	8923 Oletha	#7	1
122	M-3.2	8703 Oletha	#21	1
123	M-3.2	8703 Palm Bluff	#20	1
124	M-3.2	3500 Palm Bluff	#22	1
125	M-3.4	3770 Remigio	Fire Hydrant B	1
126	L-10.1	8107 S. Flores	#7	1
127	L-9.4	E. Petaluma @ Bascum	#9	1
128	L-9.3	Bascum	#5	1
129	L-8.4	Proctor @ Garnett	#5	1
130	L-8.4	211 Hopkins	#1	1
131	L-8.4	Hopkins @ Garnett	#4	1
132	L-8.4	W. Petaluma @ Garnett	#9	1

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 7 of 32

Line #	Plat #	Address	Valve #	Number of Valves
133	L-8.4	W. Petaluma @ Clamp	#8, 14	2
134	L-8.3	W. Petaluma	#5	1
135	L-8.2	W. Amber @ Pleasanton	Fire Hydrant I	1
136	L-8.1	W. Hutchins @ Clamp	#4	1
137	L-8.1	W. Hutchins @ Oppenheimer	#5, 13	2
138	L-8.1	Malcolm @ W. Formosa	#9	1
139	L-7.4	8327 Cougar	#14	1
140	L-7.4	8327 Charger	#15	1
141	L-7.4	1511 Escalon	#18	1
142	L-7.3	618 Pike Ridge	#12	1
143	L-7.3	W. Petaluma @ Ludtke	#7	1
144	L-7.1	Tacoma @ W. Hutchins	#5	1
145	L-7.1	W. Hutchins @ Escalon	#7	1
146	L-7.1	W. Formosa @ Cougar	#33, 26	2
147	L-7.1	W. Formosa @ Escalon	#12	1
148	L-6.2	W. Amber @ Hilton	#2	1
149	L-6.2	1313 Ackard	#15	1
150	L-6.1	Gaddis @ Crenshaw	#10	1
151	L-5.2	Parnell @ Marek	#2	1
152	L-5.1	Misty Springs @ Barlite	#5	1
153	L-5.1	Misty Springs @ Niagara	#3, 4	2
154	L-5.1	W. Hutchins @ IH 35	Fire Hydrant D, C	2

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 8 of 32

Line #	Plat #	Address	Valve #	Number of Valves
155	L-5.1	Barlite @ IH 35	#6	1
156	L-4.4	St. Claire @ IH 35	#7	1
157	L-4.2	Caddo @ Palo Alto	#18	1
158	L-4.2	Palo Alto @ Hwy 16	#14, 5 H	3
159	L-4.2	Hwy 16	Fire Hydrant G	1
160	L-4.2	IH 35	#8	1
161	L-4.1	Mohawk @ Somerset	#32	1
162	L-4.1	Somerset @ Caddo	Fire Hydrant F	1
163	L-4.1	Ute St. @ IH 35	#12	1
164	L-3.3	St. Claire @ Somerset	Fire Hydrant D	1
165	L-2.4	U.S. Hwy 81 @ Plumnear	#3	1
166	L-2.2	U.S. Hwy 81	Fire Hydrant C	1
167	L-2.1	Quintana Rd.	#2, 1	2
168	K-10.4	Genevieve @ Curtis	#3	1
169	K-10.1	U.S. Hwy 281 @ Harding	#12, 10, 10 A	3
170	K-9.3	550 Ware	Fire Hydrant B	1
171	K-9.3	610 Ware	#14	1
172	K-9.3	718 Ware	Fire Hydrant A	1
173	K-9.3	Genevieve @ S. Flores	#23	1
174	K-9.3	7005 S. Flores	#9	1
175	K-9.2	104 Lorita	#3	1
176	K-9.1	206 W. Harding	#14	1

APPENDIX I
Edwards Underground Water District
Valves/Unable to Locate
1992

System: Bexar Metropolitan Water District

Page 9 of 32

<u>Line #</u>	<u>Plat #</u>	<u>Address</u>	<u>Valve #</u>	<u>Number of Valves</u>
177	K-9.1	Briar @ Sussex	#10	1
178	K-8.4	Mango @ W. Vestal	#26	1
179	K-8.4	Mango North of Aaron	#1	1
180	K-8.4	Clamp @ Cantrell	#2	1
181	K-8.4	W. Vestal @ Garnett	#25	1
182	K-8.3	Cantrell @ Pleasanton	#9	1
183	K-8.2	Loleta @ Shrine	#11	1
184	K-8.1	738 W. Harding	Fire Hydrant N	1
185	K-8.1	702 W. Harding	#20	1
186	K-7.4	Drury @ Escalon	#11	1
187	K-7.4	Tacoma @ W. Vestal	#28, 30	2
188	K-7.3	707 Aaron	#5	1
189	K-7.3	Altura @ Aaron	#8	1
190	K-7.3	Drury @ Commercial	#19	1
191	K-7.3	Burton	#3	1
192	K-7.3	W. Vestal @ Commercial	#11	1
193	K-7.2	1203 W. Harding	#7	1
194	K-7.2	1103 W. Harding	#35, L	2
195	K-7.2	934 W. Harding	Fire Hydrant P	1
196	K-7.2	635 Clovis	#32	1
197	K-7.2	538 Clovis	#33	1
198	K-7.1	330 Nock Ave	#24	1

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 16 of 32

Line #	Plat #	Address	Valve #	Number of Valves
328	I-8.1	W. Southcross @ Tupper	#19	1
329	I-8.1	W. Southcross @ Tobar	#3	1
330	I-7.4	Linda @ Shelby	#4	1
331	I-7.4	Buffalo @ Gerald	#19	1
332	I-7.3	Noble @ W. Pyron	#12	1
333	I-7.3	Noble @ Rosebud	#14	1
334	I-7.2	Bodie @ Canavan	#5	1
335	I-7.2	W. Southcross @ Noble	#10	1
336	I-7.1	Bauer @ Brunswick	Fire Hydrant B	1
337	I-7.1	W. Southcross between Buffalo and Adolfo	#16	1
338	I-7.1	Macdona @ IH 35	#20	1
339	I-6.4	Linder @ Zarzamora	Fire Hydrant K	1
340	I-6.4	Gerald @ Zarzamora	#6	1
341	I-6.4	Packard @ Whitman	?	1
342	I-6.4	Vickers @ Zarzamora	#4	1
343	J-6.3	Huron @ Gerald	#4	1
344	J-6.3	Gerald @ Oconee	Fire Hydrant B	1
345	J-6.3	Wagner @ Oconee	#6	1
346	I-6.2	Brunswick @ Lenard	#16	1
347	I-6.2	Berlina @ Lenard	20	1
348	I-6.2	Lenard Service # 31384	Service Valve	1

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 17 of 32

Line #	Plat #	Address	Valve #	Number of Valves
349	I-6.1	Milvid @ Votaw	#36	1
350	I-6.1	Berlin @ Zarzamora	#15	1
351	I-6.1	Pump Station #5 "	#42	1
352	I-5.4	New Laredo Hwy @ Gerald	#16, 4	2
353	I-5.4	Rankin @ Kings Ave.	#7	1
354	I-5.3	Gerald @ Mallard	#7, 11	2
355	I-5.3	Vickers @ Votaw	#8	1
356	I-5.2	Somerset @ R. R. Tracks	#10	1
357	I-5.2	Votaw @ Berlin	#48	1
358	I-5.2	2203 W. Southcross	#29	1
359	I-5.2	U.S. Hwy 81 @ Fay	#22	1
360	I-5.1	200 Block of Fay	#16	1
361	I-5.1	2337 W. Southcross	Service Valve #10	1
362	I-5.1	Southcross @ U.S. Hwy 81	#6	1
363	I-5.1	U.S. Hwy 81 @ 30' Esmt	#4	1
364	I-5.1	2239 W. Southcross	Fire Hydrant B	1
365	I-4.4	Between Wilcox & Gerald @ Crittendon	#12, 14	2
366	I-4.4	Gerald @ Spindle	#42	1
367	I-4.4	Gerald @ Crittendon	#28	1
368	I-4.4	Quintana @ Bynum	#4	1
369	I-4.4	Lovetta @ Bynum	#65	1

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 18 of 32

Line #	Plat #	Address	Valve #	Number of Valves
370	I-4.4	Between Lovetta and Peabody @ Bynum	#2	1
371	I-4.4	Peabody @ Bynum	#58	1
372	I-4.4	Between Peabody and King Ave @ Bynum	#18	1
373	I-4.4	" " " @ Lindeman	#15	1
374	I-4.4	" " " @ Crittendon	#57	1
375	I-4.4	Kings Ave @ Lindeman	#74	1
376	I-4.4	Between King & W. Mayfield @ Bynum	#124	1
377	I-4.4	W. Mayfield @ Bynum	#3	1
378	I-4.4	Between Wilcox and Gerald @ Creighton	#37, 38	2
379	I-4.3	" " " @ Pierian	#51	1
380	I-4.3	Creighton @ Gerald	#39	1
381	I-4.3	Between Gerald and Lovett @ Clarenden	#42, 43	2
382	I-4.3	Lovett @ Clarenden	#45	1
383	I-4.3	530 Lovett	#24	1
384	I-4.3	Lovett @ Oregon	#34, 35	2
385	I-4.3	Peabody @ Clarenden	#46	1
386	I-4.3	432 Peabody	#18	1
387	I-4.3	Between Peabody and King @ Clarenden	#30	1
388	I-4.3	Kings Ave. @ Fleming	#9, 15	2

APPENDIX I
Edwards Underground Water District
Valves/Unable to Locate
1992

System: Bexar Metropolitan Water District

Page 19 of 32

Line #	Plat #	Address	Valve #	Number of Valves
389	I-4.3	U.S. Hwy 81 @ Fleming	#16, 17	2
390	I-4.3	Lovett @ Fleming	#13	1
391	I-4.3	U.S. Hwy 81 @ Lovett	#21	1
392	I-4.2	Baker @ Creighton	#16	1
393	I-4.2	Between Fay and Hollenbeck	#23, 24	2
394	I-4.2	Hollenbeck @ Creighton	#17	1
395	I-4.2	Between W. Southcross and Wilcox @ Creighton	#6,30	2
396	I-4.2	2492 W. Southcross	Service Valve #12	1
397	I-4.1	Between Baker and Fay @ Quintana	#32	1
398	I-4.1	" " @ Crittenden	#2	1
399	I-4.1	Northwest of Southcross and Quintana	#38, 37	2
400	I-4.1	W. Southcross @ Quintana	#7, 28, 39	3
401	I-4.1	Between W. Southcross and Wilcox @ Crittenden	#30	1
402	I-3.3	3223 Gerald	#2, 8	1
403	I-3.3	Between Peabody and Lovett @ Quintana	#14	1
404	I-3.3	Kings Ave @ Quintana	#12	1
405	I-3.3	W. Mayfield @ Quintana	#26	1
406	I-3.3	W. Mayfield @ Holder	#22, Fire Hydrant F	2
407	I-3.3	Prospect @ Quintana	#23	1

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 20 of 32

Line #	Plat #	Address	Valve #	Number of Valves
408	H-7.4	102 Elks	#28, 47	2
409	H-7.4	Ferndale @ Stonewall	#48	1
410	H-7.3	842 Brighton	#6	1
411	H-7.3	Flanders @ Commercial	#10	1
412	H-7.3	Flanders @ IH 35	#19	1
413	H-7.3	Stonewall School on Commercial	#34	1
414	H-6.4	Harlon @ Packard	#36, 53, F.H. R	3
415	H-6.3	Stonewall @ Lenard	#45, 46	2
416	H-6.1	Division @ Nogalitos	#3	1
417	H-6.1	Ames @ Nogalitos	#5, 9, 13	3
418	H-6.1	Centennial @ Zarzamora	#19	1
419	H-5.3	San Antonio Shoe Factory	#4	1
420	H-5.3	San Antonio Shoe Factory	#7 Service Valve	1
421	H-5.3	Miller Curtis Factory Plant #3	#12, 13	2
422	H-5.3	New Laredo Hwy Southwest of Humbolt	Fire Hydrant C	1
423	H-5.3	Humbolt Service # 8893-92-91	Service Valve #1	1
424	H-5.3	Somerset @ Harlan	#2	1
425	H-4.4	Between Baker and Tampa on Crittenden	#1, 2	2
426	H-4.3	Quintana @ Griffin	#11, Fire Hydrant C	2
427	H-4.3	1415 Quintana	#4	1

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 21 of 32

Line #	Plat #	Address	Valve #	Number of Valves
428	H-4.3	Palestine @ Quintana	#12	1
429	H-4.3	Dacus @ Creighton	#16, F.H. F	2
430	H-4.2	1123 Quintana	Service Valve	1
431	H-4.2	1221 Quintana	Service Valve	1
432	G-4.4	Frio City Road near Croyden	#1	1
433	G-4.2	Cupples Rd.	#7	1
434	G-4.2	Quintana Rd.	#9	1
435	F-6.1	Carolyn between Barrett and Thompson	#19	1
436	F-6.1	Carolyn @ Thompson	#15, 16, 17	3
437	F-6.1	Frio City Road @ F.H. B	#14	1
438	F-5.4	Behind 203 Pletz	#3	1
439	F-5.4	Behind 155 W. Emerson	#4	1
440	F-5.4	Behind 139 Greenway	#8	1
441	F-5.4	Behind 203 W. Jewel	#6, 7	2
442	F-5.4	2701 Roselawn	#11	1
443	F-5.3	Frio City Rd. @ Industrial	#12, 13	2
444	F-5.3	2103 Frio City Road	#1, 2	2
445	F-5.3	Jupiter @ Frio City Rd.	#3	1
446	F-5.3	Jupiter @ Saturn	#4	1
447	F-5.3	Jupiter @ Venus	#11	1
448	F-5.2	W. Kirk @ Niemeyer	#1, 2, 3, 13	4

APPENDIX I
Edwards Underground Water District
Valves/Unable to Locate
1992

System: Bexar Metropolitan Water District

Page 22 of 32

<u>Line #</u>	<u>Plat #</u>	<u>Address</u>	<u>Valve #</u>	<u>Number of Valves</u>
449	F-5.2	Niemeyer between Barrett @ W. Thompson	#5, 6	2
450	F.5.2	Venus @ W. Thompson	#10	1
451	F-5.1	2330 S.W. 21st. St.	#14	1
452	F-5.1	Behind 1334 W. Thompson	#11	1
453	F-4.4	106 Ballard	#12	1
454	F-4.4	Roselawn @ Marlow	#8, 9	2
455	F-4.2	Thompson @ S.W. 28th St.	#2, 3	2
456	F-4.3	Thompson @ S.W. 27th St.	#20, 21	2
457	F-4.1	Thompson @ Gen. McMullen	#1, 2, F.H. A	3
458	F-4.1	1900 Block of Gen. McMullen Service 21525	Service Valve	1
459	F-3.2	Dexter @ Imperial	#1	1
460	E-5.4	Darby @ Barley	#11	1
461	E-5.4	1247 W. Kirk	Service Valve	1
462	E-5.3	W. Kirk @ S.P. Tracks	#5	1
463	E-5.1	725 Cupples	Fire Hydrant D	1
464	E-5.1	734 Cupples	#21	1
465	E-4.4	Hatton @ Aiker	#11	1
466	E-4.4	Weir, service valve to 1770 Gen. McMullen	Service Valve	1
467	E-4.4	1820 Gen. McMullen	Fire Hydrant J	1

APPENDIX I
Edwards Underground Water District
Valves/Unable to Locate
1992

System: Bexar Metropolitan Water District

Page 23 of 32

Line #	Plat #	Address	Valve #	Number of Valves
468	E-4.4	Gen. McMullen @ Darby	#8	1
469	E-4.4	Gen. McMullen @ Menefee	#18	1
470	E-4.4	3322 Weir Ave.	Service Valve #22	1
471	E-4.3	Hatton @ Blocker	#26	1
472	E-4.3	Lacora Ashly	#24	1
473	E-4.3	Leslie Nicole @ Michael Brian	#22	1
474	E-4.3	Weir to Jardine	#20	1
475	E-4.3	141 Andy Dr.	#18	1
476	E-4.1	Behind 2403 Aiken @ Menefee	#5, 12	2
477	E-4.1	Aiken @ Menefee	#13	1
478	E-3.4	End of Beech	#14	1
479	E-3.3	3700 Beech	#2	1
480	E-3.2	Menefee @ Wescott	#3	1
481	D-5.4	514 Cupples	Service Valve	1
482	D-5.4	636 Cupples	Service Valve	1
483	D-5.1	318 Cupples	#13, 16	2
484	D-4.4	Brady @ Patton	#27	1
485	D-4.4	Patton @ Gen. McMullen	#9, 35	2
486	D-4.4	139 Arteago	#15	1
487	D-4.3	3018 Cumbre	#18	1
488	D-4.3	2922 Cumbre	#19	1

APPENDIX I

Edwards Underground Water District Valves/Unable to Locate 1992

System: Bexar Metropolitan Water District

Page 32 of 32

<u>Line #</u>	<u>Plat #</u>	<u>Address</u>	<u>Valve #</u>	<u>Number of Valves</u>
655	CG-3	111 Parade	#55 Service Valve	1
656	CG-3	107 Parade	#54 Service Valve	1
657	CG-3	101 Parade	#53 Service Valve	1
658	CH-3	Blanco Rd. between Oblate Dr. and Jackson Keller	#5	1
659	CH-3	139 Danube	#2 Service Valve	1
660	CH-3	141 Danube	#3 Danube	1

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 1 of 58

*Service Number

Line #	Plat #	Address	Reason
1	S-94	14625 Pleasanton Rd.	Unable to locate
2	S-7.1	1302 Mauermann Rd.	"
3	R-10.2	30617*	"
4	P-8.2	27345* Pleasanton Rd.	"
5	P-4.1	26930* Durette	"
6	P-4.1	26929* Durette	"
7	P-4.1	26928* Durette	"
8	P-4.1	26921* Durette	"
9	P-4.1	26915* Durette	"
10	P-4.1	26914* Durette	"
11	P-4.1	26913* Durette	"
12	P-4.1	28912* Durette	"
13	P-4.1	10814 Gaylord	"
14	P-4.1	10810 Gaylord	"
15	P-4.1	10806 Gaylord	"
16	P-4.1	10802 Gaylord	"
17	P-4.1	10718 Gaylord	"
18	P-4.1	10714 Gaylord	"
19	P-4.1	10710 Gaylord	"
20	P-4.1	10706 Gaylord	"
21	P-4.1	10702 Gaylord	"
22	P-4.1	26945* Gaylord	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 2 of 58

*Service Number

Line #	Plat #	Address	Reason
23	P-4.1	26946* Gaylord	Unable to locate
24	P-4.1	26947* Gaylord	"
25	P-4.1	26909* Bay Hurst	"
26	P-4.1	26910* Bay Hurst	"
27	P-4.1	26852* Valley Star	"
28	P-4.1	26851* Valley Star	"
29	P-4.1	26849* Valley Star	"
30	O-11.4	1527 Estancia	"
31	O-11.4	17129* Estancia	"
32	O-11.4	1507 Socorro	"
33	O-11.4	1506 Socorro	"
34	O-11.4	1703 Socorro	"
35	O-11.4	1707 Socorro	"
36	O-10.2	1139 Sanez	"
37	O-10.2	1235 Sanez	"
38	O-10.2	1130 Sanez	"
39	O-10.2	1214 Sanez	"
40	O-10.2	1218 Sanez	"
41	O-10.2	9901 U.S. Hwy 281	"
42	O-10.2	9907 U.S. Hwy 281	"
43	O-10.2	10107 U.S. Hwy 281	"
44	O-10.2	10114 U.S. Hwy 281	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 3 of 58

*Service Number

Line #	Plat #	Address	Reason
45	O-10.2	10014 U.S. Hwy 281	Unable to locate
46	O-10.2	16021* U.S. Hwy 281	"
47	O-10.2	5516 U.S. Hwy 281	"
48	O-10.2	1315 San Casimiro	"
49	O-10.3	1415 San Acacia	"
50	O-8.2	10111 Moursund	"
51	O-4.3	26537* State Hwy 16	"
52	O-4.3	10357 State Hwy 16	"
53	O-4.3	10350 State Hwy 16	"
54	O-4.2	21676* State Hwy 16	"
55	O-4.2	19719 State Hwy 16	"
56	N-11.4	1630 Chavaneaux	"
57	N-11.4	1634 Chavaneaux	"
58	N-11.4	1726 Chavaneaux	"
59	N-10.3	19835* U.S. Hwy 281	"
60	N-10.3	5431 U.S. Hwy 281	"
61	N-10.3	1346 Chavaneaux	"
62	N-10.3	1430 Chavaneaux	"
63	N-10.2	5139 U.S. 281	"
64	N-10.2	5141 U.S. 281	"
65	N-10.2	5135 U.S. 281	"
66	N-9.3	805 Chavaneaux	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 4 of 58

*Service Number

Line #	Plat #	Address	Reason
67	N-9.3	Next to 806 Chavaneaux	Unable to locate
68	N-9.1	435 Wimberly	Locked Gate
69	N-9.1	423 E. Mally	Unable to locate
70	N-9.1	427 E. Mally	"
71	N-8.3	126 Buchanan Blvd.	"
72	N-8.2	101 E. Villaret Blvd.	"
73	N-8.2	4247 Pleasanton Rd.	Unable to locate
74	N-8.2	4251 Pleasanton Rd.	"
75	N-8.1	234 Mally	"
76	N-8.1	218 Mally	"
77	N-8.1	9710 Clamp	"
78	N-7.3	610 Buchanan	"
79	N-7.3	606 Buchanan	"
80	N-7.3	602 Buchanan	"
81	N-7.3	4444 Commercial	"
82	N-7.3	4445 Commercial	"
83	N-7.2	802 Mally	"
84	N-7.1	29618* Earth	"
85	N-7.1	27501* Earth	"
86	N-7.1	27503* Earth	"
87	N-7.1	27502* Earth	"
88	N-7.1	731 W. Villaret	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 5 of 58

*Service Number

Line #	Plat #	Address	Reason
89	N-6.4	27795* Veronica	Unable to locate
90	N-6.4	27794 Veronica	"
91	N-6.4	27793 Veronica	"
92	N-6.4	27792 Veronica	"
93	N-6.4	27791 Veronica	"
94	N-6.2	1003 W. Villaret	"
95	N-6.2	9510 Strech	"
96	N-6.1	9339 Zarzamora	"
97	N-6.1	1603 Mally Ave.	"
98	N-6.1	1442 Mally Ave.	"
99	N-6.1	222 Cargo Blvd.	"
100	N-6.1	202 Cargo Blvd.	"
101	N-6.1	134 Cargo Blvd.	"
102	N-6.1	126 Cargo Blvd.	"
103	N-6.1	122 Cargo Blvd.	"
104	N-6.1	1027 W. Villaret	"
105	N-6.1	1131 W. Villaret	"
106	N-5.2	9411 Rhoda	"
107	N-5.2	9343 Rhoda	Dog
108	N-5.2	9339 Oden	Locked Gate
109	N-5.1	1570 W. Villaret	Unable to locate
110	N-5.1	1560 W. Villaret	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 6 of 58

*Service Number

Line #	Plat #	Address	Reason
111	N-5.1	1536 W. Villaret	Unable to locate
112	N-5.1	1530 W. Villaret	"
113	N-4.4	3367 Aragon	"
114	N-4.4	3359 Aragon	"
115	N-4.4	3355 Aragon	Unable to locate
116	N-4.4	3351 Aragon	"
117	N-4.4	3347 Aragon	"
118	N-4.4	3343 Aragon	"
119	N-4.4	3339 Aragon	"
120	N-4.4	3358 Aragon	"
121	N-4.4	3354 Aragon	"
122	N-4.4	3350 Aragon	"
123	N-4.4	3346 Aragon	"
124	N-4.4	3342 Aragon	"
125	N-4.4	3338 Aragon	"
126	N-4.4	3331 Twining	"
127	N-4.4	3327 Twining	"
128	N-4.4	3319 Twining	"
129	N-4.4	3315 Twining	"
130	N-4.4	3322 Twining	"
131	N-4.4	3318 Twining	"
132	N-4.4	3314 Twining	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 7 of 58

*Service Number

Line #	Plat #	Address	Reason
133	N-4.4	3310 Twining	Unable to locate
134	N-4.4	3331 Reforma	"
135	N-4.4	3327 Reforma	"
136	N-4.4	3323 Reforma	"
137	N-4.4	3319 Reforma	"
138	N-4.4	3315 Reforma	"
139	N-4.4	3311 Reforma	"
140	N-4.4	3307 Reforma	"
141	N-4.4	3303 Reforma	"
142	N-4.4	3267 Reforma	"
143	N-4.4	3259 Reforma	"
144	N-4.4	3255 Reforma	"
145	N-4.4	3351 Reforma	"
146	N-4.4	3347 Reforma	"
147	N-4.4	3343 Reforma	"
148	N-4.4	3335 Reforma	"
149	N-4.4	3331 Reforma	"
150	N-4.4	3327 Reforma	"
151	N-4.4	3323 Reforma	"
152	N-4.4	3319 Reforma	"
153	N-4.4	3315 Reforma	"
154	N-4.4	3307 Reforma	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 8 of 58

*Service Number

Line #	Plat #	Address	Reason
155	N-4.4	3330 Reforma	Unable to locate
156	N-4.4	3326 Reforma	"
157	N-4.4	3318 Reforma	"
158	N-4.4	3314 Reforma	"
159	N-4.4	3310 Reforma	"
160	N-4.4	3306 Reforma	"
161	N-4.4	3302 Reforma	"
162	N-4.4	3268 Reforma	"
163	N-4.4	3264 Reforma	"
164	N-4.4	3260 Reforma	"
165	N-4.4	3252 Reforma	"
166	N-4.4	3248 Reforma	"
167	N-4.4	3244 Reforma	"
168	N-4.4	3240 Reforma	"
169	N-4.4	3327 Avoca Dr.	"
170	N-4.4	3323 Avoca Dr.	"
171	N-4.4	3319 Avoca Dr.	"
172	N-4.4	3315 Avoca Dr.	"
173	N-4.4	3311 Avoca Dr.	"
174	N-4.4	3307 Avoca Dr.	"
175	N-4.4	3303 Avoca Dr.	"
176	N-4.4	3239 Avoca Dr.	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 9 of 58

*Service Number

Line #	Plat #	Address	Reason
177	N-4.4	3235 Avoca Dr.	Unable to locate
178	N-4.4	3231 Avoca Dr.	"
179	N-4.4	3227 Avoca Dr.	"
180	N-4.4	3219 Avoca Dr.	"
181	N-4.4	3211 Avoca Dr.	"
182	N-4.4	3007 Avoca Dr.	"
183	N-4.4	3203 Avoca Dr.	"
184	N-4.4	3330 Avoca Dr.	"
185	N-4.4	3326 Avoca Dr.	"
186	N-4.4	3322 Avoca Dr.	"
187	N-4.4	3318 Avoca Dr.	"
188	N-4.4	3314 Avoca Dr.	"
189	N-4.4	3310 Avoca Dr.	"
190	N-4.4	3306 Avoca Dr.	"
191	N-4.4	3302 Avoca Dr.	"
192	N-4.4	3242 Avoca Dr.	"
193	N-4.4	3238 Avoca Dr.	"
194	N-4.4	3234 Avoca Dr.	"
195	N-4.4	3230 Avoca Dr.	"
196	N-4.4	3226 Avoca Dr.	"
197	N-4.4	3222 Avoca Dr.	"
198	N-4.4	3214 Avoca Dr.	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 10 of 58

*Service Number

Line #	Plat #	Address	Reason
199	N-4.4	3210 Avoca Dr.	Unable to locate
200	N-4.4	3206 Avoca Dr.	"
201	N-4.4	3202 Avoca Dr.	"
202	N-4.4	9622 Palo Court	"
203	N-4.4	9618 Palo Court	"
204	N-4.4	9614 Palo Court	"
205	N-4.4	9610 Palo Court	"
206	N-4.4	9606 Palo Court	"
207	N-4.4	28133* Celeste	"
208	N-4.4	28126* Celeste	"
209	N-4.3	2803 State Hwy 16	"
210	N-4.1	419 Ike	"
211	N-4.1	323 Ike	"
212	N-4.1	410 Tedder	"
213	N-4.1	351 Tedder	"
214	N-4.1	314 Tedder	"
215	N-4.1	259 Tedder	"
216	N-4.1	27387* Coconino	"
217	N-4.1	27386* Coconino	"
218	N-4.1	27385* Coconino	"
219	N-4.1	27384* Coconino	"
220	N-4.1	27381* Coconino	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 11 of 58

*Service Number

Line #	Plat #	Address	Reason
221	N-4.1	27428* Algo Dulce	Unable to locate
222	N-4.1	27426* Algo Dulce	"
223	N-4.1	27425* Algo Dulce	"
224	N-4.1	27424* Algo Dulce	"
225	N-4.1	27423* Algo Dulce	"
226	N-4.1	27422* Algo Dulce	"
227	N-4.1	26566* Algo Dulce	"
228	N-4.1	26567* Algo Dulce	"
229	N-4.1	26568* Algo Dulce	"
230	N-4.1	26569* Algo Dulce	"
231	N-4.1	26570* Algo Dulce	"
232	N-4.1	26571* Algo Dulce	"
233	N-3.3	3455 Aragon	"
234	N-3.3	3451 Aragon	"
235	N-3.3	3447 Aragon	"
236	N-3.3	3443 Aragon	"
237	N-3.3	3439 Aragon	"
238	N-3.3	3435 Aragon	"
239	N-3.3	3431 Aragon	"
240	N-3.3	3427 Aragon	"
241	N-3.1	3423 Aragon	"
242	N-3.1	3419 Aragon	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 12 of 58

*Service Number

Line #	Plat #	Address	Reason
243	N-3.1	3415 Aragon	Unable to locate
244	N-3.1	3411 Aragon	"
245	N-3.1	3407 Aragon	"
246	N-3.1	3403 Aragon	"
247	N-3.1	3454 Aragon	"
248	N-3.1	3450 Aragon	"
249	N-3.1	3446 Aragon	"
250	N-3.1	3442 Aragon	"
251	N-3.1	3426 Aragon	"
252	N-3.1	3422 Aragon	"
253	N-3.1	3418 Aragon	"
254	N-3.1	3414 Aragon	"
255	N-3.1	3410 Aragon	"
256	N-3.1	3406 Aragon	"
257	N-3.1	3362 Aragon	"
258	N-3.1	3451 Twining	"
259	N-3.1	3447 Twining	"
260	N-3.1	3443 Twining	"
261	N-3.1	3435 Twining	"
262	N-3.1	3431 Twining	"
263	N-3.1	3419 Twining	"
264	N-3.1	3411 Twining	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 13 of 58

*Service Number

Line #	Plat #	Address	Reason
265	N-3.1	3403 Twining	Unable to locate
266	N-3.1	3339 Twining	"
267	N-3.1	3335 Twining	"
268	N-3.1	3454 Twining	"
269	N-3.1	3450 Twining	"
270	N-3.1	3446 Twining	"
271	N-3.1	3442 Twining	"
272	N-3.1	3438 Twining	"
273	N-3.1	3426 Twining	"
274	N-3.1	3422 Twining	"
275	N-3.1	3418 Twining	"
276	N-3.1	3406 Twining	"
277	N-3.1	3402 Twining	"
278	N-3.1	3338 Twining	"
279	N-3.1	3342 Twining	"
280	N-3.1	3455 Reforma	"
281	N-3.1	3451 Reforma	"
282	N-3.1	3447 Reforma	"
283	N-3.1	3443 Reforma	"
284	N-3.1	3439 Reforma	"
285	N-3.1	3435 Reforma	"
286	N-3.1	3431 Reforma	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 14 of 58

*Service Number

Line #	Plat #	Address	Reason
287	N-3.1	3427 Reforma	Unable to locate
288	N-3.1	3423 Reforma	"
289	N-3.1	3419 Reforma	"
290	N-3.1	3415 Reforma	"
291	N-3.1	3411 Reforma	"
292	N-3.1	3407 Reforma	"
293	N-3.1	3403 Reforma	"
294	N-3.1	3343 Reforma	"
295	N-3.1	3339 Reforma	"
296	N-3.1	3454 Reforma	"
297	N-3.1	3450 Reforma	"
298	N-3.1	3446 Reforma	"
299	N-3.1	3442 Reforma	"
300	N-3.1	3438 Reforma	"
301	N-3.1	3434 Reforma	"
302	N-3.1	3430 Reforma	"
303	N-3.1	3422 Reforma	"
304	N-3.1	3414 Reforma	"
305	N-3.1	3410 Reforma	"
306	N-3.1	3406 Reforma	"
307	N-3.1	3402 Reforma	"
308	N-3.1	3342 Reforma	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

Page 15 of 58

System: Bexar Metropolitan Water District

*Service Number

Line #	Plat #	Address	Reason
			Unable to locate
309	N-3.1	3338 Reforma	"
310	N-3.1	3334 Reforma	"
311	N-3.1	3330 Reforma	"
312	N-3.1	3455 Avoca Dr.	"
313	N-3.1	3451 Avoca Dr.	"
314	N-3.1	3447 Avoca Dr.	"
315	N-3.1	3443 Avoca Dr.	"
316	N-3.1	3439 Avoca Dr.	"
317	N-3.1	3435 Avoca Dr.	"
318	N-3.1	3431 Avoca Dr.	"
319	N-3.1	3427 Avoca Dr.	"
320	N-3.1	3423 Avoca Dr.	"
321	N-3.1	3419 Avoca Dr.	"
322	N-3.1	3415 Avoca Dr.	"
323	N-3.1	3411 Avoca Dr.	"
324	N-3.1	3407 Avoca Dr.	"
325	N-3.1	3403 Avoca Dr.	"
326	N-3.1	3343 Avoca Dr.	"
327	N-3.1	3339 Avoca Dr.	"
328	N-3.1	3335 Avoca Dr.	"
329	N-3.1	3331 Avoca Dr.	"
330	N-3.1	3454 Avoca Dr.	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

Page 16 of 58

System: Bexar Metropolitan Water District

*Service Number

Line #	Plat #	Address	Reason
331	N-3.1	3450 Avoca	Unable to locate
332	N-3.1	3446 Avoca	"
333	N-3.1	3442 Avoca	"
334	N-3.1	3438 Avoca	"
335	N-3.1	3434 Avoca	"
336	N-3.1	3430 Avoca	"
337	N-3.1	3426 Avoca	"
338	N-3.1	3422 Avoca	"
339	N-3.1	3418 Avoca	"
340	N-3.1	3414 Avoca	"
341	N-3.1	3410 Avoca	"
342	N-3.1	3406 Avoca	"
343	N-3.1	3402 Avoca	"
344	N-3.1	3342 Avoca	"
345	N-3.1	3338 Avoca	"
346	N-3.1	3334 Avoca	"
347	N-3.1	9647 Maria Isabel	"
348	N-3.1	9643 Maria Isabel	"
349	N-3.1	9639 Maria Isabel	"
350	N-3.1	9635 Maria Isabel	"
351	N-3.1	9631 Maria Isabel	"
352	N-3.1	9627 Maria Isabel	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

Page 17 of 58

System: Bexar Metropolitan Water District

*Service Number

Line #	Plat #	Address	Reason
353	N-3.1	9623 Maria Isabel	Unable to locate
354	N-3.1	9615 Maria Isabel	"
355	N-3.1	9611 Maria Isabel	"
356	N-3.1	9607 Maria Isabel	"
357	N-3.1	9603 Maria Isabel	"
358	N-3.2	442 Ike	"
359	N-3.2	27400* Coconino	"
360	N-3.2	27399 Coconino	"
361	N-3.2	27398* Coconino	"
362	N-3.2	27397* Coconino	"
363	N-3.2	27396* Coconino	"
364	N-3.2	27395* Coconino	"
365	N-3.2	27394* Coconino	"
366	N-3.2	27393* Coconino	"
367	N-3.2	27392* Coconino	"
368	N-3.2	27391* Coconino	"
369	N-3.2	27390* Coconino	"
370	N-3.2	27389* Coconino	"
371	N-3.2	27388* Coconino	"
372	N-3.2	27440* Algo Dulce	"
373	N-3.2	27439* Algo Dulce	"
374	N-3.2	27438* Algo Dulce	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

Page 18 of 58

System: Bexar Metropolitan Water District

*Service Number

Line #	Plat #	Address	Reason
375	N-3.2	27437* Algo Dulce	Unable to locate
376	N-3.2	27436* Algo Dulce	"
377	N-3.2	27435* Algo Dulce	"
378	N-3.2	27434* Algo Dulce	"
379	N-3.2	27433* Algo Dulce	"
380	N-3.2	27432* Algo Dulce	"
381	N-3.2	27431* Algo Dulce	"
382	N-3.2	27430* Algo Dulce	"
383	N-3.2	37429* Algo Dulce	"
384	N-3.2	3306 Algo Dulce	"
385	N-3.2	3334 Algo Dulce	"
386	M-10.4	906 Sams Dr.	"
387	M-10.4	910 Sams Dr.	"
388	M-10.4	1002 Sams Dr.	"
389	M-10.4	1034 Sams Dr.	"
390	M-10.4	1038 Sams Dr.	"
391	M-10.4	4907 U.S. 281	"
392	M-10.1	12861* Troy	"
393	M-10.1	12633* Troy	"
394	M-10.1	12661* Troy	"
395	M-10.4	8839 Troy	"
396	M-10.1	903 Ashley	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 19 of 58

*Service Number

Line #	Plat #	Address	Reason
397	M-10.1	907 Ashley	Unable to locate
398	M-10.1	830 Ashley	"
399	M-9.4	9034 Yett	"
400	M-9.4	258 Baetz	"
401	M-9.2	550 Ansley	"
402	M-9.2	626 Emmett	"
403	M-9.2	750 Ashley	"
404	M-9.2	803 Ashley	"
405	M-9.1	528 Emmett	"
406	M-9.1	534 Barberry	"
407	M-8.3	259 Moursund	"
408	M-8.2	12391* Dorsey Ave.	"
409	M-8.2	215 Ansley	"
410	M-8.2	Pleasanton @ Ansley	"
411	M-8.1	131 Dorsey	Locked Gate
412	M-8.1	307 Dorsey	Unable to Locate
413	M-8.1	241 Dorsey	"
414	M-8.1	239 Dorsey	"
415	M-8.1	Between 207 and 205 Ansley	"
416	M-8.1	226 Dorsey	"
417	M-8.1	186 Dorsey	"
418	M-7.4	1122 Baetz	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 20 of 58

*Service Number

Line #	Plat #	Address	Reason
419	M-7.4	722 Rockwell	Unable to locate
420	M-7.4	771 Gillette	"
421	M-7.4	767 Gillette	"
422	M-7.4	770 Gillette	"
423	M-7.4	766 Gillette	"
424	M-7.2	2551 Commercial	"
425	M-7.2	389 Ansley Blvd.	"
426	M-7.2	8727 Ludtke	"
427	M-7.1	5847* Escalon	"
428	M-6.2	1410 Beverly Ann	Locked gates
429	M-5.4	Lift Station on Gillette	Unable to locate
430	M-5.3	1902 Hunter Blvd.	"
431	M-5.3	1903 Edenvale	"
432	M-5.3	2636* Gillette	"
433	M-5.3	28194* Lytle	"
434	M-5.1	2527 Big John	"
435	M-5.1	2523 Big John	"
436	M-5.1	2507 Big John	"
437	M-5.1	2503 Big John	"
438	M-5.1	2606 Big John	"
439	M-5.1	2602 Big John	"
440	M-5.1	2507 Tortuga	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 21 of 58

*Service Number

Line #	Plat #	Address	Reason
441	M-5.1	9010 Perma	Unable to locate
442	M-4.4	258 Wainwright	"
443	M-4.4	366 Spaatz	"
444	M-4.4	339 Doolittle	"
445	M-4.4	335 McNarney	"
446	M-4.4	263 McNarney	"
447	M-4.4	410 McNarney	"
448	M-4.4	406 Bradley	"
449	M-4.3	210 Wainwright	"
450	M-4.3	214 Spaatz	"
451	M-4.1	24705* Fair Meadow	"
452	M-4.1	3039 Pine Hollow	"
453	M-4.1	3039 Goose Creek	"
454	M-3.3	436 Bradley	"
455	L-10.4	931 Dodic	"
456	L-9.4	2965* E. Petaluma	"
457	L-9.4	358 E. Petaluma	"
458	L-9.4	237 E. Petaluma	Locked gates
459	L-9.4	363 E. Petaluma	"
460	L-9.4	373 E. Petaluma	"
461	L-9.3	803 Saipan Pl.	"
462	L-9.3	815 Saipan Pl.	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 22 of 58

*Service Number

Line #	Plat #	Address	Reason
463	L-9.3	819 Saipan Pl.	Locked gates
464	L-9.3	603 E. Petaluma	"
465	L-9.2	614 E. Formosa	"
466	L-9.2	555 E. Amber Pl.	"
467	L-9.2	615 E. Amber Pl.	"
468	L-9.2	490 E. Amber Pl.	"
469	L-9.1	170 Langford	Unable to locate
470	L-9.1	218 Creath	"
471	L-9.1	307 E. Formosa	"
472	L-9.1	362 E. Formosa	"
473	L-9.1	366 E. Formosa	"
474	L-9.1	402 E. Formosa	"
475	L-8.4	126 Hopkins	"
476	L-8.4	139 Hopkins	"
477	L-8.4	1858 Clamp	"
478	L-8.4	210 W. Petaluma	"
479	L-8.4	201 W. Petaluma	"
480	L-8.4	275 W. Petaluma	"
481	L-8.4	251 W. Petaluma	Under car
482	L-8.3	236 E. Petaluma	Unable to locate
483	L-8.3	240 E. Petaluma	"
484	L-8.2	106 Ackard	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 23 of 58

*Service Number

Line #	Plat #	Address	Reason
485	L-8.2	110 Ackard	Unable to locate
486	L-8.2	114 Ackard	"
487	L-8.2	207 E. Amber	"
488	L-8.2	1814 Clamp	"
489	L-8.1	202 W. Hutchins	"
490	L-8.1	339 W. Hutchins	"
491	L-8.1	334 Leff Pl.	"
492	L-8.1	438 W. Formosa	"
493	L-8.1	434 W. Formosa	"
494	L-8.1	303 W. Formosa	"
495	L-7.4	1514 Logwood	"
496	L-7.4	1518 Logwood	"
497	L-7.4	619 W. Petaluma	"
498	L-7.4	1550 Logwood	"
499	L-7.3	3540 Commercial	"
500	L-7.3	8506 Honora	"
501	L-7.3	8723 Ludtke	"
502	L-7.3	8507 Ludtke	"
503	L-7.3	611 Pike Ridge	"
504	L-7.1	835 Amber	"
505	L-7.1	1038 W. Hutchins	"
506	L-7.1	938 W. Hutchins	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 24 of 58

*Service Number

Line #	Plat #	Address	Reason
507	L-7.1	1322 Logwood	Unable to locate
508	L-7.1	1007 W. Formosa	"
509	L-6.3	8703 Wilma Jean	Locked gate
510	L-6.3	8618 Wilma Jean	"
511	L-6.3	8439 Wilma Jean	Unable to locate
512	L-6.3	8434 Wilma Jean	"
513	L-6.2	1406 W. Hutchins	"
514	L-6.2	1302 W. Hutchins	"
515	L-6.1	1426 Rodrick	"
516	L-6.1	1703 Gaddis	"
517	L-5.4	2503 Viejita	"
518	L-5.2	15739* Gaddis	"
519	L-4.2	142 Iroquois	Dog
520	L-4.2	172 Caddo	Unable to locate
521	L-4.2	719 State Hwy 16	"
522	L-4.1	179 Mohawk	"
523	L-4.1	178 Mohawk	"
524	L-4.1	202 Caddo	"
525	L-3.3	14642* St. Claire	"
526	L-3.3	29956* St. Claire	"
527	L-3.3	29957* St. Claire	"
528	L-7.1	1126 W. Hutchins	Locked gates

APPENDIX J
Edwards Underground Water District
Services/Unable to Survey
1992

System: Bexar Metropolitan Water District

Page 25 of 58

*Service Number

Line #	Plat #	Address	Reason
529	K-9.4	536 Ware	Locked gates
530	K-9.4	531 Ware	"
531	K-9.4	270 E. Vestal	Unable to locate
532	K-9.4	411 E. Vestal	"
533	K-9.4	363 E. Hutchins	"
534	K-10.1	3535 U.S. Hwy 281	"
535	K-10.1	254 E. Harding	"
536	K-10.1	263 E. Harding	"
537	K-10.1	283 E. Harding	"
538	K-9.2	110 W. Harding	"
539	K-9.1	346 W. Harding	"
540	K-9.1	1066* W. Harding	"
541	K-9.1	338 Shrine	"
542	K-8.4	510 Drury	Locked gates
543	K-8.4	1302 Clamp	"
544	K-8.4	403 Aaron	Unable to locate
545	K-8.3	3215 Pleasanton	"
546	K-8.3	219 Ware	"
547	K-8.2	146 Shrine	"
548	K-8.2	150 Shrine	"
549	K-8.2	154 Shrine	"
550	K-8.2	158 Shrine	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 26 of 58

*Service Number

Line #	Plat #	Address	Reason
551	K-8.1	322 Sharmain	Unable to locate
552	K-8.1	314 Sharmain	"
553	K-8.1	410 Sunglo	"
554	K-8.1	702 W. Harding	"
555	K-8.1	306 Clovis	Locked gates
556	K-7.4	1038 Cantrell	Unable to locate
557	K-7.4	903 Cantrell	"
558	K-7.4	907 Escalon	"
559	K-7.4	927 W. Vestal	"
560	K-7.4	910 W. Vestal	"
561	K-7.4	1023 W. Vestal	"
562	K-7.4	614 Logwood	"
563	K-7.4	618 Logwood	"
564	K-7.3	534 Aaron	Under car
565	K-7.3	882 Burton	Unable to locate
566	K-7.3	526 Aaron	"
567	K-7.3	2802 Commercial	"
568	K-7.3	2804 Commercial	"
569	K-7.3	522 Cantrell	"
570	K-7.3	526 Cantrell	"
571	K-7.3	514 W. Vestal	"
572	K-7.2	1111 W. Harding	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 27 of 58

*Service Number

Line #	Plat #	Address	Reason
573	K-7.2	2623 Commercial	Unable to locate
574	K-7.2	2600 Commercial	"
575	K-7.2	635 Clovis	"
576	K-7.2	631 Clovis	"
577	K-7.2	627 Clovis	"
578	K-7.2	630 Clovis	"
579	K-7.2	539 Clovis	"
580	K-7.2	535 Clovis	"
581	K-7.2	538 Clovis	"
582	K-7.1	1114 Clovis	Dogs
583	K-7.1	1411 W. Harding	Locked gates
584	K-7.1	1331 W. Harding	Unable to locate
585	K-7.1	1019 Clovis	"
586	K-7.1	9876* Logwood	"
587	K-6.3	1238 Aaron	Locked gates
588	K-6.3	1239 Cantrell in alley	Unable to locate
589	K-6.3	1320 Drury	"
590	K-6.3	1230 W. Vestal in alley	"
591	K-6.3	1239 W. Vestal	"
592	K-6.3	906 Cullin in alley	"
593	K-6.3	1226 Drury in alley	"
594	K-6.2	1522 W. Vestal	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 28 of 58

*Service Number

Line #	Plat #	Address	Reason
595	K-6.2	1406 Grosvenor	Unable to locate
596	K-6.1	7105 Zarzamora	"
597	K-6.1	7638 Cantrell	"
598	K-5.1	31489* Barlite	"
599	K-4.4	3210 Golden	"
600	K-4.4	3039 Golden	"
601	K-4.4	7622 Somerset Rd.	"
602	K-4.4	12859* Somerset Rd.	"
603	K-4.4	235 Pima	"
604	K-4.4	202 Pima	"
605	K-4.3	311 Palo Alto	Under car
606	K-4.3	511 Palo Alto	Unable to locate
607	K-4.3	611 Palo Alto	"
608	K-4.2	249 Palo Alto	"
609	K-4.2	2940 Mac Arthur	"
610	K-4.2	7403 Somerset	"
611	K-4.1	3235 Mac Arthur	"
612	K-4.1	3312 Mac Arthur	"
613	K-4.1	3239 Pitluk	"
614	K-4.1	3227 La Violetta	"
615	K-4.1	3059 La Rosa	"
616	K-4.1	3109 La Rosa	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 29 of 58

*Service Number

Line #	Plat #	Address	Reason
617	K-4.1	3123 La Rosa	Unable to locate
618	K-4.1	3203 La Rosa	"
619	K-3.2	3303 Pitluk	"
620	K-3.2	3339 Pitluk	"
621	K-3.2	3271 Pitluk	"
622	K-3.1	3839 Pitluk	"
623	K-2.3	Quintana Rd.	"
624	J-9.3	138 Emilie	"
625	J-9.3	103 Dickson	"
626	J-9.4	164 Dickson in alley	"
627	J-9.1	105 E. Pyron	"
628	J-9.1	216 Kendalia Ave	"
629	J-9.1	206 Kendalia Ave	"
630	J-9.1	120 W. Bonner Ave.	"
631	J-9.1	110 W. Bonner Ave.	"
632	J-9.1	143 Mayfield	"
633	J-9.1	106 Wiggins	"
634	J-9.1	104 Wiggins	"
635	J-8.4	323 Grosvenor	"
636	J-8.4	327 Grosvenor	"
637	J-8.4	202 Rayburn	"
638	J-8.4	1139 S.W. Military	"

APPENDIX J
Edwards Underground Water District
Services/Unable to Survey
1992

System: Bexar Metropolitan Water District

Page 30 of 58

*Service Number

Line #	Plat #	Address	Reason
639	J-8.3	502 S.W. Military	Unable to locate
640	J-8.3	606 S.W. Military	Service #12178 Unable to locate
641	J-8.3	606 S.W. Military	Service #12179 Unable to locate
642	J-8.3	102 Shasta	Unable to locate
643	J-8.3	130 Shasta	"
644	J-8.3	134 Shasta	"
645	J-8.3	138 Shasta	"
646	J-8.3	142 Shasta	"
647	J-8.3	146 Shasta	"
648	J-8.2	514 Kendalia	"
649	J-8.2	118 McCauley	"
650	J-8.2	Between 219 and 223 E. Mayfield	"
651	J-8.2	143 E. Mayfield	Locked gate
652	J-8.1	560 Kendalia	Unable to locate
653	J-8.1	1139 S.W. Military	"
654	J-8.1	148 W. Mayfield	"
655	J-8.1	439 McCauley	"
656	J-8.1	426 McCauley	"
657	J-8.1	674 Kendalia	Locked gates
658	J-7.4	833 Rayburn	Unable to locate
659	J-7.4	1809 S.W. Military	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 31 of 58

*Service Number

Line #	Plat #	Address	Reason
660	J-7.3	2115 Commercial	Unable to locate
661	J-7.3	2213 Commercial	Under car
662	J-7.3	519 Verne	Unable to locate
663	J-7.3	534 Verne	"
664	J-7.3	845 Grosvenor	"
665	J-7.3	723 Grosvenor	"
666	J-7.3	703 Grosvenor	"
667	J-7.2	280 W. Mayfield	Brush Pile
668	J-7.2	727 Kendalia	"
669	J-7.1	1085 W. Pyron	Unable to locate
670	J-7.1	1222 W. Pyron	"
671	J-7.1	347 W. Mayfield	Brush Pile
672	J-7.1	1070 Kendalia	Dog
673	J-7.1	9018 McCauley	Unable to locate
674	J-7.1	9055 McCauley	"
675	J-6.3	1304 Rayburn	"
676	J-6.3	2130 S.W. Military	"
677	J-6.3	2" Service S.W. Military @ IH 35	"
678	J-6.2	458 W. Mayfield	"
679	J-6.2	1246 W. Pyron	Locked gate
680	J-6.2	533 W. Mayfield	Brush Pile
681	J-6.2	1305 Kendalia	Locked gates

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 32 of 58

*Service Number

Line #	Plat #	Address	Reason
682	J-6.2	1235 Kendalia	Locked gates
683	J-6.2	1191 Kendalia	"
684	J-6.2	1135 Kendalia	"
685	J-6.2	522 W. Mayfield	"
686	J-6.2	1273 W. Pyorn	Brush Pile
687	J-6.1	1800 W. Pyron	"
688	J-6.1	1702 W. Mayfield	"
689	J-6.1	544 W. Mayfield	Locked gate
690	J-6.1	1210 Kyle	Brush Pile
691	J-5.4	1627 Somerset Rd.	Unable to locate
692	J-5.2	1942 W. Pyron	"
693	J-5.2	817 W. Mayfield	"
694	J-5.2	840 W. Mayfield	"
695	J-5.2	838 W. Mayfield	"
696	J-5.2	738 W. Mayfield	"
697	J-5.2	822 W. Mayfield	Locked gates
698	J-5.2	1718 Kendalia	Under truck in alley
699	J-5.2	2735 S.W. Military	Unable to locate
700	J-5.1	206 King Ave.	"
701	J-5.1	Next to 2046 W. Pyron	"
702	J-5.1	930 W. Mayfield	"
703	J-5.1	923 W. Mayfield	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 33 of 58

*Service Number

Line #	Plat #	Address	Reason
704	J-5.1	153 Fenfield	Service on Mayfield
705	J-5.1	883 W. Mayfield	Unable to locate
706	J-5.1	1531 Somerset Rd.	"
707	J-5.1	1532 Somerset Rd.	"
708	J-5.1	1874 Kendalia	"
709	J-5.1	1975 McCauley	"
710	J-5.1	1574 Somerset Rd.	Service on Barlite
711	J-5.1	1547 Somerset Rd.	Locked Gate
712	J-4.4	251 Briggs	Unable to Locate
713	J-4.4	303 Briggs	"
714	J-4.4	335 Briggs	Locked Gate
715	J-4.4	339 Briggs	"
716	J-4.4	3622 S.W. Military	"
717	J-4.4	1317 Hwy 81	"
718	J-4.4	Next to 7122 Hwy 81	"
719	J-4.3	157 Briggs	Unable to Locate
720	J-4.3	Somerset @ Briggs	Service #28408
721	J-4.3	Southwest corner of S.W. Military @ Kelsey	Unable to Locate
722	J-4.2	918 U.S. Hwy 81	One of two services
723	J-4.2	1033 W. Mayfield	Brush Pile
724	J-4.2	1043 W. Mayfield	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 34 of 58

*Service Number

Line #	Plat #	Address	Reason
725	J-4.2	1023 W. Mayfield	Unable to Locate
726	J-4.2	249 Fenfield	Service on Mayfield Locked Gates
727	J-4.2	1020 W. Mayfield	Locked Gates
728	J-4.2	1216 W. Mayfield	"
729	J-4.2	414 Fenfield	Unable to Locate
730	J-4.2	102 Kelsey	Locked Gates
731	J-4.2	110 Kelsey	Unable to Locate
732	J-4.2	307 Price Ave.	"
733	J-4.2	222 Price Ave.	"
734	J-4.2	264 Price Ave.	"
735	J-4.2	212 Price Ave.	Locked Gates
736	J-4.2	226 Kelsey	Brush Pile
737	J-4.1	1622 W. Mayfield	Unable to Locate
738	J-4.1	1021 Crittendon	Service on Mayfield
739	J-4.1	1323 W. Mayfield	Unable to Locate
740	J-4.1	1520 W. Mayfield	Locked Gates / Services on Fenfield
741	J-4.1	419 Price Ave.	Unable to Locate
742	J-4.1	633 Price Ave.	"
743	J-4.1	415 Price Ave.	Trash Pile
744	J-4.1	1211 U.S. Hwy 81	Unable to Locate / Service on Price

APPENDIX J

Edwards Underground Water District Services/Unable to Survey

1992

System: Bexar Metropolitan Water District

Page 35 of 58

*Service Number

Line #	Plat #	Address	Reason
745	J-4.1	1235 U.S. Hwy 81	Unable to Locate
746	J-4.1	1710 Bynum	"
747	J-3.4	603 Briggs	"
748	J-3.4	605 Briggs	"
749	J-3.4	4042 S.W. Military	"
750	J-3.4	4038 S.W. Military	"
751	J-3.4	7266 Quintana Rd.	"
752	J-3.4	7222 Quintana Rd.	"
753	J-3.4	7214 Quintana Rd.	"
754	J-3.3	3650 S.W. Military	"
755	J-3.3	3805 S.W. Military	"
756	J-3.3	831 Bynum	"
757	J-3.3	836 Bynum	"
758	J-3.3	855 Bynum	"
759	J-3.3	501 Briggs	Locked Gates
760	J-3.3	502 Briggs	"
761	J-3.3	519 Briggs	Unable to Locate
762	J-3.3	433 Briggs	"
763	J-3.2	214 Prospect	"
764	J-3.2	1238 Fenfield	"
765	J-3.2	1383 Fenfield	"
766	J-3.2	1371 Fenfield	Locked Gates

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 36 of 58

*Service Number

Line #	Plat #	Address	Reason
767	J-3.2	1367 Fenfield	Locked Gates
768	J-3.2	1327 Fenfield	"
769	J-3.2	1302 Fenfield	"
770	J-3.2	1231 Fenfield	"
771	J-3.2	1365 Fenfield	Dogs
772	J-3.2	538 McLaughlin	Unable to Locate
773	J-3.2	534 McLaughlin	"
774	J-3.2	111 Carmel	"
775	I-8.4	222 Rosebud	Brush Pile
776	I-8.3	327 Mosaly	Locked Gate
777	I-8.3	200 Block of Gerald	
778	I-8.1	302 W. Southcross	Locked Gate
779	I-8.1	315 Burchan	"
780	I-7.4	6309 Macdona	Under Car
781	I-7.4	6115 Macdona	Unable to Locate
782	I-7.4	2206 Buffalo	Brush Pile
783	I-7.3	535 Burchan	Unable to Locate
784	I-7.3	518 Gerald	"
785	I-7.3	1410 Commercial	Locked Gate
786	I-7.2	734 Fitch	Unable to Locate
787	I-7.2	471 Cananvan	Locked Gates
788	I-7.1	1115 Brunswick	Unable to Locate

APPENDIX J

Edwards Underground Water District Services/Unable to Survey

1992

System: Bexar Metropolitan Water District

Page 38 of 58

*Service Number

Line #	Plat #	Address	Reason
811	I-6.1	902 Milvid	Unable to Locate
812	I-6.1	507 Berlin	"
813	I-6.1	802 Berlin	"
814	I-6.1	1402 Southcross	Locked Gate
815	I-5.4	597 New Laredo Hwy	Unable to Locate
816	I-5.4	571 New Laredo Hwy	"
817	I-5.4	2326 Gerald	Under Car
818	I-5.4	206 Lovett	Unable to Locate
819	I-5.4	259 Lovett	"
820	I-5.4	130 Peabody	Brush Pile
821	I-5.3	209 Mallard	Unable to Locate
822	I-5.3	902 Somerset	"
823	I-5.3	2103 Gerald	"
824	I-5.3	2104 Gerald	"
825	I-5.3	2043 Gerald	"
826	I-5.3	2031 Gerald	"
827	I-5.3	2027 Gerald	Locked Gates
828	I-5.2	360 Hwy 81	Unable to Locate
829	I-5.2	312 Hwy 81	"
830	I-5.2	260 Hwy 81	Under Car
831	I-5.2	Fay Service #7820	Unable to Locate
832	I-5.2	127 Fay	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 41 of 58

*Service Number

Line #	Plat #	Address	Reason
876	I-4.2	122 Applebee	Unable to Locate
877	I-4.2	126 Applebee	"
878	I-4.1	210 Baker	"
879	I-4.1	2802 W. Southcross	"
880	I-4.1	2923 W. Southcross	"
881	I-4.1	2738 W. Southcross	"
882	I-4.1	2634 W. Southcross	"
883	I-4.1	2624 W. Southcross	Locked Gate
884	I-4.1	2700 Block of Southcross Service #144	Unable to Locate
885	I-4.1	2700 Block of Southcross Service #5583	"
886	I-4.1	2700 Block of Southcross Service #10582	"
887	I-4.1	2700 Block of Southcross Service #20857	"
888	I-4.1	435 Wilcox	Under Brush
889	I-4.1	431 Wilcox	Locked Gate
890	I-4.1	311 Wilcox	"
891	I-3.3	Gerald - Service #15919	Unable to Locate
892	I-3.3	2643 Quintana	"
893	I-3.3	2639 Quintana	Locked Gate
894	I-3.3	2503 Quintana	"
895	H-8.4	558 Stonewall	Unable to Locate

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 42 of 58

*Service Number

Line #	Plat #	Address	Reason
896	H-8.4	518 Stonewall	Unable to Locate
897	H-8.4	492 Harlan	"
898	H-8.3	409 Stonewall	"
899	H-8.3	1109 Pleasanton	"
900	H-7.4	231 Flanders	"
901	H-7.4	238 Elks	"
902	H-7.4	854 Stonewall	"
903	H-7.3	706 Harlan	Locked Gate
904	H-7.3	686 Stonewall	Unable to Locate
905	H-7.2	Vermont @ Commercial - Service #25016	"
906	H-7.2	845 Crystal Blvd.	"
907	H-7.1	1110 Vermont	"
908	H-7.1	1104 Buffalo	"
909	H-7.1	1003 Chalmers 1 of 2	"
910	H-7.1	1003 Crystal 1 of 2	Locked Gate
911	H-7.1	1146 Crystal	Unable to Locate
912	H-7.1	921 Keats	Locked Gate
913	H-6.4	Zarzamora - Service #12302	Unable to Locate
914	H-6.4	Between 217 and 207 Somerset	"
915	H-6.4	306 Somerset	"
916	H-6.4	1535 Harlan	"
917	H-6.4	5406 Zarzamora	"

APPENDIX J
Edwards Underground Water District
Services/Unable to Survey
1992

System: Bexar Metropolitan Water District

Page 43 of 58

*Service Number

Line #	Plat #	Address	Reason
918	H-6.4	5318 Zarzamora	Unable to Locate
919	H-6.4	634 Humboldt	"
920	H-6.4	1420 Stonewall	"
921	H-6.4	1447 Flanders in alley	"
922	H-6.4	1443 Flanders in alley	"
923	H-6.4	1439 Flanders in alley	"
924	H-6.3	1222 Brighton in alley	"
925	H-6.3	1216 Brighton in alley	"
926	H-6.3	1210 Brighton in alley	"
927	H-6.3	1209 Flanders	Locked Gate
928	H-6.3	1418 Flanders	"
929	H-6.3	1431 Flanders	"
930	H-6.3	1342 Flanders	"
931	H-6.3	1428 Flanders - Service on Elks	Unable to Locate
932	H-6.3	1320 Flanders - Service on Elks	"
933	H-6.3	1314 Flanders - Service on Elks	"
934	H-6.3	1226 Flanders - Service on Elks	"
935	H-6.3	1212 Flanders - Service on Elks	"
936	H-6.3	344 Elks	"
937	H-6.3	364 Humboldt	Unable to Locate
938	H-6.2	1429 Division	"
939	H-6.2	1428 Division	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 45 of 58

*Service Number

Line #	Plat #	Address	Reason
961	H-4.3	218 Dacus	Locked Gate
962	H-4.2	1211 Quintana	Unable to Locate
963	H-4.2	1207 Quintana	Locked Gate
964	G-7.4	412 Carlisle Ave.	Unable to Locate
965	G-7.4	426 Carlisle Ave.	"
966	G-7.4	428 Carlisle Ave.	"
967	G-6.4	331 Illg Ave.	"
968	G-6.4	336 Illg Ave.	Under Brush Pile
969	G-6.3	118 Carlisle Ave.	Locked Gate
970	G-6.3	122 Carlisle Ave.	Unable to Locate
971	G-6.3	124 Carlisle Ave.	"
972	G-6.3	128 Carlisle Ave.	"
973	F-6.1	802 Kirk	"
974	F-6.1	778 Kirk	Locked Gate
975	F-6.1	Across from 1329 Frio City Rd.	Unable to Locate
976	F-5.3	2003 Jupiter	"
977	F-5.3	3211 Saturn	"
978	F-5.3	3203 Mars	Locked Gate
979	F-5.1	334 W. Academy	"
980	F-5.1	206 W. Academy	"
981	F-5.1	118 W. Academy	"
982	F-4.4	114 W. Academy	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 46 of 58

*Service Number

Line #	Plat #	Address	Reason
983	F-4.4	103 Nightengale	Locked Gate
984	F-4.3	327 Emerson Ave.	"
985	F-4.3	3051 Roselawn	Unable to Locate
986	F-4.3	3055 Roselawn	"
987	F-4.2	427 Academy	"
988	F-4.2	435 Bedford	"
989	F-4.2	346 W. Academy	Locked Gate
990	F-4.1	Gen. McMullen - Service #21427	Unable to Locate
991	F-4.1	130 Darson Marie	"
992	F-4.1	Gen. McMullen - Service #3134	"
993	E-6.4	Next to 716 Harriman Pl.	"
994	E-5.1	1203 Brady Blvd.	"
995	E-5.1	Between 338-330 Patton	"
996	E-4.4	Weir - Service #9259	"
997	E-4.4	Weir - Service #11815	"
998	E-4.4	3326 Weir Ave.	"
999	E-4.4	3406 Weir Ae.	"
1000	E-4.4	3406 Weir Ave.	"
1001	E-4.4	3331 Weir Ave.	"
1002	E-4.4	3434 Weir Ave.	Locked Gate
1003	E-4.4	123 Darson Marie	Under Brush Pile
1004	E-4.3	3111 Jane Ellen	Unable to Locate

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 47 of 58

*Service Number

Line #	Plat #	Address	Reason
1005	E-4.3	3107 Jane Ellen	Unable to Locate
1006	E-4.3	3102 Jane Ellen	Locked Gate
1007	E-4.3	3034 Hatton	Unable to Locate
1008	E-4.3	3030 Hatton	"
1009	E-4.3	938 Cupples	"
1010	E-4.3	Lauren Ashley - Service #30719	"
1011	E-4.3	Lauren Ashley - Service #30720	"
1012	E-4.3	Lauren Ashley - Service #30721	"
1013	E-4.3	Lauren Ashley - Service #30722	"
1014	E-4.3	Lauren Ashley - Service #30723	"
1015	E-4.3	Michael Brian - Service #30759	"
1016	E-4.3	Michael Brian - Service #30758	"
1017	E-4.3	Michael Brian - Service #30714	"
1018	E-4.2	802 Menefee	"
1019	E-4.1	Gen. McMullen under Hwy 90	"
1020	E-4.1	240 Guanajuato	"
1021	E-3.4	3715 Beech St.	"
1022	E-3.3	3735 Weir	"
1023	E-3.3	Between 3709 and 3639 Weir	"
1024	E-3.2	1543 Menefee St.	"
1025	E-3.2	1539 Menefee St.	"
1026	E-3.2	1534 Menefee St.	Locked Gate

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 48 of 58

*Service Number

Line #	Plat #	Address	Reason
1027	E-3.2	1542 Menefee St.	Unable to Locate
1028	D-5.1	215 Cheyenne	"
1029	D-5.1	1518 Merida	Locked Gate
1030	D-5.1	1522 Merida	"
1031	D-4.4	419 Sylvia	"
1032	D-4.4	2016 Ceralvo	Under Car
1033	D-4.4	145 Aldama	Locked Gate
1034	D-4.4	219 Amayo	Under Brush Pile
1035	D-4.4	218 Amayo	Locked Gate
1036	D-4.4	1027 Patton	Unable to Locate
1037	D-4.4	1023 Patton	"
1038	D-4.4	947 Patton	"
1039	D-4.4	945 Patton	"
1040	D-4.4	939 Patton	"
1041	D-4.4	922 Patton	"
1042	D-4.4	847 Patton	"
1043	D-4.3	214 Sylvia	"
1044	D-4.3	1703 Ceralvo	"
1045	D-4.3	802 Patton	Under Brush Pile
1046	D-4.3	526 Patton	"
1047	D-4.3	542 Patton	Unable to Locate
1048	D-4.2	423 Queretaro	Under Brush Pile

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 49 of 58

*Service Number

Line #	Plat #	Address	Reason
1049	D-4.2	422 Queretaro	Under Brush Pile
1050	D-4.2	314 Chipinque	"
1051	D-4.2	107 Chipinque	Unable to Locate
1052	D-4.2	222 Remolino	Under Trash Pile
1053	D-4.1	523 Chipinque	Unable to Locate
1054	D-4.1	1106 Gen. McMullen	"
1055	D-4.1	Across from 126 Coronado	"
1056	D-4.1	201 Coronado	"
1057	D-4.1	209 Coronado	Unable to Locate
1058	D-4.1	225 Coronado	"
1059	D-4.1	301 Coronado	"
1060	D-4.1	129 Balboa	"
1061	D-4.1	336 Balboa	"
1062	D-4.1	231 Juanita	"
1063	D-4.1	331 Juanita	"
1064	D-4.1	335 Juanita	"
1065	D-3.3	423 Aldama	Locked Gate
1066	D-3.3	347 Aldama	"
1067	D-3.3	410 Aldama	Under Brush Pile
1068	D-3.3	404 Aldama	Unable to Locate
1069	D-3.3	1111 Patton	"
1070	D-3.3	452 Arteago	Locked Gate

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 50 of 58

*Service Number

Line #	Plat #	Address	Reason
1071	D-3.3	446 Arteago	Locked Gate
1072	D-3.3	310 Arteago	Unable to Locate
1073	D-3.3	2023 Wescott	Under Brush Pile
1074	D-3.2	1626 Allende	Unable to Locate
1075	D-5.4	118 Apperson	"
1076	D-3.3	1245 Patton	"
1077	D-3.3	319 Coronado	"
1078	D-4.2	427 Chipinque	Under Brush Pile
1079	D-4.2	202 Remolino	Locked Gate
1080	D-4.3	551 Patton	"
1081	D-5.1	1807 Saltillo	"
1082	D-5.4	1406 Merida	Under Brush Pile
1083	E-4.2	902 Menefee	Unable to Locate
1084	E-4.3	3030 Jane Ellen	Locked Gate
1085	E-5.3	W. Kirk Ave. - Service #15998	Unable to Locate
1086	F-4.2	1304 Cupples	Locked Gate
1087	F.4.2	1302 Cupples	"
1088	F.6.2	1240 Chalmers	Unable to Locate
1089	F-6.3	1342 Flanders	"
1090	F-6.3	1303 Flanders	Locked Gate
1091	F-6.3	1230 Flanders	Unable to Locate
1092	F-6.3	1126 Stonewall	Locked Gate

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 51 of 58

*Service Number

Line #	Plat #	Address	Reason
1093	H-6.4	1552 Brighton	Unable to Locate
1094	H-6.4	1503 Flanders	Locked Gate
1095	H-7.1	855 Division	"
1096	H-7.1	862 Division	"
1097	H-7.1	1024 Crystal Blvd.	"
1098	H-7.4	912 Harlan	"
1099	H-7.4	202 Elks	"
1100	H-7.4	1012 Stonewall	"
1101	H-7.4	906 Brighton	Unable to Locate
1102	I-3.3	2415 Quintana	Locked Gate
1103	I-3.3	263 Prospect	Unable to Locate
1104	I-4.3	440 King	"
1105	I-5.3	703 Somerset	"
1106	I-5.3	1114 Wagner	"
1107	I-5.3	1214 Wagner	"
1108	I-5.2	11222 Wagner	"
1109	I-5.3	1602 Whitman	"
1110	I-6.1	1007 Milvid	Locked Gate
1111	J-3.2	1115 Fenfield	"
1112	J-3.2	1113 Fenfield	"
1113	J-3.2	242 Prospect	"
1114	J-3.2	110 Fernleaf	"

APPENDIX J
Edwards Underground Water District
Services/Unable to Survey
1992

System: Bexar Metropolitan Water District

Page 52 of 58

*Service Number

Line #	Plat #	Address	Reason
1115	J-3.3	602 Briggs	Unable to Locate
1116	J-4.4	302 Briggs	"
1117	J-4.4	Harlan #24139	"
1118	J-4.4	Harlan #28809	"
1119	J-5.1	1862 Kendalia	"
1120	J-5.3	1802 Rayburn	"
1121	J-6.1	Zarzamora #29245	"
1122	J-7.1	1722 S.W. Military	Locked Gate
1123	J-7.1	847 McCauley	"
1124	J-7.1	978 Kendalia	Unable to Locate
1125	J-8.4	1103 S.W. Military	Locked Gate
1126	J-9.1	543 Mayfield	Under Brush Pile
1127	J-9.2	104 Congress	Unable to Locate
1128	K-4.1	3071 La Violetta	Locked Gate
1129	K-4.4	3034 Navajo	Unable to Locate
1130	K-6.4	1523 W. Vestal	Under Brush Pile
1131	K-6.4	Cantrell #23571	Unable to Locate
1132	K-7.1	1114 Clovis	Dog
1133	K-7.2	602 Sunglo	Unable to Locate
1134	K-7.2	602 Burton	"
1135	K-7.3	639 Drury	Locked Gate
1136	K-7.4	812 Logwood	Under Brush Pile

APPENDIX J
Edwards Underground Water District
Services/Unable to Survey
1992

System: Bexar Metropolitan Water District

Page 53 of 58

*Service Number

Line #	Plat #	Address	Reason
1137	K-8.1	218 Sunglo	Locked Gate
1138	K-8.1	234 Clovis	Unable to Locate
1139	K-8.2	2905 Pleasanton Rd.	"
1140	K-8.3	102 E. Vestal	"
1141	K-8.4	502 Cantrell	"
1142	K-8.4	414 Aaron	Under Brush Pile
1143	K-9.4	338 E. Hutchins	Unable to Locate
1144	K-10.1	255 Lorita	Dog
1145	L-4.3	Palo Alto #26543	Unable to Locate
1146	L-5.1	Lytle @ W. Hutchins	"
1147	L-7.1	1126 W. Hutchins	Locked Gate
1148	L-8.4	1938 Clamp	Under Car
1149	L-9.1	155 Creath Pl.	Unable to Locate
1150	L-9.3	714 Kopplow	"
1151	L-9.3	815 Dodic	"
1152	L-9.4	337 E. Petaluma	"
1153	M-4.1	3211 Fort Parker	Dog
1154	M-4.1	3023 Anna Rose	Unable to Locate
1155	M-4.4	335 Wainwright	"
1156	M-4.4	329 Wainwright	"
1157	M-4.4	250 Spaatz	"
1158	M-4.4	247 Spaatz	"

APPENDIX J
Edwards Underground Water District
Services/Unable to Survey
1992

System: Bexar Metropolitan Water District

Page 54 of 58

*Service Number

Line #	Plat #	Address	Reason
159	M-4.4	302 Doolittle	Unable to Locate
1160	M-4.4	9235 Lasswell	"
1161	M-4.4	266 McNarney	"
1162	M-5.1	2315 Abacus	Locked Gate
1163	M-5.2	1815 Ann Arbor	Unable to Locate
1164	M-6.1	1518 W. Ansley	"
1165	M-6.1	1554 Beverly Ann	"
1166	M-6.3	1404 Hunter	"
1167	M-7.2	363 W. Ansley	"
1168	M-7.3	634 W. Baetz	"
1169	M-8.1	233 Dorsey	"
1170	M-8.3	214 Myrick	"
1171	M-9.2	618 Baltzell	"
1172	M-9.2	603 Ashley	"
1173	M-9.3	835 Bernard	"
1174	M-9.4	507 Lanier	Locked Gate
1175	M-10.4	1018 Bernard	Unable to Locate
1176	N-4.1	228 Ike	"
1177	N-5.2	1870 W. Mally	"
1178	N-5.2	1866 W. Mally	"
1179	N-6.1	1715 W. Mally	"
1180	N-6.1	1711 W. Mally	"

APPENDIX J
Edwards Underground Water District
Services/Unable to Survey
1992

System: Bexar Metropolitan Water District

Page 55 of 58

*Service Number

Line #	Plat #	Address	Reason
1181	N-6.1	1707 W. Mally	Unable to Locate
1182	N-6.2	1446 W. Mally	Locked Gate
1183	N-6.2	9419 Street	Unable to Locate
1184	N-6.2	9318 Viz Rey	"
1185	N-7.2	819 W. Mally	"
1186	N-7.2	550 Villaret	"
1187	N-8.3	106 Buchanan	"
1188	N-9.1	327 Pinhurst	"
1189	N-9.1	538 E. Villaret	"
1190	O-4.2	10042 State Hwy #16	"
1191	O-10.2	1426 San Rafael	"
1192	O-11.1	1611 Sanez	"
1193	O-11.4	1518 Estancia	"
1194	P-4.1	3015 Moss Springs	"
1195	Q-0.1	12325 Fisher Rd.	"
1196	SH-21.4	8016 First St.	"
1197	SH-21.4	19511 N. Dixon	"
1198	SH-21.4	19525 N. Dixon	"
1199	SI-21.1	Fifth St. @ Oil St.	"
1200	SI-21.1	Oil St. @ Seventh	"
1201	SI-21.1	Across from 8150 Seventh St.	"
1202	SI-21.1	Seventh St. @ N. Dixon	"

APPENDIX J
Edwards Underground Water District
Services/Unable to Survey
1992

System: Bexar Metropolitan Water District

Page 56 of 58

*Service Number

Line #	Plat #	Address	Reason
1203	SI-21.2	7988 Fifth St. in alley	Unable to Locate
1204	SI-21.2	7968 Seventh	"
1205	SI-21.2	Seventh St. next to 7912	"
1206	SI-21.3	313 W. Dixon	"
1207	SI-21.3	Between 7785 and 7769 W. Dixon	"
1208	SI-21.4	Pyron @ Ninth	"
1209	SI-21.4	8020 Eighth	"
1210	SI-21.4	19914 #2 Somerset St.	"
1211	SI-22.1	19611 Quail Run	"
1212	SI-22.1	7350 Sixth St.	"
1213	SI-22.4	7641 W. Dixon	"
1214	SJ-21.1	20397 Somerset Rd.	"
1215	CD-1	105 Winston Lane	"
1216	CD-1	West Castle #7662	"
1217	CD-1	316 Foxhall Ln.	"
1218	CD-2	Military @ Winston	"
1219	CD-2	108 Martha Glynn	"
1220	CD-2	120 Elizabeth Ann	"
1221	CD-2	1339 Lockhill Selma	"
1222	CE-1	308 Foxhall Ln.	"
1223	CE-1	246 Foxhall Ln.	"
1224	CE-1	228 Foxhall Ln.	"

APPENDIX J

Edwards Underground Water District Services/Unable to Survey 1992

System: Bexar Metropolitan Water District

Page 57 of 58

*Service Number

Line #	Plat #	Address	Reason
1225	CE-1	82 Roundup Dr.	Unable to Locate
1226	CE-1	Hibiscus #10318	"
1227	CE-2	Next to 101 Manton #6421	"
1228	CE-2	Castle Oaks #23802	"
1229	CE-2	111 Lemonwood	"
1230	CE-2	206 East Castle	"
1231	CE-2	108 Sunflower	"
1232	CE-2	204 Gardenview	"
1233	CE-3	225 Gardenview	Locked Gate
1234	CE-3	303 Tamworth	"
1235	CE-3	303 Tamworth	Unable to Locate
1236	CE-3	102A Peg Sue	"
1237	CE-3	7243 Blanco Rd.	"
1238	CF-1	6209 West Ave.	"
1239	CF-2	102 Roundup	"
1240	CF-3	102 Briarcliff	Locked Gate
1241	CF-3	1011 Loop 410	Unable to Locate
1242	CF-3	1105 Blanco Rd.	"
1243	CF-3	1000 Loop 410	"
1244	CF-3	6601 Blanco Rd.	"
1245	CF-3	205 Lundblade	"
1246	CF-3	208 Lundblade	"

APPENDIX J
Edwards Underground Water District
Services/Unable to Survey
1992

System: Bexar Metropolitan Water District

Page 58 of 58

*Service Number

Line #	Plat #	Address	Reason
1247	CF-3	222 Lundblade	Unable to Locate
1248	CF-3	225 Lundblade	"
1249	CF-3	Lundblade #3389	"
1250	CF-3	6501 Blanco	"
1251	CG-2	108 Cotillion	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 1 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
1	S-9.1	Pleasanton @ Mauermann	#3, 4	2	Raise to Grade
2	S-7.2	Mauermann	#2	1	"
3	R-9.4	Pleasanton Rd.	#1	1	"
4	R-9.1	Pleasanton Rd.	#1, 2	2	"
5	R-6.3	Mauermann Rd.	F.H. A	1	"
6	Q-11.4	U.S. 281	F.H. B	1	"
7	O-8.3	Pleasanton Rd.	F.H. A	1	"
8	Q-5.4	Zarzamora @ Applewhite	#6	1	"
9	Q-5.1	Applewhite	F.H. A	1	"
10	Q-4.4	State Hwy. 16	F.H. A	1	"
11	Q-4.4	State Hwy. 16	#1, 2, 3	3	"
12	Q-4.1	State Hwy. 16	F.H. A, C, B, #2	4	"
13	P-8.2	10762 Pleasanton Rd.	Service Valve	1	"
14	P-8.2	11021 Pleasanton Rd.	#2	1	"
15	P-5.4	Applewhite	F.H. B, #2	2	"
16	P-4.4	Valley Star @ Ivy Ridge	#5	1	"
17	P-4.4	State Hwy. 16	#23	1	"
18	P-4.2	State Hwy. 16	F.H. B, 5, 4	3	"
19	P-4.1	Durette @ Gaylord	#5, 6	2	"
20	P-4.1	Durette @ Musket	#7	1	"

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 2 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
21	P-4.1	Gaylord @ Red Star	#21	1	Raise to Grade
22	P-4.1	Bending @ Claymore	#15	1	"
23	O-11.4	Renova @ Socorro	#10	1	"
24	O-11.4	Renova @ Rada	#14, 15	2	"
25	O-11.4	Renova @ San Acacia	#16	1	"
26	O-10.2	Santa Rita @ U.S. 281	#3	1	"
27	O-10.2	Sanchez @ U.S. 281	#6	1	"
28	O-10.2	San Rafael @ U.S. 281	#1	1	"
29	O-9.1	San Rafael	F.H. B, 4	2	"
30	O-6.1	Zarzamora @ S.W. Loop 410	#1, 2, 6, 7, 8, 10	6	"
31	O-5.2	S.W. Loop 410	F.H. D	1	Repair
32	O-5.1	S.W. Loop 410	F.H. D, 2	2	Raise to Grade
33	O-4.3	State Hwy 16	F.H. D, 6	2	"
34	N-10.4	1118 E. Chavaneaux	#1	1	"
35	O-4.2	State Hwy 16	F.H. D, C	2	"
36	N-10.2	U.S. Hwy 281 @ Herbst	#2	1	"
37	N-10.2	U.S. Hwy 281 @ Rilling	#1	1	"
38	N-9.4	S.W. Loop 410	#4, 5, 6	3	"
39	N-9.4	E. Chavaneaux	#2	1	"
40	N-9.3	S.W. Loop 410	#2, 3, 4	3	"
41	N-9.1	Mally @ Walhalla	#7, 1	2	"

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 3 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
42	N-9.1	E. Villaret @ Walhalla	#5	1	Raise to Grade
43	N-8.4	Chavaneaux	F.H. E, 4, 7	2	"
44	N-8.3	4535 Pleasanton Rd.	#10	1	"
45	N-8.3	Buchanan @ Moursund	#3	1	"
46	N-8.3	655 Moursund	#5	1	"
47	N-8.2	Pinehurst @ Pleasanton	#8	1	"
48	N-8.1	Mally @ Clamp	F.H. D	1	"
49	N-8.1	Garnett @ W. Villaret	#3	1	"
50	N-7.3	555 W. Chavaneaux	F.H. D	1	"
51	N-7.2	623 W. Mally	F.H. D	1	"
52	N-7.1	Mally @ Rockwell	#3, 4, 5	3	"
53	N-7.1	W. Mally @ Earth	#9	1	"
54	N-7.1	1007 Grand River	#11	1	Unable to Open
55	N-6.4	Ursula @ Cassandra	#1, 2	2	Raise to Grade
56	N-6.4	Ursula @ Jennifer	#4	1	"
57	N-6.3	W. Chavaneaux @ Strech	#1, 2	2	"
58	N-6.2	1310 Mally	#17	1	"
59	N-6.2	Mally @ Hindi	#12	1	"
60	N-6.2	Mally @ Wobaker Circle	#5	1	"
61	N-6.2	1270 Mally	#4	1	"
62	N-6.2	Strech @ W. Villaret	#15	1	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 4 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
63	N-6.2	Caballero @ Viz Rey	#9	1	Raise to Grade
64	N-6.1	Caballero @ Cerro Verde	#6	1	"
65	N-6.1	Zarzamora @ Cayo	#3	1	"
66	N-6.1	Zarzamora @ W. Villaret	#7	1	"
67	N-5.4	----	#2	1	Repair
68	N-5.3	Jennifer @ Sonia	#10	1	Raise to Grade
69	N-5.3	Jennifer @ Cassandra	#5	1	"
70	N-5.3	Jennifer @ Rhoda	#9	1	"
71	N-5.2	Cayo @ Rhoda	#4, 5, 12 20	4	"
72	N-5.2	W. Mally @ Rhoda	#11	1	"
73	N-5.1	1477 Villaret	#5	1	"
74	N-4.4	9603 Obispo Circle	#18	1	"
75	N-4.4	Aragon @ Manzano	#1, 2, 5	4	"
76	N-4.4	Aragon @ Algo Dulce	#7	1	"
77	N-4.4	3330 Twining	#26, F.H. G	2	"
78	N-4.4	Twining @ Anaheim	#9, 10	1	"
79	N-4.4	3306 Reforma	#21	1	"
80	N-4.4	Reforma @ Celeste	#15, 22	2	"
81	N-4.4	3322-18 Avoca Dr.	#25	1	"
82	N-4.4	Reforma @ Manzano	#13	1	"
83	N-4.3	Aragon # Wikieup	#5	1	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 5 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
84	N-4.3	Aragon @ Palo Alto	#3	1	Raise to Grade
85	N-4.3	Aragon @ Palo Alto	#4	1	Repair
86	N-4.3	State Hwy 346 @ Loop 410	#1, 2	2	Raise to Grade
87	N-4.3	Reforma @ Hwy 346	#12	1	"
88	N-4.2	State Hwy 346 @ Villaret	#20	1	"
89	N-4.2	Malta @ Hwy 346	F.H. L	1	"
90	N-4.2	Ike @ Lawley	---	1	"
91	N-4.2	Bradley @ Lawley	---	2	"
92	N-4.1	Ike @ Krueger	#27	1	"
93	N-4.1	Tedder @ Lasswell	#25	1	"
94	N-4.1	Vincent @ Krueger	F.H. G	1	"
95	N-3.3	3346 Aragon	F.H. A	1	"
96	N-3.3	Twining @ Maria Isabel	#4	1	"
97	N-3.3	Maria Isabel @ Reforma	#7	1	"
98	N-3.3	Maria Isabel @ Avoca	#9, 8	2	"
99	N-3.3	Maria Isabel @ Aragon	#1	1	"
100	N-3.2	Maria Isabel @ Coconino	#1, 2	2	"
101	N-3.2	Maria Isabel & Algo Dulce	#4, 10	2	"
102	M-10.1	Ashley @ Troy	#1	1	"
103	M-10.1	Ashley @ Ely	#2	1	"
104	M-10.1	Ashley # Hwy 281	#3, 4	2	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 6 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
105	M-9.4	9223 Brink Ln.	#10	1	Raise to Grade
106	M-9.3	Sams @ Leah	#5, 14, 15	3	"
107	M-9.3	Bernard @ Leah	#6, 7, 13	3	"
108	M-9.3	Bernard @ Lucinda	#4	1	"
109	M-9.2	Ashley @ Leah	#12, 2	2	"
110	M-9.1	Topsey @ Ansley	#6	1	"
111	M-9.1	407 Ashley	#5	1	"
112	M-8.4	Gillette @ Clamp	#6, 8	2	"
113	M-8.3	122-126 Baetz	F.H. G	1	"
114	M-8.3	Baetz @ Pleasanton	#13, 14 F.H. F	3	"
115	M-8.3	Pleasanton @ Beam	#8	1	"
116	M-8.3	Pleasanton & Oakbrook	#18	1	"
117	M-8.2	Ansley @ Braburn	#12	1	"
118	M-8.2	155 Ansley	#26, 25	2	"
119	M-8.2	Pleasanton @ Coffee	#23	1	Repair
120	M-8.1	2106 Clamp	#10	1	Unable to Open
121	M-8.1	Ansley @ Clamp	#11	1	Raise to Grade
122	M-7.4	Rockwell @ Gillette	#20, 21, 22	3	"
123	M-7.3	Baetz near Commercial	#12	1	"
124	M-6.4	Points West @ Silver Springs	#15, 16, 17	3	"

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 7 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
125	M-6.3	Gillette @ Conde	#12, 13, 4	3	Raise to Grade
126	M-6.3	Rockwell @ Hunter	#6, 2	2	"
127	M-6.2	Wilma Jean @ Hendrix	#11	1	"
128	M-6.2	Ilene Lynn @ Rockwell	#8	1	"
129	M-6.1	Janice Lavon @ Hunter	#13	1	"
130	M-6.1	1730 Ann Arbor	#2	1	"
131	M-5.4	Ozalid @ Gillette	#10	1	"
132	M-5.4	2243 Reel Dr.	#14	1	"
133	M-5.3	Trident @ Hunter	#27, 26	2	"
134	M-5.3	Rhonda @ Duluth	#8	1	"
135	M-5.2	Lytle @ Ann Arbor	#6	1	"
136	M-5.1	Tortuga @ Ozalid	#11	1	"
137	M-5.1	Abacus @ Buda	#1	1	"
138	M-4.4	Lasswell @ Spaatz	#3	1	"
139	M-4.4	Lasswell @ Wainwright	#14, 7	2	"
140	M-4.3	Lawley @ McNarney	#33	1	"
141	M-4.3	State Hwy 346	F.H. K, J, 15	3	"
142	M-4.3	State Hwy 346 @ Gillette	#18	1	"
143	M-4.2	Praire Hill @ Fair Meadows	#5	1	"
144	M-4.2	Praire @ Goose Creek	#8	1	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 8 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
145	M-4.2	Fair Meadows @ Palo Alto	#3	1	Raise to Grade
146	M-4.2	Palo Alto	F.H. J	1	"
147	M-4.2	Pollote @ Ted	#16	1	"
148	M-4.1	Hunter Creek @ Pine Hollow	#8, 9	2	"
149	M-4.1	Hunter Creek @ Fair Meadows	#2, F.H. A	2	"
150	M-4.1	Oxydol @ Pine Hollow	#16	1	"
151	M-4.1	3110-06 Goose Creek	#6	1	"
152	M-3.2	Somerset @ Fair Meadows	#18, 19, 27 30, 32	5	"
153	M-3.2	Somerset @ IH 35	#1, 26, 36, F.H. I	4	"
154	M-3.2	IH35	F.H. L, K	2	"
155	M-3.2	Palm Beach @ Palm Leaf	#15	1	"
156	M-3.2	Palm Beach @ Fair Meadows	#13, 14	2	"
157	M-3.2	Fair Meadows @ Palm Bluff	#2, 37	2	"
158	L-10.4	Saipan @ Barranca	#1	1	"
159	L-10.4	Petaluma @ Barranca	#5	1	"
160	L-10.4	Deely @ S. Flores	#10, 13	2	"
161	L-10.4	Petaluma @ Barranca	#11	1	"
162	L-10.1	S. Flores	F.H. C, E	2	"
163	L-9.4	Kopplow @ Bascum	#7	1	"

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 9 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
164	L-9.4	264 E. Petaluma	#8	1	Raise to Grade
165	L-9.3	Dodic @ Bascum	#3	1	"
166	L-9.3	Dodic @ Chaucer	#4	1	"
167	L-9.3	E. Petaluma @ Chaucer	#8	1	"
168	L-9.3	630 Deely	#13	1	"
169	L-9.3	Deely @ Bascum	F.H. J	1	"
170	L-9.2	Amber Pl @ Chaucer	F.H. J	1	"
171	L-9.2	E. Formosa @ Chaucer	#13	1	"
172	L-9.1	Oxana @ Langford	#15, 16	2	"
173	L-9.1	Oxana @ Creath	#12	1	"
174	L-9.1	Oxana @ E. Formosa	#10	1	"
175	L-8.4	Proctor @ Clamp	#13	1	Raise to Grade / Need Box
176	L-8.3	Sultenfuss @ Saipan	#10	1	Raise to Grade
177	L-8.3	219 Kopplow	Service Valve	1	"
178	L-8.3	167 E. Petaluma	#2, 21	2	"
179	L-8.3	Easement between Petaluma @ Ansley	F.H. I	1	"
180	L-8.2	Hutchins @ Pleasanton	#6, 8, 16	3	"
181	L-8.2	143 E. Amber Pl.	#4	1	"
182	L-8.2	Ackard @ Gladnell	9, F.H. H	2	"
183	L-8.1	419 W. Hutchins	Service Valve	1	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 10 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
184	L-8.1	435 W. Hutchins	Service Valve	1	Raise to Grade
185	L-8.1	W. Hutchins @ Mango	#19	1	"
186	L-8.1	W. Formosa @ Hohen	#11	1	"
187	L-7.4	567 Petaluma	#7	1	"
188	L-7.4	Petaluma @ Escalon	#9	1	"
189	L-7.3	8615 Honora	#10	1	"
190	L-7.2	W. Hutchins @ Burton	#12	1	"
191	L-7.2	W. Hutchins	#1. F.H. E, 18, 20, 31	5	"
192	L-7.2	W. Hutchins @ Escalon	#4	1	"
193	L-7.1	W. Hutchins @ Nock	F.H. A	1	"
194	L-6.3	W. Petaluma @ Wilma Jean	#2, 4	2	"
195	L-6.2	W. Hutchins	F. H. D	1	"
196	L-6.2	W. Hutchins @ Hilton	#9, 10	2	"
197	L-6.2	W. Formosa @ Cullin	#4	1	"
198	L-6.1	Gaddis @ Crenshawq	#8	1	"
199	L-6.1	W. Hutchins @ Zarzamora	#1	1	"
200	L-6.1	Peterson @ Zarzamora	#20	1	"
201	L-5.2	W. Hutchins @ Marek	F.H. D	1	"
202	L-5.2	Peterson @ Marek	#3	1	"
203	L-5.2	Gaddis @ Marek	#4	1	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 11 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
204	L-4.4	IH 35	F.H. E, C, 2, 3	4	Raise to Grade
205	L-4.4	IH 35 @ Kiowa	#1	1	"
206	L-4.3	IH 35	F.H. E, 8	2	"
207	L-4.3	Patron @ Ted	#4, 5	2	"
208	L-3.3	Somerset Rd.	#2	1	"
209	L-3.3	IH 35	F.H. A, 1	2	"
210	L-3.1	8130 U.S. Hwy 81	#1	1	"
211	L-2.4	Quintana @ Plumnear	#2	1	"
212	L-2.4	4532 Plumnear	F.H. B, 1	2	"
213	L-2.4	Plumnear @ U.S. 81	#4, 5, 67, 9	5	"
214	L-2.2	8510 U.S. Hwy 81	#1	1	"
215	K-10.1	E. Harding @ Hwy 281	#4, 10	2	"
216	K-9.4	Oxana @ E. Hutchins	#8	1	"
217	K-9.3	S. Flores	F.H. J	1	"
218	K-9.3	S. Flores @ Genevieve	F.H. I	1	"
219	K-9.2	Parchman @ Snyder	#11	1	"
220	K-9.1	Sussex @ Norma	F.H. F	1	"
221	K-9.1	346 W. Harding	#12	1	"
222	K-8.4	Drury @ Clamp	#7, 8	2	"
223	K-8.4	W. Vestal @ Oppenheimer	#20	1	"

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 12 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
224	K-8.3	119 W. Vestal	#3, 19, 20	3	Raise to Grade
225	K-8.2	Loleta @ Sussex	#6	1	"
226	K-8.2	Clovis @ Pleasanton	#5	1	"
227	K-7.3	Burton @ Drury	#1	1	"
228	K-7.3	Burton @ W. Vestal	#7, 25	2	"
229	K-7.2	W. Harding @ Burton	#36	1	"
230	K-6.3	Drury @ Hilton	#13, 14	2	"
231	K-6.3	Drury @ Cullin	#3, 9	2	"
232	K-6.3	W. Vestal @ Cullin	#29	1	"
233	K-6.2	Clovis @ Cullin	#1	1	"
234	K-6.2	Clovis @ Hilton	#5	1	"
235	K-6.1	E. Aviation	#14	1	"
236	K-6.1	Zarzamora	#13	1	"
237	K-5.4	IH 35 @ Navajo	#15, 3	2	"
238	K-5.3	7915 U.S. Hwy 81	#5	1	"
239	K-5.1	----	F.H. E	1	"
240	K-4.3	Moss Circle @ Glen Garden	#21, 13	2	"
241	K-3.1	3843 Pitluk	F.H. A, 3	2	"
242	K-3.1	3725 Pitluk	F.H. C	1	"
243	K-3.1	3631 Pitluk	F.H. D	1	"
244	K-2.2	Quintana @ Pitluk	#1	1	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 13 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
245	J-9.4	S.W. Military @ Norma	#10, 11, 12	3	Raise to Grade
246	J-9.4	Norma @ Emilie	#16	1	"
247	J-9.3	826 Durr St.	#35	1	"
248	J-9.3	7223 Green Oak	#41	1	"
249	J-9.3	7203 Green Oak	#37	1	"
250	J-9.3	S.W Military @ Curtis	#1	1	"
251	J-9.1	W. Pyron @ S. Flores	#16, 25	2	"
252	J-9.1	Kendalia @ Handley	F.H. H	1	"
253	J-9.1	Kendalia @ Harold	#11	1	"
254	J-9.1	Kendalia @ S. Flores	#3	1	"
255	J-8.4	Garnett @ Verne	#4, 36, 39	3	"
256	J-8.4	Verne @ Clamp	#40	1	"
257	J-8.3	Boswell Service #23943	Service Valve 41	1	"
258	J-8.2	E. Mayfield @ Boswell	#30	1	"
259	J-8.2	2045 Pleasanton	#3	1	"
260	J-8.1	128 W. Mayfield	F.H. J	1	Repair
261	J-8.1	Kendalia & Garnett	F.H. K	1	Can't Open
262	J-7.4	1802 S.W. Military	Fire line & service valve	2	Raise to Grade
263	J-7.4	S.W. Military @ Escalon	#19	1	"
264	J-7.3	Rayburn @ Burton	#21	1	"

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 14 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
265	J-7.3	Grosvenor @ Burton	F.H. F	1	Raise to Grade
266	J-7.2	McCauley @ Burton	#2, 7	2	"
267	J-7.1	IH 35	#25	1	Can't Open
268	J-7.1	IH 35	#25	1	Raise to Grade
269	J-7.1	409 W. Mayfield	#17	1	"
270	J-7.1	Logwood @ Kendalia	#29	1	"
271	J-7.1	929 Kendalia	#12	1	"
272	J-7.1	McCauley @ Escalon	#21, 4	2	"
273	J-6.4	6919 Zarzamora	Service Valve	1	"
274	J-6.4	6900 block of Zarzamora Service #23315	Service Valve	1	"
275	J-6.4	2310 S.W. Military	Service Valve to J.C. Penny #14, 20	2	"
276	J-6.4	S.W. Military @ Zarzamora	F.H. H, 4, 6	3	"
277	J-6.4	7100 block of Zarzamora	Fire line to Fed March #15	1	"
278	J-6.3	1900 block of S.W. Military	F.H. F	1	"
279	J-6.3	1926 S.W. Military	Service Valve	1	"
280	J-6.2	503 W. Mayfield	#11	1	"
281	J-6.1	W. Mayfield @ Kyle	#5, 7	2	"
282	J-6.1	545 W. Mayfield	F.H. D	1	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 17 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
324	I-6.2	Milved @ Huron	#15, 12	2	Raise to Grade
325	I-6.2	Berlin @ Lenard	#27, 26, 21, 20	4	"
326	I-6.2	Berlin @ Huron	#13, 14	2	"
327	I-6.2	835 W. Southcross	#25	1	"
328	I-6.1	1610 Fitch	Service Valve	2	"
329	I-5.4	Lovett @ Rankin	#23	1	Lid Concreted
330	I-5.4	206 Lovett	F.H. D	1	Raise to Grade
331	I-5.4	142 Peabody	F.H. E	1	"
332	I-5.3	1302 Whitman	#2	1	"
333	I-5.2	U.S. Hwy 81	#2	1	"
334	I-5.2	W. Southcross @ Wabash	#25	1	"
335	I-5.1	2372 W. Southcross	Service Valve	1	"
336	I-5.1	W. Southcross @ U.S. Hwy 81	5, 11, 12	3	"
337	I-5.1	2250 W. Southcross	Service Valve #15	1	"
338	I-5.1	2242 W. Southcross	Service Valve #14	1	"
339	I-4.4	Gerald @ Crittendon	#11	1	"
340	I-4.4	Peabody @ Spindle	#60	1	"
341	I-4.4	Kings Ave. @ Spindle	#72	1	"
342	I-4.4	Peabody @ Creighton	#55, 65	2	"

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 18 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
343	I-4.3	Gerald @ Oregon	F.H. E	1	Raise to Grade
344	I-4.3	530 Lovett	F.H. A	1	"
345	I-4.3	Between Lovett & Peabody @ Oregon	#26, 27	2	"
346	I-4.3	Between Peabody @ Kings Ave. @ Oregon	#28, 29	2	"
347	I-4.3	Kings Ave. & Clarendon	F.H. H	1	"
348	I-4.2	Baker @ Creighton	#15	1	"
349	I-4.2	Fay @ Creighton	#22	1	"
350	I-4.2	Hollenbeck @ Creighton	#18	1	"
351	I-4.2	Fay @ Applebee	#13, 2	1	"
352	I-4.1	Quintana @ Bartholomew	#30	1	Unable to Open
353	I-4.1	703 W. Southcross	Service Valve #26	1	Raise to Grade
354	I-4.1	Wilcox @ Quintana	#15	1	"
355	I-4.1	Wilcox @ Quintana	#41	1	Unable to Open
356	I-4.1	Wilcox @ Quintana	#42	1	"
357	I-3.3	Between Peabody & Kings Ave. @ Quintana	#3, 4	2	Raise to Grade
358	I-3.3	Kings Ave. @ Quintana	#24	1	"
359	I-3.3	W. Mayfield @ Burd	#5, 6	2	"
360	H-8.4	Harlan @ Donegan	#5, 6	1	"
361	H-7.4	Brighton & Ferndale	#11, 2	2	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 19 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
362	H-7.3	Harlan @ IH 35	#21, 22	2	Raise to Grade
363	H-6.4	New Laredo Highway	#54	1	Need Valve Box
364	H-6.4	Humboldt @ Packard	F.H. M	1	Raise to Grade
365	H-6.4	Harlan @ Packard	36, 53, FH R	3	"
366	H-6.2	Division @ Lenard	#1, 42	2	"
367	H-6.1	Nogalitos @ Division	#2	1	"
368	H-6.1	Nogalitors @ Hosack	#27	1	"
369	H-6.1	Ames @ Bloom	#33	1	"
370	H-6.1	Nogalitos @ Chalmers	#34	1	"
371	H-5.3	New Laredo Hwy.	#8, 9, 10	3	"
372	H-4.4	1717 Quintana	5, 6	2	"
373	H-4.3	Griffin @ Creighton	#10	1	Unable to Open
374	H-4.3	Between Palestine & Dacus on Quintana	#1	1	"
375	H-4.2	203 Lester	#6	1	Raise to Grade
376	G-7.4	930 Britton	#19	1	Unable to Open
377	H-4.4	Dacus @ Quintana	#8	1	"
378	H-4.4	1607 Quintana	Service Valve #10	1	"
379	H-4.4	Crittenden @ Quintana	#3	1	"
380	G-4.2	150 Querida	#10	1	"
381	F-5.3	Jupiter @ Saturn	#5, 6, 7	3	

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 20 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
382	F-5.1	W. Thompson @ Village Place	#19	1	
383	F-5.1	Village Place between Thompson & Academy	#9	1	
384	F-4.4	Elkins @ Gen McMullen	#14	1	
385	F-4.4	Roselawn @ Gen McMullen	#3	1	Raise to Grade
386	F-4.4	3238 Roselawn	#4	1	"
387	F-4.2	Thompson @ S.W. 27th St.	#18, 20	2	"
388	F-4.2	Thompson @ Cupples	#7	1	Unable to Open
389	F-4.1	Thompson - Service #28383	Service Valve #15	1	Raise to Grade
390	F-4.1	Thompson @ Gen McMullen	#17	1	"
391	F-4.1	Allendale @ Hallett	#7	1	"
392	F-3.3	Felton @ Imperial	#3	1	Needs Repair
393	F-3.2	Thompson @ Imperial	F.H. C	1	Raise to Grade
394	F-3.2	Bayville @ Imperial	#3	1	"
395	F-3.2	Chesley @ Imperial	#6	1	"
396	E-5.4	Menefee @ Barclay	#8, 10	2	"
397	E-5.4	2810 Depla	F.H. F	1	"
398	E-5.4	1346 W. Kirk	#3	1	"
399	E-5.4	W. Kirk @ S.W. 21th St.	#13, 5	2	"
400	E-5.3	Grothues @ W. Kirk	#4	1	"
401	E-5.1	344 Patton	?	1	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 21 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
402	E-5.1	Menefee @ Cupples	#G	1	Raise to Grade
403	E-4.4	Behind 2519 Aiken	#28, 29	2	"
404	E-4.4	Weir @ Gen McMullen	#1, 31, 3, 4	4	"
405	E-4.4	Darby @ Gen McMullen	F.H. E	1	"
406	E-4.4	Menefee @ Gen McMullen	F.H. H	1	"
407	E-4.3	3026 Weir		1	"
408	E-4.2	Menefee @ Yantis	#3	1	"
409	E-4.2	Menefee @ Darlington	#1	1	"
410	E-3.2	1614 Menefee	F.H. C	1	"
411	D-5.4	Merida @ Barclay	#1, 10, 11, 12	4	"
412	D-5.4	Ceralvo @ Barclay	#15	1	"
413	D-5.4	619 Cupples	Service Valve 20	1	"
414	D-5.4	635 Cupples	Service Valve	1	"
415	D-5.1	Cheyenne @ Cupples	F.H. E	1	"
416	D-5.1	Merida @ Cupples	#14	1	"
417	D-4.4	2012 Ceralvo	Service Valve	1	"
418	D-4.3	Sylvia @ Cardova	#5	1	"
419	D-4.2	Morelia & Cameto	#12	1	"
420	D-4.2	Queretaro & Cantoria	F.H. E, 5, 6, 19	4	"

APPENDIX K
Edwards Underground Water District
Valve Stack/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 22 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
421	D-4.2	Queretaro @ Escuela	F.H. 4	1	Raise to Grade
422	D-4.2	Chipinque @ Cantoria	#20, 7	2	"
423	D-4.2	Cardova @ Remolino	#14	1	"
424	D-4.1	Between Gen McMullen & Juanita	#43	1	"
425	D-4.1	St. Merida @ Coronado	#22	1	"
426	D-4.1	Afton @ Coronado	#17, 18	2	"
427	D-4.1	Afton @ Southlawn	#15, 16	2	"
428	D-4.1	Saltillo @ Southlawn	#6, 7	2	"
429	D-3.2	Afton @ Madrid	#9	1	"
430	D-3.2	Saltillo @ Madrid	#5, 6	2	"
431	E-4.1	Menefee @ Aiken	#14	1	"
432	K-8.4	11400 Clamp	Service Valve	1	"
433	K-3.2	3555 Pitluk	---	1	Repair
434	L-6.1	W. Hutchins #23254	Service Valve	1	Raise to Grade
435	L-8.3	3800 Pleasanton	---	1	"
436	M-3.3	450 Ike	F.H. C	1	"
437	M-4.2	Pine Hollow @ Prairie Hill	---	1	Repair
438	O-1.3	Somerset @ Loop 410	#15	1	"
439	O-1.3	Somerset @ Loop 410	#16, 17, 18	3	Raise to Grade
440	O-4.2	10127 State Hwy 16	F.H. D	1	"

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 23 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
441	O-4.3	State Hwy 16	F.H. P #16	2	Raise to Grade
442	O-5.1	S.W. Loop 410	#2	1	"
443	O-5.2	S.W. Lop 410	F.H. D	1	Repair
444	O-6.1	Zarzamora @ S.W. Loop 410	#1, 2, 6, 8, 9, 10	6	Raise to Grade
445	P-(1.2)	IH35	F.H. W - M	2	"
446	P-(1.3)	Fisher Rd.	#7 F.H. J	2	"
447	O-11.1	Ruidosa @ Sanco	#28	1	"
448	O-11.1	Renova @ Sanco	#3	1	"
449	P-6.1	Zarzamora	#1 F.H. A	2	"
450	Q-0.1	Fisher Rd.	#6, 5, - F.H. H, G, F	5	"
451	Q-0.3	Somerset Rd.	F.H. EE	1	Repair
452	Q-0.4	12365 Fisher Rd.	F.H. E	1	Raise to Grade
453	Q-1.1	Somerset Rd.	F.H. BB	1	"
454	Q-1.4	Somerset Rd.	#22	1	Repair
455	SA-25.4	Somerset Rd.	#2	1	"
456	SB-24.3	Old Somerset Rd.	#3	1	"
457	SD-23.4	Somerset Rd.	#17	1	Raise to Grade
458	SD-23.4	Somerset Rd.	#18	1	"
459	SD-23.4	Somerset Rd.	#19	1	"
460	SE-23.4	Somerset Rd.	#23	1	"

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 24 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
461	SG-22.4	Somerset Rd.	#31	1	Raise to Grade
462	SH-21.2	Somerset Rd.	#32	1	Repair
463	SH-21.2	Somerset Rd.	F.H. B	1	Raise to Grade
464	SH-21.2	Somerset Rd. Pump Station	F.H. A, 1, 6	3	"
465	SH-21.3	1604 @ Somerset Rd.	F.H. F, 30, 21, 22, 23, 24, 17	7	"
466	SH-21.3	Lantana @ Somerset Rd.	#2	1	"
467	SH-21.3	Lantana @ 20' Easement	#13, F.H. C	2	"
468	SH-21.3	Somerset Rd. @ 1604	#7, 29	2	Repair
469	SH-21.4	K. Street across from 19475	#14	1	Raise to Grade
470	SH-21.4	Caruther @ K. Street	#1	2	"
471	SH-22.4	FM 1604 @ Quail Run	#1, 3, 4 Blow Off	4	"
472	SI-20.3	Clayton @ S. FM 2790	#1, 4	2	"
473	SI-21.1	Fourth St. @ Oil Street	#1	1	"
474	SI-21.1	James St. @ Oil Street	#5	1	"
475	SI-21.2	Fourth St. @ Somerset	#3	1	"
476	SI-21.3	7835 Touchstone St.	#1	1	"
477	SI-21.3	Barron @ W. Dixon	#3	1	"
478	SI-21.4	Kenney Ave.	#17	1	"
479	SI-21.4	Eighth St. @ Somerset	#2	1	"

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 25 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
480	SI-21.4	Eighth St. @ Pyron St.	#3	1	Raise to Grade
481	SI-21.4	Ninth St. @ Oil St.	#4	1	"
482	SI-21.4	Ninth St. @ Pyron	#6	1	"
483	SI-21.4	Somerset @ W. Dixon	#14	1	"
484	SI-21.4	W. Dixon @ Pyron	#10	1	"
485	CD-1	Foxhall @ Winston	#10	1	"
486	CD-1	115 Winston	#12	1	"
487	CD-2	Lockhill Selma @ Winston	#80	1	"
488	CD-2	Across from 2259 Military	#58	1	"
489	CD-2	2116 Military	#61	1	"
490	CD-2	Military @ West Ave.	#65	1	"
491	CD-2	Military @ Woodyew	#77	1	"
492	CD-2	Manton @ Lockhill Selma	#19	1	"
493	CD-2	Sunflower @ Lockhill Selma	#18 - Service Valve	2	"
494	CD-2	10126 Jandre Lane	#41	1	"
495	CD-3	Evening Sun @ Blanco Rd.	#42	1	"
496	CD-3	Spent Wing @ Blanco Rd.	#47	1	"
497	CD-3	M.T. Riga @ Blanco Rd.	#33, 34	2	"
498	CE-1	Hibiscus @ West Ave.	#6	1	"
499	CE-2	100 Zornia	#8	1	Repair
500	CE-2	Castleoak @ Roundup	#79	1	Raise to Grade

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 26 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
501	CE-2	Lemonwood @ Roletto	#59	1	Raise to Grade
502	CE-2	Lockhill Selma @ Prinz	#5	1	"
503	CE-3	Melissa @ Blanco Rd.	#32	1	"
504	CE-3	7203 Blanco Rd.	#51	1	"
505	CE-3	Lockhill Selma between Briarcliff & Northcrest	#10, 11, 17	3	"
506	CE-3	Homeric @ Lockhill Selma	#41	1	"
507	CF-1	Castleoak @ West Ave.	#10	1	"
508	CF-1	West Ave. @ Loop 410	#7	1	"
509	CF-2	Adobe @ Roundup	#3, 4	2	"
510	CF-2	1905 Loop 410	F.H. Z	1	"
511	CF-2	Loop 410 Honeysuckle	#9, 19, 20, 61	4	"
512	CF-2	Squires Row @ Loop 410	F.H. V	1	"
513	CF-2	Traventine @ Twinleaf	#26	1	"
514	CF-2	Sheffield @ Squires Row	#55	1	"
515	CF-2	Sir Arthur @ Oak Royal	#48, 51	2	"
516	CF-2	Wickford @ Oak Royal	#38, 39, 40	3	"
517	CF-3	York #18741	Service Valve	1	"
518	CF-3	York #22756	Service Valve	1	"
519	CF-3	207 Sir Arthur	Service Valve	1	"
520	CF-3	Loop 410 between Northcrest & Baltimore	#4	1	"

APPENDIX K

Edwards Underground Water District Valve Stack/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 27 of 27

Line #	Plat #	Address	Valve #	Number of Valves	Needed
521	CF-3	Loop 410 @ Blanco	F.H. A	1	Raise to Grade
522	CF-3	Blanco @ Cornwall	F.H. U, #11	2	"
523	CF-3	230 Lundblade	#63	1	"
524	CF-3	223 Warwick	#33	1	"
525	CF-3	Warwick @ Bamburgh	#16	1	"
526	CG-2	Jackson Keller @ Gladiola	#42	1	"
527	CG-2	Dandelion @ Traventine	#18	1	"
528	CG-2	Shalimar @ Bluet	#46	1	"
529	CG-2	Bluet @ Amerson	#45	1	"
530	CG-2	Jackson Keller @ Amreson	#61, 37, two service valves	4	"
531	CG-2	Flinstone	#39, 40	2	"
532	CG-3	Atwater @ Buckaroo	#6	1	"
533	CG-3	Blanco @ Herwick	#15	1	"
534	CG-3	Langton @ alley past York	#73	1	"

APPENDIX L

Edwards Underground Water District Meter Box/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 1 of 5

Line #	Plat #	Address	Needed
1	0-5.2	2114 S.W. Loop 410	Repair
2	0.8.3	10421 Moursund	Raise to Grade
3	N-8.2	503 Moursund	"
4	N-8.2	507 Moursund	"
5	N-6.3	1303 Strech St.	"
6	N-5.3	1843 Cassandra	Missing Box
7	M-8.1	8807 Topsey	Raise to Grade
8	M-8.1	8810 Topsey	"
9	M-7.4	775 Gillette	"
10	M-7.1	437 Ansley	"
11	M-7.1	435 Ansley	"
12	M-7.3	9110 Silver Arrow	"
13	M-7.3	9118 Silver Arrow	"
14	M-6.1	1414 Betty	"
15	M-6.1	1514 Betty	"
16	M-6.1	1518 Beverly Ann	"
17	M-6.1	1506 Beverly Ann	"
18	M-5.4	9014 Chaminade	"
19	M-5.1	2503 Pollote	"
20	M-5.1	2507 Gibbens	"
21	M-5.1	227 Abacus	"
22	M-4.1	3211 Fair Meadows	"

APPENDIX L

Edwards Underground Water District Meter Box/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 2 of 5

Line #	Plat #	Address	Needed
23	L-9.3	811 Saipan	Raise to Grade
24	L-9.2	535 Creath	"
25	L-9.2	531 Creath	"
26	L-8.4	8618 Garnett	"
27	L-8.3	215 Kopplow	"
28	L-7.3	347 W. Petaluma	"
29	L-7.3	343 W. Petaluma	"
30	L-7.3	8515 Ludtke	"
31	L-6.2	8206 Forsen Dr.	"
32	L-2.4	8750 U.S. Hwy 81	Repair
33	K-9.2	219 Parchman	Raise to Grade
34	K-8.4	403 Drury	"
35	K-8.4	222 W. Vestal	"
36	K-8.2	135 Sussex	"
37	K-8.2	139 Sussex	"
38	K-8.1	227 Sharmain	"
39	K-4.3	3007 Navajo	Reset Meter Box
40	J-9.2	205 E. Pyron	"
41	J-9.2	207 E. Pyron	"
42	J-9.2	219 E. Pyron	"
43	J-8.2	427 Kendalia	Missing Box
44	J-8.1	6726 Tupper	Broken Box

APPENDIX L

Edwards Underground Water District Meter Box/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 3 of 5

Line #	Plat #	Address	Needed
45	J-6.2	1147 Kendalia	Raise to Grade
46	J-5.1	882 W. Mayfield	"
47	J-7.4	79 Wagner Rd.	"
48	J-7.4	71 Wagner Rd.	"
49	I-6.4	1011 Whitman	"
50	I-6.3	311 Linden	"
51	I-6.2	215 Milvid	"
52	I-6.2	1024 W. Southcross	"
53	I-4.3	601 Lovett	"
54	H-6.4	663 Humboldt	Replace Meter Box
55	H-6.2	1421 Crystal	Raise to Grade
56	H-6.2	1309 Crystal	"
57	H-6.1	126 Hosack	"
58	F-5.3	2223 Jupiter	"
59	F-4.4	123 Ballard	"
60	F-4.4	102 Ballard	"
61	E-4.3	3122 Hatton	"
62	E-4.3	3123 W. Kirk	"
63	E-4.3	3119 W. Kirk	"
64	E-4.3	3115 W. Kirk	"
65	E-4.3	2618 Vyra	"
66	E-4.3	3031 Weir	"

APPENDIX L
Edwards Underground Water District
Meter Box/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 4 of 5

Line #	Plat #	Address	Needed
67	E-3.3	3759 Weir	Raise to Grade
68	D-5.4	1111 Barclay	"
69	D-5.1	1315 Merida	"
70	D-4.3	3015 Cumbre	"
71	D-4.3	706 Patton	"
72	D-4.2	219 Queretaro	"
73	D-4.1	216 Coronado	"
74	D-4.1	308 Coronado	"
75	D-3.3	1834 Romero	"
76	D-3.3	1835 Romero	"
77	D-3.2	1735 Madrid Ave.	"
78	D-3.2	323 Southlawn	"
79	D-5.4	1315 Merida	"
80	H-6.2	1221 Crystal	"
81	I-5.3	111 Berlin	"
82	I-7.1	206 Adolph	"
83	J-7.4	1055 Rayburn	"
84	J-7.4	1047 Rayburn	"
85	K-8.4	402 Drury	"
86	L-6.1	1527 Ackard	"
87	M-4.2	8914 Prairie Hill	"
88	M-4.2	8918 Prairie Hill	"

APPENDIX L

Edwards Underground Water District Meter Box/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 5 of 5

Line #	Plat #	Address	Needed
89	M-4.2	8922 Prairie Hill	Raise to Grade
90	M-8.2	159 Moursund	"
91	M-9.3	742 Bernard	"
92	N-8.2	445 Moursund	"
93	O-11.4	1702 Socorro	"
94	CE-1	6600 West Ave.	"
95	CE-2	206 East Castle	"
96	CE-2	101 Glen Tower	"
97	CE-3	301 Tamworth	"
98	CE-3	212 Northcrest	"
99	CF-1	104 Bluet Ln.	"
100	CF-1	112 Trillium Lane	"
101	CF-1	100 Honeysuckle	"
102	I-6.3	1442 Gerald	"
103	I-7.3	539 Gerald	"
104	J-6.2	1305 Kendalia	"
105	J-6.2	1235 Kendalia	"
106	J-6.3	1235 Rayburn	"
107	J-6.3	1307 Rayburn	"
108	J-6.3	1311 Rayburn	"
109	J-6.3	1323 Rayburn	"

APPENDIX M
Edwards Underground Water District
General/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 1 of 4

Line #	Date #	Address	Valve or Hydrant #	Type of Repair
1	N-4.4	3114 Aragon		Broken Curb Stop
2	N-8.1	503 W. Mally		"
3	N-9.1	Yukon @ Walhalla	F.H. B	Repairs
4	M-5.4	9027 Ozalid		Broken Curb Stop
5	M-6.4	9207 Silver Hill		"
6	M-6.4	9207 Silver Arrow		"
7	M-6.4	9200 Zarzamora		Broken Hand Wheel
8	M-6.4	9014 Perma Lane		Broken Curb Stop
9	M-5.4	2119 Bane Blvd.		"
10	M-6.4	9202 Planter Dr.		"
11	M-6.4	2210 Six Mile Dr.		"
12	M-6.4	2210 Abdo		"
13	L-8.4	8407 Garnett		Broken Meter Glass
14	L-6.4	1506 Rodrich		Broken Curb Stop
15	L-6.1	9319 Whitley		"
16	L-4.1	335 Iroquois		"
17	K-9.4	314 Ware		No Meter
18	K-6.4	1515 W. Vestal		Broken Curb Stop
19	K-5.1	---	F.H. D	Repair
20	K-5.1	Service #28298 Barlite		Broken Curb Stop
21	K-4.1	3107 Mac Arthur		Broken Meter Glass

APPENDIX M

Edwards Underground Water District
General/Repairs Needed
1992

System: Bexar Metropolitan Water DistrictPage 2 of 4

Line #	Date #	Address	Valve or Hydrant #	Type of Repair
22	J-9.2	216 Congress		Meter Repair
23	J-8.3	147 Shasta		"
24	J-8.2	422 W. Dickson		"
25	J-8.2	341 Kendalia		"
26	J-8.2	337 Kendalia		"
27	J-3.2	Parmly @ Carmel	F.H. I	Repair
28	I-7.2	510 W. Southcross		Broken Curb Stop
29	I-6.2	Berlin @ Huron	F.H. D	Missing Oil Plug
30	H-6.1	Ames @ Bloom	#21	Broken Stem on Valve
31	F-5.4	107 W. Greenway		Broken Curb Stop
32	F-4.2	Thompson @ Andy	#25	Valve Repair
33	F-4.2	526 Bedford	F.H. D	Hydrant Repair
34	E-4.2	1503 Brady	F.H. D	"
35	D-4.2	Morelia @ Cantoria	#28	Valve Stack Repair
36	F-4.3	107 Greenway		Broken Curb Stop
37	K-7.1	1123 Clovis		Repair
38	L-6.1	1603 Parnell		Broken Curb Stop
39	L-8.3	306 Saipan		Meter Repair
40	L-9.4	354 Saipan		Repair
41	M-3.2	2535 Fairmeadows		Broken Curb Stop
42	M-5.3	1926 Calais		"

APPENDIX M

Edwards Underground Water District General/Repairs Needed 1992

System: Bexar Metropolitan Water District

Page 3 of 4

Line #	Date #	Address	Valve or Hydrant #	Type of Repair
43	M-5.3	1943 Duluth		Broken Curb Stop
44	M-5.3	1935 Edenvale		"
45	N-4.1	3110 Coconino		Repair
46	N-4.1	3127 Chamita		"
47	N-4.1	3123 Chamita		"
48	N-7.1	907 Rockwell		Meter Repair
49	N-7.1	911 Rockwell		"
50	N-9.4	510 Tidewind		Broken Curb Stop
51	F-5.4	107 Greenway		"
52	J-7.2	836 Pyron		"
53	F-4.3	107 Greenway		"
54	D-3.2	135 Sylvia		Broken Registor
55	K-3.2	3262 Pitluk		Broken Curb Stop
56	L-4.1	219 Caddo		"
57	P-4.2	10851 Hwy 16		"
58	M-3.2	8919 Palm Crest		"
59	N-4.4	3122 Aragon		"
60	N-4.4	3126 Aragon		"
61	M-4.1	360 Wainwright		"
62	M-5.4	9209 Planter		"
63	M-3.4	2222 Six Mile		"

APPENDIX M
Edwards Underground Water District
General/Repairs Needed
1992

System: Bexar Metropolitan Water District

Page 4 of 4

Line #	Date #	Address	Valve or Hydrant #	Type of Repair
64	M-5.3	1950 Duluth		Broken Curb Stop
65	M-5.3	1922 Edenvale		"
66	K-7.4	939 Drury		"
67	M-9.3	9222 Yett		"
68	M-8.3	326 Moursund		"
69	SI-21.1	8021 N. Dixon		No Meter
70	SI-21.4	8175 W. Dixon		Broken Curb Stop
71	CE-1	204 Hibiscus		Main Exposed
72	CE-2	Zornia @ Wisteria		Valve Lid Marked Gas
73	CE-2	219 Northcrest		Meter repair
74	CD-2	1338 Grey Oak		Curb Stop Frozen

APPENDIX N

Edwards Underground Water District Curb Stops Not Holding 1992

System: Bexar Metropolitan Water District

Page 1 of 3

Line #	Plat #	Address
1	J-4.4	346 Briggs
2	K-4.1	3027 Pitluk
3	K-4.3	114 Pima
4	K-4.4	204 Pima
5	K-4.3	2714 Navajo
6	K-5.4	2623 Sleepy Glade
7	N-4.2	121 Vincent
8	M-4.3	115 Spaatz
9	M-3.2	8907 Long Branch
10	M-3.2	8910 Oletha
11	M-3.2	3402 Fair Meadows
12	N-6.1	1522 Caballero
13	K-4.3	111 Hopi
14	K-6.4	1515 W. Vestal
15	O-5.2	2114 S.W. Loop 410
16	M-5.1	9011 Niner
17	M-5.4	9023 Niner
18	M-5.4	2302 Six Mile
19	L-7.3	3541 Commercial
20	K-7.4	926 W. Vestal
21	K-6.3	1227 W. Vestal
22	K-7.1	1202 Clovis

APPENDIX N
Edwards Underground Water District
Curb Stops Not Holding
1992

System: Bexar Metropolitan Water District

Page 2 of 3

Line #	Plat #	Address
23	K-7.2	614 Sunglo
24	L-10.4	8506 Barranca
25	K-8.4	502 W. Vestal
26	L-8.1	8115 Oppenheimer
27	I-6.1	1336 Harlan
28	I-6.1	710 Berlin
29	H-7.2	823 Keats
30	J-3.2	970 Brighton
31	J-5.2	687 McLaughlin
32	J-5.2	816 W. Mayfield
33	I-4.2	2532 Southcross
34	H-7.1	1110 Chalmers
35	E-4.1	Gen. McMullen @ Hwy 90
36	F-5.4	106 Pletz
37	I-3.3	1927 W. Mayfield
38	I-3.3	8524 Johnson
39	E-4.4	3631 Weir
40	SF-21.1	19774 Tammy Kay
41	P-4.3	2806 Rosebaum
42	D-4.3	103 Piegan
43	D-5.1	111 Queretaro
44	J-8.1	711 W. Pyron

APPENDIX N
Edwards Underground Water District
Curb Stops Not Holding
1992

System: Bexar Metropolitan Water District

Page 3 of 3

Line #	Plat #	Address
45	J-9.1	113 E. Bonner
46	SI-21.1	19921 Somerset
47	CE-2	109 Gardenvue
48	CF-2	145 Twinleaf

APPENDIX O

Edwards Underground Water District Curb Stops Partly Open 1992

System: Bexar Metropolitan Water District

Page 1 of 6

<u>Line #</u>	<u>Plat #</u>	<u>Address</u>
1	E-3.4	3910 Carnation
2	E-3.4	3826 Bay
3	F-5.2	3115 Venus
4	H-6.3	426 Elks
5	H-6.4	1440 Flanders
6	H-6.4	1346 Stonewall
7	I-5.3	1310 Whitman
8	I-6.3	314 Linden
9	I-7.1	1026 Brunswick
10	I-7.2	835 Brunswick
11	I-7.3	387 Rosebud
12	I-7.4	2242 Buffalo
13	I-7.4	6207 Macdona
14	J-3.2	850 Price
15	J-5.1	1827 Kendalia
16	J-7.1	1202 Pyron
17	J-7.4	1018 Rayburn
18	K-7.1	1139 Sharmain
19	K-7.1	330 Escalon
20	K-7.2	714 Sunglo
21	K-7.2	1030 W. Harding
22	K-7.2	519 Clovis

APPENDIX O
Edwards Underground Water District
Curb Stops Partly Open
1992

System: Bexar Metropolitan Water District

Page 2 of 6

Line #	Plat #	Address
23	K-7.3	515 W. Vestal
24	K-8.4	430-1/2 Aaron
25	K-9.1	311 Sussex
26	L-6.1	1442 Peterson
27	L-6.1	1422 Peterson
28	L-6.2	1331 W. Hutchins
29	L-6.3	8707 Wilma Jean
30	L-7.1	1215 Formosa
31	L-7.2	8711 Honora
32	L-8.4	303 W. Petaluma
33	L-8.4	1950 Clamp
34	M-4.2	8923 Gernander
35	M-5.1	2522 Pollote
36	M-5.1	2215 Abacus
37	M-5.2	1934 Ann Arbor
38	M-5.3	9151 Lytle
39	M-5.3	1943 Hunter Blvd.
40	M-5.3	1946 Hunter Blvd.
41	M-5.3	1926 Calais
42	M-5.3	1910 Duluth
43	M-5.3	1947 Duluth
44	M-5.4	2115 Bane Blvd.

APPENDIX O
Edwards Underground Water District
Curb Stops Partly Open
1992

System: Bexar Metropolitan Water District

Page 3 of 6

<u>Line #</u>	<u>Plat #</u>	<u>Address</u>
45	M-5.4	2114 Henrietta
46	M-5.4	2134 Henrietta
47	M-5.4	2130 Henrietta
48	M-6.1	1726 Ann Arbor
49	M-6.1	1722 Ann Arbor
50	M-6.1	1714 Ann Arbor
51	M-6.1	1562 Beverly Ann
52	M-6.1	1400 Betty
53	M-6.1	1503 Hunter Blvd.
54	M-6.2	9051 Geraldine
55	M-6.3	642 Rockwell
56	M-6.3	Lot 55 Edris St.
57	M-6.4	1730 Point West
58	M-6.4	1726 Point West
59	M-6.4	1731 Point West
60	M-6.4	1727 Point West
61	M-6.4	9231 Silver Hill
62	M-7.4	9118 Hugo Circle
63	M-7.4	934 W. Baetz
64	M-7.4	1114 Faulk
65	M-9.3	9114 Yett
66	M-9.3	9210 Yett

APPENDIX O

Edwards Underground Water District Curb Stops Partly Open 1992

System: Bexar Metropolitan Water District

Page 4 of 6

Line #	Plat #	Address
67	M-9.3	9211 Yett
68	M-9.3	9314 Yett
69	M-9.3	806 Sams
70	M-9.4	258 E. Baetz
71	M-9.4	9223 Brink
72	M-9.4	9222 Walhalla
73	M-9.4	9303 Walhalla
74	M-10.4	1040 Sams
75	M-10.4	906 Bernard
76	N-4.1	402 Tedder
77	N-5.2	9411 Cadiz
78	N-6.1	9310 Cerro-Verde
79	N-6.2	1434 Caballero
80	N-6.2	9410 Hindi
81	N-6.2	9414 Hindi
82	N-8.3	4509 Pleasanton
83	N-8.3	434 E. Villaret
84	N-8.3	506 E. Villaret
85	N-9.1	434 Wimberly
86	N-9.1	510 Pinehurst
87	N-9.1.	538 E. Villaret
88	O-11.4	1507 Socorro

APPENDIX O
Edwards Underground Water District
Curb Stops Partly Open
1992

System: Bexar Metropolitan Water District

Page 5 of 6

Line #	Plat #	Address
89	O-11.4	1515 Socorro
90	O-11.4	1522 San Acacia
91	N-6.1	234 Cayo
92	M-5.4	2110 Hunter
93	M-5.4	2130 Hunter
94	M-5.3	1942 Edenvale
95	M-5.4	2110 Bane
96	M-4.2	2622 Gibbens
97	N-6.1	1518 Caballero
98	M-6.1	1546 Betty
99	L-7.4	8314 Charger
100	L-7.4	8320 Charger
101	K-7.4	939 Drury
102	K-6.3	1227 Cantrell
103	K-6.3	1335 Cantrell
104	K-7.3	536 Cantrell
105	K-6.3	1311 Aaron
106	K-7.1	930 Sunglo
107	K-7.2	1006 W. Harding
108	M-8.3	235 Beam
109	M-8.3	222 Myrick
110	L-9.3	815 Dodic

APPENDIX O
Edwards Underground Water District
Curb Stops Partly Open
1992

System: Bexar Metropolitan Water District

Page 6 of 6

Line #	Plat #	Address
111	CE-3	213 Northcrest
112	CF-3	219 Warwick

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 1 of 22

Line #	Plat #	Address	Valve #	# of Valves
1	R-11.1	U.S. Hwy 281	#2, 3	2
2	P-10.2	U.S. Hwy 281	F.H. B	1
3	P-5.4	---	#3	3
4	P-4.4	Gaylord @ Woodsage	#1	1
5	P-4.4	State Hwy 16	#23	1
6	P-4.1	Moss Springs @ Claymore	#11, 12, 13, 14	4
7	P-4.1	Musket @ Durette	#7	1
8	O-10.3	U.S. Hwy 281 @ Socorro	#1	1
9	O-10.3	U.S. Hwy @ San Acacia	#3	1
10	O-10.3	U.S. Hwy @ Estancia	#4	1
11	O-10.3	U.S. Hwy @ Sava	#7, #6	2
12	O-10.3	U.S. Hwy @ Sava	F.H. F	1
13	O-10.2	U.S. Hwy @ Sanez	#11	1
14	O-8.1	S.W. Loop 410	#1, F.H. A	2
15	O-7.2	S.W. Loop 410	F.H. A, 1, 3	3
16	O-7.1	S.W. Loop 410	F.H. A	1
17	O-5.2	S.W. Loop 410	#5	1
18	O-5.1	S.W. Loop 410	#1	1
19	N-10.3	5345 U.S. Hwy 281	#5	1
20	N-10.3	E. Chavaneaux @ Hwy 281	#2	1
21	N-9.3	E. Chavaneaux	#6, 8	2
22	N-9.2	E. Mally @ Yett	#3, 4, 5, 6	4

APPENDIX P
Edwards Underground Water District
Valve Stack/Cleaning Needed
1992

System: Bexar Metropolitan Water District

Page 2 of 22

Line #	Plat #	Address	Valve #	# of Valves
23	N-9.2	546 Pinehurst	#7	1
24	N-8.3	Tidewind @ Pleasanton	#9	1
25	N-8.2	E. Mally @ Pleasanton	#3	1
26	N-8.2	Pinehurst @ Pleasanton	#8	1
27	N-8.2	E. Villaret @ Pleasanton	#10	1
28	N-8.1	Garnett @ W. Villaret	#4, 11	2
29	N-7.2	Commercial @ W. Mally	#2, 4, 11	3
30	N-7.2	Commercial @ W. Villaret	#7, 8, 9	3
31	N-7.1	Edris @ Rockwell	#6	1
32	N-7.1	W. Mally @ Earth	#7	1
33	N-6.4	Ursula @ Jennifer	#3	1
34	N-6.4	Veronica @ Jennifer	#5	1
35	N-6.4	Jennifer @ Zarzarmora	#7	1
36	N-6.4	W. Chavaneaux @ Zarzamora	#15	1
37	N-6.1	W. Mally @ Zarzamora	#4, 12	2
38	N-6.1	W. Mally @ Cerro-Verde	#5	1
39	N-6.1	Cayo @ Zarzamora	#3	1
40	N-5.2	Bruni @ Lytle	#7	1
41	N-5.3	Cassandra @ Rhonda	#1	1
42	N-4.4	Reforma @ Celeste	#12, 23, 15	3
43	N-4.4	Chamita @ Manzano	#4	1
44	N-4.3	Chamita @ Wikieup	#7	1

APPENDIX P

Edwards Underground Water District
Valve Stack/Cleaning Needed
1992

System: Bexar Metropolitan Water DistrictPage 3 of 22

Line #	Plat #	Address	Valve #	# of Valves
45	N-4.3	Reforma @ State Hwy. 346	#12	1
46	N-4.2	Ike @ Palo Alto	#4	1
47	N-4.2	Palo Alto @ W. Villaret	F.H. N	1
48	N-4.2	State Hwy 346 @ Villaret	F.H. I	1
49	N-4.2	W. Mally @ State Hwy 346	#12, 1	2
50	N-4.2	Tedder @ Palo Alto	#30, 31	2
51	N-4.1	Tedder @ Palo Alto	#21	1
52	N-4.1	Vincent @ Palo Alto	#16, 12	2
53	N-4.1	Losswell @ Coconino	#8	1
54	N-4.1	Coconino @ Questa	#10	1
55	N-4.1	Ike @ Kreuger	#28, 29	2
56	N-3.2	Maria Isabel @ Algo Dulce	#3	1
57	M-10.4	1038 Sams	#7	1
58	M-9.4	Felps @ Walhalla	#4, 56	3
59	M-9.4	Lanier @ Walhalla	#2	1
60	M-9.4 M-9.2	Emmett @ Bascum	#9	1
61	M-9.1	Ashley @ Yett Ave.	#3	1
62	M-8.4	Garnett @ Baetz	#11	1
63	M-8.4	Garnett @ Gillette	#3, 4, 10	3
64	M-8.3	Pleasanton @ Felps	#10, 9	2
65	M-8.3	Pleasanton @ Myrick	#12	1

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 4 of 22

Line #	Plat #	Address	Valve #	# of Valves
66	M-8.3	Baetz @ Moursund	#3	1
67	M-8.2	Moursund @ E. Aviation	#5, 6	2
68	M-8.2	E. Ansley @ Braburn	#13	1
69	M-8.1	Garnett @ Ansley	#8	1
70	M-7.4	Baetz @ Escalon	#7, 6, 17	3
71	M-7.4	Escalon @ Gillette	#4, 9, 14, 15, 16	5
72	M-7.4	1134 Faulk	#11	1
73	M-7.3	Gillette @ Commercial	#10, 4	2
74	M-7.3	Gillette @ Burton	#7	1
75	M-7.1	Escalon @ Shemya	#5	1
76	M-7.1	Escalon @ W. Ansley	#1, 2	2
77	M-6.4	Hunter @ Silver Arrow	#9, 10	2
78	M-6.4	Zarzamora @ Gillette	#19, 20	2
79	M-6.3	1404 Hunter	#5	1
80	M-6.3	915 Gillette	#15	1
81	M-6.2	Hunter @ Rockwell	#1	1
82	M-6.1	1542 W. Ansley	#17	1
83	M-6.1	Zarzamora @ Beverly Ann	#9	1
84	M-6.1	Zarzamora @ Betty	#10	1
85	M-6.1	Zarzamora @ Hunter	#3, 6	2
86	M-5.4	Hunter @ Oswald	#12	1

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 5 of 22

Line #	Plat #	Address	Valve #	# of Valves
87	M-5.4	Hunter @ Buda	#4	1
88	M-5.4	Ozwald @ Six Mile	#8	1
89	M-5.4	Planter Dr. @ Gillette	#7	1
90	M-5.3	Hunter @ Lytle	#15	1
91	M-5.3	Calais @ Lytle	#16	1
92	M-5.3	Rhoda @ Gillette	#2, 5, 6	3
93	M-5.3	Edenvale @ Rhoda	#7	1
94	M-5.3	Rhoda @ tank site	#28, 30	2
95	M-5.3	Calais @ Rhoda	#9	1
96	M-5.2	Ann Arbor @ Rhoda	#2, 7	2
97	M-5.2	Ann Arbor @ Lytle	#4	1
98	M-5.2	Hunter @ Rhoda	#12	1
99	M-5.1	Tortuga @ Ozalid	#10	1
100	M-5.1	Abacus @ Ozalid	#7	1
101	M-5.1	Niner @ Abacus	#6	1
102	M-5.1	Perma @ Abacus	#4	1
103	M-4.4	Doolittle @ Lasswell	#4, 5, 8	3
104	M-4.4	Bradley @ Kreuger	#18	1
105	M-4.3	Lawley @ Wainwright	#7, 8	2
106	M-4.3	Lawley @ Spaatz	#10	1
107	M-4.3	Lawley @ Doolittle	#11	1
108	M-4.3	Palo Alto @ Doolittle	#6, 29	2

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 6 of 22

Line #	Plat #	Address	Valve #	# of Valves
109	M-4.2	Prairie Hill @ Fair Meadows	#4	1
110	M-4.2	Prairie Hill @ Fort Parker	#7	1
111	M-4.2	Palo Alto @ Hunter	#11	1
112	M-4.2	Gibbens @ Gernander	#15	1
113	M-4.2	Tortuga @ Hwy 346	#12	1
114	M-4.1	Pine Hollow @ Dunaway	#13	1
115	M-4.1	3302 Fair Meadows	#20, 21	2
116	M-3.3	3740 Remigio St.	F.H. A	1
117	M-3.2	IH 35 @ Palm Beach	#33, 34	2
118	M-3.2	Fair Meadows @ Somerset	F.H. G	1
119	M-3.2	Fair Meadows	#17	1
120	M-3.2	Fair Meadows @ Oletha	#3, 4	2
121	M-3.2	Lowland @ Oletha	#6	1
122	M-3.1	IH 35	F.H. B, A	2
123	L-10.4	Barranca @ Petaluma	#6	1
124	L-9.3	Bascum @ E. Petaluma	#7	1
125	L-9.3	Bascum @ Deely	#9	1
126	L-9.2	Creath @ Chaucer	#8	1
127	L-9.2	E. Formosa @ Fournier	#14, 12	2
128	L-9.1	Oxana @ E. Amber	#1, 14	2
129	L-9.1	Creath @ Walhalla	#5	1
130	L-8.4	Garnett @ W. Petaluma	#15	1

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 7 of 22

Line #	Plat #	Address	Valve #	# of Valves
131	L-8.4	Garnett @ Pike Ridge	#12	1
132	L-8.4	Garnett @ Hopkins	#4	1
133	L-8.1	W. Hopkins @ Mango	#1	1
134	L-7.4	Escalon @ Petaluma	#6, 8, 10	3
135	L-7.2	W. Hutchins @ Commercial	#2, 5, 11, 13, 15	5
136	L-7.2	Burton @ Ackard	#24	1
137	L-7.2	Commercial @ W. Formosa	#16	1
138	L-7.1	1027 Hutchins tank	#8, 9	2
139	L-6.2	Amber @ Cullin	#17, 18, 20	3
140	L-6.1	W. Hutchins @ Crenshaw	#13	1
141	L-6.1	W. Hutchins @ Zarzamora	#2, 3, 11, 32, 33, 34	6
142	L-6.1	Zarzamora	#37	1
143	L-6.1	Ackard @ Kingley	#24	1
144	L-6.1	Ackard @ Manoway	#38	1
145	L-6.1	Crenshaw @ Parnell	#6, 14	2
146	L-6.1	Rodrick @ Whitley	#29, 30, 35	3
147	L-5.1	Barlite @ IH 35	#9	1
148	L-4.3	Patron @ Hwy 346	#1, 3	2
149	L-4.2	Palo Alto @ Owasso	#9	1
150	K-9.3	Ware @ S. Flores	#1	1
151	K-9.1	Sussex @ Briar	#9	1

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 8 of 22

Line #	Plat #	Address	Valve #	# of Valves
152	K-9.1	Sussex @ Norma	#11, 4	2
153	K-9.1	Shire @ Norma	#1	1
154	K-8.4	Aaron @ Garnett	#10	1
155	K-8.3	222 Ware	#21	1
156	K-8.3	Gladnell @ E. Hutchins	#23	1
157	K-8.2	Sharmain @ Pleasanton	#17, 9	2
158	K-8.2	Sunglo @ Pleasanton	#26	1
159	K-7.3	Burton @ Cantrell	#6, 9	2
160	K-7.3	Commercial @ Cantrell	#15, 21	2
161	K-7.2	Sharmain @ Altura	F.H. R	1
162	K-7.2	Sunglo @ Commercial	#19, 20, 21 22	4
163	K-7.2	Clovis @ Burton	#30	1
164	K-7.1	Logwood @ Sunglo	F.H. I, 28, 17, 29	4
165	K-7.1	Logwood @ Clovis	F.H. J, 24	2
166	K-7.1	Sunglo @ Tacoma	#20	1
167	K-7.1	W. Harding @ Escalon	#4	1
168	K-6.4	Zarzamora @ W. Vestal	#7	1
169	K-6.3	Cantrell	#18, 19	2
170	K-6.3	Cantrell @ East Aviation	#17	1
171	K-6.3	W. Vestal @ Hilton	#21, 24, 25, 26, 27	5

APPENDIX P

Edwards Underground Water District
Valve Stack/Cleaning Needed
1992

System: Bexar Metropolitan Water DistrictPage 9 of 22

Line #	Plat #	Address	Valve #	# of Valves
172	K-6.3	Cullin @ Aaron	#20	1
173	K-5.4	Navajo @ Niagra	#6	1
174	K-5.4	Navajo @ Barlite	#5	1
175	K-5.4	Navajo @ IH 35	#19	1
176	K-6.1	Zarzamora	#11, 12	2
177	K-5.3	Hwy 81	#5	1
178	K-5.3	Cantrell @ Delight	#1	1
179	K-5.3	Delight	#2, 3	2
180	K-5.1	---	#8	1
181	K-4.4	Somerset @ Navajo	#12	1
182	K-4.4	7823 Somerset	#7	1
183	K-4.3	Navajo @ Palo Alto	#20	1
184	K-4.3	Navajo @ Kindred	#10, 7	2
185	K-4.2	Somerset @ Cree	#?	1
186	K-4.2	Somerset @ Pitluk	#28, 30, F.H. K	3
187	K-4.2	Sioux @ Palo Alto	#7, service valve	2
188	K-4.2	Sioux @ Somerset	#13, 14, 32	3
189	K-4.1	3114 MacArthur	#52	1
190	K-4.1	La Violetta @ Anapola	#37	1
191	K-4.1	La Violetta @ Albren	#27	1
192	K-3.2	La Violetta @ Baecke	#12	1

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 10 of 22

Line #	Plat #	Address	Valve #	# of Valves
193	J-9.4	S.W. Military @ Norma	#3, 7, 8	3
194	J-9.4	Behind 192 Dickson	F.H. B	1
195	J-9.3	S. Flores @ Dickson	#17	1
196	J-9.3	S. Flores @ S.W. Military	Service Valve	1
197	J-9.3	E. Dickson @ Trenton	#2, 3	2
198	J-9.1	W. Pyron @ S. Flores	#26, 27, 28, 29, 2	5
199	J-9.1	235 Dickson	#24	1
200	J-9.1	Wiggins @ S. Flores	#26	1
201	J-9.1	Kendalia @ Boswell	#28, 33	
202	J-9.1	Harold @ Dickson	#20, 21, 23	3
203	J-8.4	S.W. Military @ Clamp	#29, 30, 31	3
204	J-8.3	Pleasanton Rd.	#23, 24, 25, 26, 27	5
205	J-8.3	Pleasanton @ S.W. Military	#19	1
206	J-8.3	Pleasanton @ Verne	#5	1
207	J-8.3	Pleasanton @ Grosvenor	#1	1
208	J-8.2	Pleasanton @ McCauley	#2, 10, 8	3
209	J-8.2	Kendalia @ Endicott	#17	1
210	J-8.2	Mayfield @ Boswell	#31, 30	2
211	J-8.2	Mayfield @ Pleasanton	#5, 27, 29	3
212	J-8.1	Tupper @ Kendalia	#25	1
213	J-8.1	Garnett @ Kendalia	#24	1

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 11 of 22

<u>Line #</u>	<u>Plat #</u>	<u>Address</u>	<u>Valve #</u>	<u># of Valves</u>
214	J-7.4	1603 S.W. Military	Service Valve	1
215	J-7.3	Commercial @ Rayburn	#14	
216	J-7.3	Grosvenor @ Burton	#3	
217	J-7.2	W. Mayfield @ Commercial	#23	1
218	J-7.2	McCauley @ Commercial	#14	1
219	J-7.1	330 W. Mayfield	#31, F.H. M	2
220	J-6.4	S.W. Military @ Zarzamora	#3	1
221	J-6.2	McCauley @ IH 35	#8	1
222	J-6.2	Kendalia @ Ascott	#2	1
223	J-6.1	W. Pyron @ Zarzamora	#4	1
224	J-6.1	W. Pyron @ Kyle	#16	1
225	J-5.4	Barlite @ S.W. Military	#6, 3, 5	3
226	J-5.2	Mallard @ W. Pyron	#17	1
227	J-5.2	Otto @ alley between Kendalia and McCauley	#19, 20	2
228	J-5.2	McCauley @ Cassin	#2	1
229	J-5.1	King Ave. @ Somerset	#11, 28	2
230	J-4.2	Price @ Kelsey	#18	1
231	J-4.1	Fenfield @ Bynum	#7, 21	2
232	J-4.1	Lindeman @ Fenfield	#8, 31	2
233	J-4.1	U.S. Hwy 81 @ Price	#26	1
234	J-3.4	Briggs @ Yvonne	#6, F.H. D	2

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 12 of 22

Line #	Plat #	Address	Valve #	# of Valves
235	J-3.3	Bynum @ U.S. Hwy 81	#7, 8, 28	3
236	J-3.2	Quintana @ Fenfield	#24	1
237	J-3.2	Holder @ McLaughlin	#29	1
238	J-3.1	Quintana @ McLaughlin	#2, 3, 4	3
239	I-8.4	Gerald @ Topper	#8, 9	2
240	I-8.4	219-215 Gerald	Service Valve	1
241	I-8.3	122 Rosebud	#3	1
242	I-8.1	Canavan @ Bodic	#27	1
243	I-8.1	Canavan @ Tobar	#5	1
244	I-7.4	Vickers @ Shelby	#24, 26	2
245	I-7.4	Gerald @ Whitman	#16	1
246	I-7.4	Shelby @ Whitman	#13	1
247	I-7.4	152 Rosebud	F.H. G	1
248	I-7.3	Burcham @ Noble	#10	1
249	I-7.3	Gerald @ Noble	#4	1
250	I-7.2	Brunswick @ IH 35	#12, F.H. I	2
251	I-7.2	Fitch @ Bruhn	#26	1
252	I-7.1	Fitch @ Bauer	#13, 14	2
253	I-7.1	Fitch @ IH 35	#10	1
254	I-7.1	Macdona	Blow Off 22	1
255	I-7.1	W. Southcross @ Shelby	#4	1
256	I-7.1	W. Southcross @ Buffalo	#18, 26	3

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 13 of 22

Line #	Plat #	Address	Valve #	# of Valves
257	J-6.4	Votaw @ Gerald	#10	1
258	J-6.4	Zarzamora @ Wagner	#24	1
259	J-6.4	Kyle @ Whitman	#23	1
260	I-6.3	Linden @ Lardner	#14	1
261	I-6.3	Linden @ Ella	#38	1
262	I-6.3	Vickers @ Huron	#19, 41	2
263	I-6.3	Gerald @ Ella	#36, 35	2
264	I-6.3	Wagner @ Lardner	#32, 26	2
265	I-6.3	Whitman @ Lardner	#1	1
266	I-6.3	Whitman @ Lenard	#30, 31	2
267	I-6.3	Whitman @ Huron	#27, 12	2
268	I-6.2	Brunswick @ Huron	#11	1
269	I-6.2	Fitch @ Huron	#18, 23	2
270	I-6.2	W. Southcross @ Lardner	#9	1
271	I-6.2	W. Southcross @ Ella	#22, 24	2
272	I-6.2	W. Southcross @ Huron	#28	1
273	I-6.2	Collier Elem. @ Southcross	#1, Service Valve	2
274	I-6.1	Brunswick @ Packard	#25, 32	2
275	I-6.1	Fitch @ Kyle	#31	1
276	I-6.1	Milvid @ Kyle	#34	1
277	I-5.4	Somerset @ Lovett	#1	1

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 14 of 22

Line #	Plat #	Address	Valve #	# of Valves
278	I-5.4	Peabody @ Rankin	#10, 11	2
279	I-5.3	Somerset @ Linden	#1	1
280	I-5.3	Somerset @ Vickers	#5, 25, 26	3
281	I-5.3	Somerset @ Gerald	#3, 9	2
282	I-5.3	Wagner @ Mallard	#18	1
283	I-5.3	Wagner @ railroad tracks	#19	1
284	I-5.3	Whitman @ Otto	#4, 12	2
285	I-5.2	134 Fay Ave.	#24	1
286	I-5.2	W. Southcross @ Somerset	#5, 28, 7, 8, 9, 11	6
287	I-4.4	Lovett @ Spindle	#66, 67	2
288	I-4.4	Lovett @ Lindeman	#68	1
289	I-4.4	Peabody @ Spindle	#59	1
290	I-4.4	Between Peabody & Kings Ave. @ Bynum	#19	1
291	I-4.3	Gerald @ Creighton	#40	1
292	I-4.3	Between Gerald and Lovett @ Oregon	#23	1
293	I-4.3	Lovett @ Fleming	#8, 20, 33	3
294	I-4.3	Gerald @ Creighton	#41	1
295	I-4.2	Southcross @ Creighton	#27	1
296	I-4.2	Between Wilcox @ W. Southcross @ Pierian	#8, 3	2
297	I-4.2	W. Southcross @ Pierian	#31, 32	2

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 15 of 22

Line #	Plat #	Address	Valve #	# of Valves
298	I-4.1	Between Baker and Fay @ Crittendon	#1	1
299	I-4.1	Fay @ Crittendon	#36	1
300	I-4.1	Between Hollenbeck and Southcross @ Quintana	#29	1
301	I-4.1	Between Hollenbeck and Southcross @ Crittendon	#20, 21	2
302	I-4.1	2635 W. Southcross	Service Valve #35	1
303	I-4.1	Between W. Southcross and Wilcox @ Quintana	#43	1
304	I-4.1	Between W. Southcross and Wilcox @ Crittendon	#23	1
305	I-4.1	Between Wilcox and Gerald @ Quintana	#12	1
306	I-3.3	Holden @ W. Mayfield	#21	1
307	I-8.4	Donegan @ Harlan	#10	1
308	H-7.4	Elks @ Ferndale	#26	1
309	H-7.4	Humboldt @ Buffalo	#15, 60, 61	3
310	H-7.4	Harlan @ Buffalo	#22, 25, 38	3
311	H-7.3	Brighton @ Commercial	#7	1
312	H-7.3	Stonewall @ Commercial	#32, 33	2
313	H-7.3	Stonewall @ IH 35	#39, 40	2
314	H-7.2	Division @ Commercial	#14	1
315	H-7.2	Vermont @ Commercial	#15	1

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 16 of 22

Line #	Plat #	Address	Valve #	# of Valves
316	H-7.2	Vermont @ Bruhn	#17	1
317	H-7.2	Crystal @ Commercial	#7, 8, 18, 9	4
318	H-7.2	Crystal @ IH 35	#24	1
319	H-7.2	Keats @ IH 35	#2	1
320	H-7.1	Orey @ alley between Carlisle and Division	#6	1
321	H-7.1	Buffalo @ Division	#7	1
322	H-7.1	Buffalo @ Vermont	#13, 14	2
323	H-7.1	Chalmers @ Ferndale	#9	1
324	H-6.4	1518 Stonewall	#46	1
325	H-6.4	Somerset @ Humboldt	#35	1
326	H-6.4	Zarzamora @ Humboldt	#50	1
327	H-6.4	Zarzamora @ Stonewall	#7, 16	2
328	H-6.4	Zarzamora @ Elks	#5	1
329	H-6.4	Zarzamora @ Flanders	#13	1
330	H-6.4	Brighton @ Nogalitos	#26	1
331	H-6.4	Stonewall @ Packard	#6, 19	2
332	H-6.4	Humboldt @ Packard	#52	1
333	H-6.3	Elks @ Huron	#18	1
334	H-6.3	Stonewall @ Huron	#51	1
335	H-6.2	Ferndale @ Division	#2, 46	3
336	H-6.2	Vermont @ Huron	#7, 6	2

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 17 of 22

Line #	Plat #	Address	Valve #	# of Valves
337	H-6.2	Ferndale @ Chalmers	#9	1
338	H-6.2	Ferndale @ Keats	#15	1
339	H-6.1	Keats @ Packard	#17, 18	2
340	H-6.1	Nogalitos @ Chalmers	#74	1
341	H-6.1	Nogalitos @ Vermont	#7	1
342	H-5.2	Centennial	#6, F.H. A	2
343	H-4.4	1515 Quintana	#9	1
344	H-4.4	1523 Quintana	F.H. C	1
345	H-4.3	1507 Quintana	#3	1
346	G-7.4	Carlisle @ Rudy	#2, 4, 5	3
347	G-7.3	Carlisle @ Commercial	#3, 6, 7	3
348	G-4.2	Cupples @ Quintana	#1	1
349	G-4.2	154 Querida	#4	1
350	F-6.1	710 Kirk	#2, 3, 4, 12, 13	5
351	F-6.1	Kirk @ Carolyn	#18	1
352	F-3.4	2710 Roselawn	#12	1
353	F-3.4	W. Jewel @ Brentwood	F.H. E	1
354	F-3.4	W. Emerson @ Brentwood	F.H. D	1
355	F-5.3	Jupiter @ Saturn	#14	1
356	F-5.1	Village Pl. between Academy and Bedford	#8	1
357	F-4.4	Roselawn @ Summerhill	#6	1

APPENDIX P
Edwards Underground Water District
Valve Stack/Cleaning Needed
1992

System: Bexar Metropolitan Water District

Page 18 of 22

Line #	Plat #	Address	Valve #	# of Valves
358	F-4.4	Marlowe @ Nightingale	#10	1
359	F-4.4	126 Marlowe	#11	1
360	F-4.3	Roselawn @ Cupples	#12, 14	2
361	F-4.3	Roselawn - Service #29702	Service Valve	1
362	F-4.2	1160 Cupples	Service Valve #22	1
363	F-4.2	Thompson @ Cupples	#1, 16	2
364	F-4.2	Cupples between Thompson and Academy	#5	1
365	F-4.2	Academy @ Cupples	#7, 8	2
366	F-4.2	Bedford @ Cupples	#12	1
367	F-4.2	Academy @ S.W. 28th St.	#8, 14	2
368	F-4.1	Thompson @ Gen. McMullen	#12, 3	2
369	F-4.1	Chesley @ Gen. McMullen	#10	1
370	F-3.3	Felton @ Imperial	#5	1
371	F-3.2	Allendale @ Imperial	#4, 5	2
372	F-3.2	Chesley @ Imperial	#2	1
373	E-5.4	Barclay @ W. Kirk	#19	1
374	E-5.4	S.W. 21st St. @ W. Kirk	#21, 5	2
375	E-4.4	Aiken @ Darby	#13	1
376	E-4.4	Aiken @ Kirk	#15, F.H. F	2
377	E-4.4	Darson Marie @ Weir	#30, 9	2
378	E-4.4	Gen. McMullen @ Weir	#2, 20	2

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 19 of 22

Line #	Plat #	Address	Valve #	# of Valves
379	E-4.4	1751 Gen. McMullen	#23	1
380	E-4.3	Weir to Jardines	#19	1
381	E-4.3	2900 block of Weir	#17	1
382	E-3.4	Barney @ Bay	#10	1
383	E-3.4	Barney @ Dahlgreen	#4	1
384	E-3.3	3627 Weir	#1	1
385	D-5.4	Ceralvo @ Cupples	#16	1
386	D-5.4	Cupples @ Patton	#21, 22, 23	3
387	D-5.1	Cupples @ Merida	#8	1
388	D-5.1	Rocco @ Mazzurana	#21	1
389	D-4.4	Ceralvo @ Balboa	#2	1
390	D-4.4	Amaya @ Juanito	#30	1
391	D-4.4	Patton @ Juanito	#31	1
392	D-4.3	Cantoria @ Ceralvo	#8	1
393	D-4.3	Posada @ Patton	#29, 32	2
394	D-4.2	Morelia @ Cardova	#2	1
395	D-4.2	Escuela @ Remolino	#12	1
396	D-4.1	Saltillo @ Southlawn	#39	1
397	D-3.3	Ceralvo @ Wescott	#31	1
398	D-3.3	Allendale @ Arteago	#22	1
399	D-3.2	Merida @ Southlawn	#13	1
400	I-5.3	Southcross @ Gifford	---	1

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 20 of 22

Line #	Plat #	Address	Valve #	# of Valves
401	K-5.3	7907 Delight	Service Valve	1
402	K-6.3	Cantrell @ E. Aviation	Service Valve	1
403	K-8.2	2717 Pleasanton	Service Valve	1
404	K-8.2	Pleasanton @ W. Harding	Service Valve	1
405	L-8.2	Creath @ Gladnell	#12, 13	2
406	Q-0.3	Somerset Rd.	F.H. DD	1
407	Q-1.1	Somerset Rd.	#21	1
408	SH-21.3	Somerset Rd. @ 1604	#7	1
409	SI-21.3	Touchstone St. @ W. Dixon	#2	1
410	SI-21.4	W. Dixon @ Pyron	#9	1
411	CD-2	Grey Oak @ Sunflower	#11, 25	2
412	CD-3	Blanco Rd. between Spent Wing and Haltown	#32	1
413	CD-3	Haltown @ Blanco Rd.	#12	1
414	CE-1	Hibiscus @ Foxhall	#2, 12	2
415	CE-1	Krameria @ West Ave.	#15	1
416	CE-2	Lockhill Selma @ Moss	#45	1
417	CE-3	Homeric @ Lockhill Selma	#41	1
418	CE-3	Northcrest @ Halbart	#24	1
419	CE-3	Tamworth @ Blanco Rd.	#14	1
420	CE-3	Briarcliff @ Blanco Rd.	#16	1
421	CE-3	Northcrest @ Blanco Rd.	#54	2

APPENDIX P
Edwards Underground Water District
Valve Stack/Cleaning Needed
1992

System: Bexar Metropolitan Water District

Page 21 of 22

Line #	Plat #	Address	Valve #	# of Valves
422	CF-2	Honeysuckle @ Loop 410	#10, 69	2
423	CF-2	Traventine @ Twinleaf	#25, 28	2
424	CF-2	Honeysuckle @ Sir Arthur	#43	1
425	CF-2	Honeysuckle @ Loop 410	#9, 19, 20, 61	4
426	CF-2	Wickford @ Squires Row	#44	1
427	CF-2	Cobblestone @ Squires Row	#41	1
428	CF-2	Wickford @ Oak Royal	#38, 39, 40	3
429	CF-2	Twinleaf @ Loop 410	#22	1
430	CF-3	Loop 410 between Briarcliff and Northcrest	#2, 3	2
431	CF-3	Loop 410 @ Northcrest	#26	1
432	CF-3	Loop 410 @ Easement	#34	1
433	CF-3	Blanco Rd.	#40	1
434	CF-3	Blanco Rd. @ Cornwall	#9	1
435	CF-3	Irongate @ Sir Arthur	#45	1
436	CF-3	Warwick @ Thames	#57	1
437	CG-2	Jackson Keller between Traventine & Shalimar	#54, 55, 56,	5
438	CG-2	113 Shalimar	#48	1
439	CG-3	Blanco @ Montfort	#25	1
440	CG-3	Montfort @ Thames	#29	1
441	CG-3	Langton @ Thames	#32	1

APPENDIX P

Edwards Underground Water District Valve Stack/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 22 of 22

<u>Line #</u>	<u>Plat #</u>	<u>Address</u>	<u>Valve #</u>	<u># of Valves</u>
442	CG-3	Langton @ York	#81	1
443	CG-3	Barchester @ Dorset	#66	1

APPENDIX Q

Edwards Underground Water District Meter Box/Cleaning Needed 1992

System: Bexar Metropolitan Water District

Page 1 of 1

Line #	Plat #	Address
1	O-10.2	1415 Santa Rita
2	M-9.4	9223 Brink Ln.
3	M-9.3	9214 Yett
4	M-9.3	9210 Yett
5	M-9.3	9314 Yett
6	M-9.3	9110 Yett
7	M-9.3	9114 Yett
8	M-9.3	806 Sams
9	M-5.1	2131 Abacus
10	K-7.2	1226 W. Harding
11	J-7.2	518 McCauley
12	J-7.1	1906 Buffalo
13	J-7.1	926 Brunswick
14	H-8.4	446 Stonewall
15	H-7.2	862 Vermont
16	H-7.1	960 Chalmers
17	F-5.3	2002 Jupiter
18	E-3.4	3826 Bay St.
19	D-4.3	135 Sylvia

APPENDIX R

Edwards Underground Water District Lids/Replacement Needed 1992

System: Bexar Metropolitan Water District

Page 1 of 5

Line #	Plat #	Address	Valve #	Type	# Needed
1	P-4.4	26955 Gaylord	---	Meter Box Lid	1
2	O-6.2	S.W. Loop 410	F.H. B	Valve Box Lid	1
3	O-7.1	S.W. Loop 410	F.H. A	"	1
4	O-5.1	S.W. Loop 410	F.H. D, 2	"	2
5	N-10.3	5323 U.S. Hwy 281	---	Meter Box Lid	1
6	N-8.2	227 Bickley	---	"	1
7	N-8.1	372 W. Villaret	---	"	1
8	N-7.2	Service west of 706 W. Mally	---	"	1
9	N-7.1	815 W. Villaret	F.H. A	Valve Box Lid	1
10	N-6.4	Zarzamora @ W. Chavaneaux	#15	"	1
11	N-6.4	Zarzamora @ Jennifer	#7	"	1
12	N-4.3	Chamita @ Wikieup	#7	"	1
13	N-4.3	State Hwy 346 @ W. Villaret	#25	"	1
14	N-4.2	Palo Alto @ W. Villaret	F.H. N	"	1
15	N-4.1	222 Tedder	---	Meter Box Lid	1
16	N-4.1	Kreuger @ Vincent	F.H. G	Valve Box Lid	1
17	M-7.2	347 W. Ansley	#10	"	1
18	M-6.2	Rockwell @ Hendrix	#2	Valve Box Lid	1
19	M-6.2	1402 Beverly Ann	---	Meter Box Lid	1
20	M-6.4	2210 Bane Blvd.	---	"	1

APPENDIX R

Edwards Underground Water District Lids/Replacement Needed 1992

System: Bexar Metropolitan Water District

Page 2 of 5

Line #	Plat #	Address	Valve #	Type	# Needed
21	M-5.3	9327 Rhoda	---	Valve Box Lid	2
22	M-4.2	129 McNarney	---	Meter Box Lid	1
23	M-4.2	2103 Palo Alto	---	"	1
24	M-4.2	2007 Palo Alto	---	"	1
25	M-4.2	8706 Prairie Hill	---	"	1
26	M-4.2	2925 Fair Meadow	---	"	1
27	M-3.4	3769 Remigio St.	---	"	1
28	L-5.2	1707 Parnell	---	"	1
29	L-5.2	Gaddis @ Marek	#4	Valve Box Lid	1
30	L-3.3	IH35	#5, F.H. F	"	2
31	K-9.3	735 Ware	---	Meter Box Lid	1
32	K-7.1	939 Sunglo	---	"	1
33	K-7.1	1007 Clovis	---	"	1
34	K-7.1	Logwood @ Sunglo	#29	Valve Box Lid	1
35	K-6.3	Cantrell	#19	"	1
36	K-5.4	Navajo @ Expressway	#19	"	1
37	K-5.4	U.S. Hwy 81	#5	"	1
38	K-2.4	Quintana Rd.	#1	"	1
39	J-9.4	Behind 192 Dickson	F.H. B	"	1
40	J-8.1	6726 Tupper		Meter Box Lid	1
41	J-6.3	1223 Rayburn	F.H. C	Valve Box Lid	1
42	J-6.3	1900 block of S.W. Military	East of F.H. F	2 Meter Box Lids	2

APPENDIX R

Edwards Underground Water District Lids/Replacement Needed 1992

System: Bexar Metropolitan Water District

Page 3 of 5

Line #	Plat #	Address	Valve #	Type	# Needed
43	J-5.3	2735 S.W. Military		Meter Box Lid	1
44	J-5.1	1555 Somerset		"	1
45	I-6.2	406 Berlin		"	1
46	I-6.2	W. Southcross @ Lardner	#9	Valve Lid	1
47	I-5.3	1302 Wagner	#19	"	1
48	I-5.2	1222 Berlin	#30	"	1
49	I-4.1	2818 W. Southcross		Meter Box	1
50	I-3.3	1024 Kings Ave.		"	1
51	I-3.3	2010 W. Mayfield		"	1
52	H-8.4	488 Stonewall		"	1
53	H-7.4	Harlan @ Buffalo	#38	Valve Box Lid	1
54	H-6.4	9155 Zarzamora		Meter Box Lid	1
55	H-6.4	5519 Zarzamora		"	1
56	H-4.4	Between Tampa and Dacus @ Quintana	#1	Valve Box Lid	1
57	H-4.3	214 Tampa		Meter Box Lid	1
58	G-6.4	Northeast corner of Bloom St.		"	1
59	F-5.4	122 W. Emerson		"	1
60	F-5.2	855 Barrett		"	1
61	F-5.2	869 Thompson		"	1
62	F-5.2	867 Thompson		"	1

APPENDIX R

Edwards Underground Water District Lids/Replacement Needed 1992

System: Bexar Metropolitan Water District

Page 4 of 5

Line #	Plat #	Address	Valve #	Type	# Needed
63	F-5.2	G.E. Kelly Elem. School W. Thompson Pl.		Meter Box Lid	1
64	F-5.2	W. Thompson @ Saturn	#10	Valve Box Lid	1
65	F-4.4	Nightengale @ Macdona	#10	"	1
66	F-4.2	Cupples between Academy and Bedford	#10	"	1
67	D-5.1	Cupples @ Merida	#8	"	1
68	D-5.1	Ricardo @ Merida	F.H. F	"	1
69	D-5.1	331 Southlawn		Meter Box Lid	1
70	F-5.1	1310 W. Thompson		"	1
71	H-6.4	5423 Zarzamora	---	"	1
72	I-6.3	Linden @ Ella	---	Valve Box Lid	1
73	J-5.1	1975 McCauley	---	Meter Box	1
74	J-7.2	424 W. Southcross		"	1
75	J-3.3	3929 S.W. Military		"	1
76	M-4.3	102 Doolittle		"	1
77	N-4.1	254 Ike		"	1
78	Q-1.1	Somerset Rd.	#21	Valve Box	1
79	P-4.4	Gaylord #26955		Meter Box	1
80	SI-21.3	19945 Casias Lane		"	1
81	SI-22.1	19609 Dove Hill Lane		"	1
82	SJ-22.1	20334 Howard Payne Rd.		"	1
83	CD-2	10122 Jandre Lane		"	1

APPENDIX R

Edwards Underground Water District Lids/Replacement Needed 1992

System: Bexar Metropolitan Water District

Page 5 of 5

Line #	Plat #	Address	Valve #	Type	# Needed
84	CF-3	Northcrest @ Loop 410	#26	Valve Box Lid	1
85	CG-3	Blanco Rd. @ Atwater	#3	"	1
86	CH-3	1794 Blanco Rd.		Meter Box Lid	1